

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI - 110001


No: F 6/DFS/MS/2012/ school/ 1140

Dated:- 29/03/12

FIRE SAFETY CERTIFICATE

Certified that the M.C.D Pratiksha School Sindhosa Kalan  
Delhi 110052 ----- comprised of Ground + one upper floor  
----- owned/occupied by M.C.D Pratiksha School  
-----  
----- Complied with the fire prevention and fire safety  
requirement in accordance with Director Edu. Circular No. F. 16 (Estate) CC / Fire Safety /  
2011/3298-3398 dt 13 ----- in the presence of Smt. Satwati ----- and that the  
building/premises is fit for occupancy Educational ----- building with  
effect from 29/03/12 ----- for a period of 03 years ----- years in compliance of the conditions  
printed overleaf.

Issued on 29/03/12 ----- at New Delhi.



Chief Fire Officer

Delhi Fire Service

Copy to:-

1. The Principal  
M.C.D Pratiksha School  
Sindhosa Kalan Delhi 110052
2. The Director of Education (M.C.D)  
Wigam Bhawan  
Kashmere Gate Delhi



1. All the means of escape shall be kept free of all type of obstruction all the time.
  2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
  3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non – functional of fire safety measures, management shall be responsible.
  4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
  5. Basement shall be used as per NBC.
  6. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

**INSPECTION REPORT**

Pralibha

1. Name & address of the building: MCD (Primary) School, Sidhori Kalan, Delhi
2. Type of Occupancy: Educational.
3. Type of Case: New Case/ Renewal
4. Details of previous NOC: Letter No. \_\_\_\_\_ Dated: \_\_\_\_\_
5. Fire Safety directives letter No: E16/state/cc/F.S/11/3298-3398 dated 1/3/2011
6. Date of inspection: 01/3/2012
7. Name of the Inspecting Officers: ADO - SHYAM LAL
8. Name and designation of officers from the building side: Smt - Satvati Goyal.
9. Year of Construction: 2008 (G+1)
10. Applicant's letter No.: NIL dated 6-2-2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	<u>Circular NBC Dir. of Edm. Requirement 1/3/2011</u>	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	<u>Accessible</u>	<u>5 mtrs.</u>	<u>M/R</u>
	• Gate width	<u>~</u>	<u>3.30 mtrs.</u>	<u>~</u>
	• Width of internal road	<u>~</u>	<u>—</u>	<u>—</u>
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
a.	Number of staircases	<u>2</u>	<u>2</u>	<u>M/R</u>
	• Upper Floors	<u>2 (1.5 mtrs)</u>	<u>2 (1.9 mtrs)</u>	<u>M/R</u>
	• Basements	<u>NIL</u>	<u>NIL</u>	<u>M/R</u>
b.	Width of staircases			
	• Upper Floors	<u>1.5 mtrs.</u>	<u>1.90 mtrs.</u>	<u>M/R</u>
	• Basements	<u>1.5 mtrs.</u>	<u>1.90 mtrs.</u>	<u>~</u>
	• Basements	<u>NIL</u>	<u>NIL</u>	<u>—</u>
c.	Protection of exits			
	• Fire check door	<u>NR</u>	<u>NR</u>	<u>~</u>
	• Pressurization		<u>NR</u>	
			<u>NR</u>	
e.	No. of continuous staircases to terrace			
g.	Width of Corridor		<u>2 m</u>	<u>M/R</u>
h.	Door Size	<u>1 m</u>	<u>1m with fitting</u>	<u>M/R</u>





	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>			
11	<b>Internal Hydrants</b>		NR	
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>			
12	<b>Yard Hydrants.</b>		NR	
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>			
13	<b>Pumping Arrangements.</b>		NR	
	<ul style="list-style-type: none"> <li>• Ground Level <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> </ul> </li> <li>• Terrace level <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>			
14	<b>Captive Water Storage for fire fighting.</b>		NR	
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> </ul>			

	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>			
15	<b>Exit Signage.</b>	Gr-1	NR	—
16	<b>Provision of Lifts.</b>		N/A	
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>			
17	<b>Standby power supply</b>		NR	
18	<b>Refuge Area.</b>		N/A	
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>			
19	<b>Fire Control Room</b>		NR	
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>			
20	Special Fire Protection Systems for Protection of special Risks, if any:		NiL	

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....



Signature of the Inspecting Officer

Name

Designation

D.O. (N/A)

Shyam Lal  
03/3/2012

Signature of the Inspecting Officer

Name

SHYAM LAL

Designation

ADD (RM)