

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI – 110001


No: F 6/DFS/MS/2011 school/ 11 42

Dated:- 28/03/12

FIRE SAFETY CERTIFICATE

Certified that the M.C.D. Primary Pratibha School, Vijay Nagar (New)
Delhi - 9 located at Vijay Nagar (New)
..... comprised of ground only occupied
by M.C.D. Primary Pratibha School was issued NOC vide this office letter
No F.6/DFS/MS/05/222 Dated: 30.1.2008 The premises was re-inspected by the
officer concerned of this department on 15.3.2012 and observed that all the fire
prevention and fire safety arrangements as provided in the premises found in good working
condition. The premises have therefore, deemed complied with the requirement under Rule 33
of the Delhi Fire Service rule 2010 and the building/premises is fit for occupancy Class
Educational with effect from 28/03/12 for a period of
..... in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under
Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service
Rules, 2010.

Issued on 28/03/12 at New Delhi.


28/3

Chief Fire Officer
Delhi Fire Service



Copy to:-

1. The Principal
M.C.D. Primary Pratibha school,
Vijay Nagar (New)
Delhi - 9

- 2:

INSPECTION REPORT

1. Name & address of the building : MCD Primary Pratibha School, Vijay Nagar (New) - Delhi-9
2. Type of Occupancy : Educational
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. F-6/DFSI/MS/08/222 Dated: 30/1/2008
5. Fire Safety directives letter No : 262-362 dt. 17-1-2005
6. Date of inspection : 12-3-2012
7. Name of the Inspecting Officers : ADO - SHYAM LAL
8. Name and designation of officers from the building side : Principal -
9. Year of Construction : 1974, (4 No's shed, ground only)
10. Applicant's letter No. : NIL dated 6-2-2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NIS Circular Dir. Edn. Requirement 17/5/2005	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	5 mtr.	MR
	• Gate width	~	1.75 mts.	~
	• Width of internal road	~	N/A	-
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases		N/A	
	• Upper Floors			
	• Basements			
	b. Width of staircases			
	• Upper Floors			
	• Basements			
	c. Protection of exits			
	• Fire check door			
	• Pressurization			
	e. No. of continuous staircases to terrace			
	g. Width of Corridor			
	h. Door Size	1 m	1 m	MR

3	Compartmentation.				
	• Fire check door				NR
	• Sealing of electrical shafts				
	• Fire Rating of shaft door				
	• Water Curtain				
	• Fire Dampers				
4	Smoke Management System.				
	• Basements	30 a/c per hour			NR
	• Upper floors	12 a/c per hour			
5	Fire Extinguishers				
	• Total numbers	300 m ² covered area for one	U		MIR
	• Types	ABC/CO ₂ Risings	ABC		m
	• IS marking	ISI marked	yes		n
6	First-Aid Hose Reels.				
	• Total numbers on each floor	_____			NR
	• Length of hose reel hose	30 m			
	• Nozzle diameter	5 mm			
7	Automatic fire detection and alarming system.				
	• Type of detectors				NR
	• Location of Main Panel				
	• Location of Repeater Panel				
	• Alternate source of power				
	• Hooters' Location				
8	MOEFA				NR
9	Public Address System.				NR
10	Automatic Sprinkler System.				
	• Basement				NR

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 			
11	Internal Hydrants			N/A
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 			
12	Yard Hydrants.			N/A
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 			
13	Pumping Arrangements.			NA
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 			
14	Captive Water Storage for fire fighting.			NA
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 			

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 			
15	Exit Signage.			NR
16	Provision of Lifts.			N/A
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			
17	Standby power supply			NR
18	Refuge Area.			N/A
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 			
19	Fire Control Room			N/A
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 			
20	Special Fire Protection Systems for Protection of special Risks, if any:			Nil

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

D.O. (Asst)
FT M. Seel
 DFO
 CPO
 22/3
 22/3
 28/3
 19/3
 28/3
 28/3
 16/3/2012
 SHYAM LAL
 Assit. Divn. Officer