

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE : NEW DELHI-110001

No: F.6/DFS/MS/2011/School/1063

Dated : 23/03/12

FIRE SAFETY CERTIFICATE

Certified that the – **M.C. Primaray School- I & II shift**, Inder Puri, New Delhi-110012 Comprised of - ground floor only, owned/occupied by Director of Education M.C.D has complied with the fire prevention and fire safety requirements in accordance with the Director of Education letter No.F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 and verified by the officer concerned of fire Service on 03.03.12 in the presence of - Smt. Sunita Chauhan Principal and that the building/premises is fit for occupancy class – group-B (educational) with effect from the date of issue of this certificate for a period of - three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules,2010 printed overleaf.

Issued on ...23/03/12.....at New Delhi.



21/3

Chief Fire Officer
Delhi Fire Service

of
mer

Copy to:

1. The Principal,
M.C. Primary School- I & II Shift,
Inder Puri,
New Delhi-110012.
2. The Director of Education
MCD Nigam Bhawan(Old Hindu Collage Bldg)
Kashmere Gate, Delhi.
3. Divisional Officer (South West)
Shanker Road Fire Station, New Delhi

GF(only)

INSPECTION REPORT

1. Name & address of the building : M.C Primary School, Indershan - 129 N Delhi
2. Type of Occupancy : Educational
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. Nil Dated: _____
5. Fire Safety directives letter No : FG/DP2/MS/2011 dt 13.5.11.
6. Date of inspection : 03.03/12
7. Name of the Inspecting Officers : D.O. H.C. Anje
8. Name and designation of officers from the building side : Mrs Sumita Chawan.
9. Year of Construction : 1 -
10. Applicant's letter No. : Nil dt 20.1.12

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	R	9mtr	MR
	• Gate width	R	3.70 mtr	MR
	• Width of internal road	—	—	—
2	Number, Width, Type & Arrangement of Exits	NR	—	—
	a. Number of staircases	—	—	—
	• Upper Floors	—	—	—
	• Basements	—	—	—
	b. Width of staircases	—	—	—
	• Upper Floors	—	—	—
	• Basements	—	—	—
	c. Protection of exits	—	—	—
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	—	—	—
	g. Width of Corridor	—	—	—
	h. Door Size	R	111 Cms	MR

3	Compartmentation.				
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NR			
4	Smoke Management System.				
	<ul style="list-style-type: none"> • Basements • Upper floors 	NR	30 a/c per hour		
			12 a/c per hour		
5	Fire Extinguishers	R	P.		MR
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 		4 Nos		MR
		ISI marked	Abe type		MR
			Yes		MR
6	First-Aid Hose Reels.	NR			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 		30 m		
			5 mm		
7	Automatic fire detection and alarming system.	NR			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 				
8	MOEFA				
9	Public Address System.	NR			
10	Automatic Sprinkler System.				
	<ul style="list-style-type: none"> • Basement 				

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 	—	—	—
11	Internal Hydrants	NR		
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	—	—	—
12	Yard Hydrants.	NR		
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	—	—	—
13	Pumping Arrangements.	NR		
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	—	—	—
14	Captive Water Storage for fire fighting.	NR		
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 	—	—	—

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	✓	✓	✓
15	Exit Signage.	NR	✓	✓
16	Provision of Lifts.	NR	✓	✓
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	✓	✓	✓
17	Standby power supply	NR	✓	✓
18	Refuge Area.	NR	✓	✓
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	✓	✓	✓
19	Fire Control Room	NR	✓	✓
	<ul style="list-style-type: none"> • Detector System Panel • Flw Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	NR	✓	✓
20	Special Fire Protection Systems for Protection of special Risks, if any:	NR	✓	✓

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers..... Nil.....

Signature of the Inspecting Officer

Name

Designation



Signature of the Inspecting Officer

Name H. L. ANEJA

Designation Div. Officer

5