

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE,
NEW DELHI**


No. F6/MS/DFS/GH/2012/ 1181

Dated: 29/03/12

FIRE SAFETY CERTIFICATE

Certified that the Shan Guest House, located at 753, Old Motor Market, Jama Masjid, Delhi-110006 comprised of ground floor (Commercial use), 1st floor (05 guest rooms + Reception + Office), 2nd floor (06 guest rooms) and 3rd floor (06 guest rooms), total 17 guest rooms was granted NOC by this department vide letter No. F6/DFS/MS/GH/2008/3079 dated 11-11-2008. The premises was re-inspected by the officer concerned of this department on 15-03-2012 in the presence of Sh. Rahish Malik and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of 17 guest rooms with effect from .29/03/12...2012 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued .29/03/12 at New Delhi by.


29/3
CHIEF FIRE OFFICER
FOR DIRECTOR
DELHI FIRE SERVICE

Copy to :-

1. The Addl. Commissioner of Police (Lic.), First Floor, P.S. Defence Colony, New Delhi – 110049
2. Sh.Rahish Malik, M/s Shan Guest House, 753 Old Motor Marker, Jama Masjid, Delhi-110006.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

INSPECTION REPORT

*Shan Guest House, 753 old
Motee market, Jama Masjid,
Delhi-110006*

1. Name & address of the building : _____
2. Type of Occupancy : Residential (Guest House)
3. Type of Case : New Case/ Renewal ✓
4. Details of previous NOC : Letter No. FG/M.S./DFS/G.M/08/13079 Dated: 11-11-08
5. Fire Safety directives letter No : - N.A -
6. Date of inspection : 15-03-12
7. Name of the Inspecting Officers : Dharm vir singh yadav
8. Name and designation of officers from the building side : Mr. Rakish Malik.
9. Year of Construction : 2001 (starting year)
10. Applicant's letter No. : NIL dated 01-03-2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks <i>old case</i> MR/NMR <i>P.S. Akla</i>
1	Access to building			
	• Road width	<i>Accessible</i>	<i>more than 06 Mtrs.</i>	<i>M.R.</i>
	• Gate width	<i>- N.A -</i>	<i>- N.A -</i>	<i>- N.A -</i>
	• Width of internal road	<i>- N.A -</i>	<i>- N.A -</i>	<i>- N.A -</i>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	<i>-</i>	<i>one</i>	<i>M.R</i>
	• Upper Floors	<i>-</i>	<i>one</i>	<i>M.R</i>
	• Basements	<i>- N.A -</i>	<i>- N.A -</i>	<i>- N.A -</i>
	b. Width of staircases			
	• Upper Floors	<i>-</i>	<i>86 cm</i>	<i>M.R</i>
	• Basements	<i>- N.A -</i>	<i>- N.A -</i>	<i>- N.A -</i>
	c. Protection of exits			
	• Fire check door	<i>- N.A -</i>	<i>-</i>	
	• Pressurization			
	e. No. of continuous staircases to terrace	<i>-</i>	<i>one</i>	<i>M.R</i>
	g. Width of Corridor	<i>- N.A -</i>	<i>- N.A -</i>	<i>- N.A -</i>
	h. Door Size	<i>- N.A -</i>	<i>- N.A -</i>	<i>- N.A -</i>

contd:-

Shan Guest House, 753,
 Old motor market, Jama Masjid,
 Delhi-110006.

old
 call

P.S.S. 178a

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	— N.A —		
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	— N.A — natural ventilation	— N.A — M.R.
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	ISI marked	Eight CO ₂ type & A.B.C. type yes	M.R. M.R. M.R.
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	one 30 m 5 mm	one yes yes	M.R. M.R. M.R.
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	— N.A —		
8	MOEFA	Required	Provided	M.R.
9	Public Address System.	— " —	— " —	M.R.
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	— N.A —		

contd.:

Shan Guest House, 753, old motor market
Jama masjid, Delhi-110006.

old case
PSS Mem

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	— N.A. —	— N.A. —	— N.A. —
		—	Provided	M.R.
		2500 litres	2500 litres	M.R.
15	Exit Signage.	Required	Provided	M.R.
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	— N.A. —		
	• Pressurization of Lift lobby			
	• Communication In lift Car			
	• Fireman's Grounding Switch			
	• Lift Signage			
17	Standby power supply	—	D.G. Set	M.R.
18	Refuge Area.		12.5KVA	
	➤ Total Area	— N.A. —		
	➤ Location			
19	Fire Control Room			
	• Detector System Panel	— N.A. —		
	• Flow Switch Panel			
	• PA System Panel			
	• Batter backup			
	• Building Floor Plans			
20	Special Fire Protection Systems for Protection of special Risks, if any:	— N.A. —		

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers~~.....


Contd. :-

Shan Guest House, 753, old metro market,
Jama masjid, Delhi-110006.

Signature of the Inspecting Officer

Name

Designation


Signature of the Inspecting Officer

Name *Dr. Ramvir Singh Yadav.*

Designation *Assistant Dir.*