

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS : DELHI FIRE SERVICE : CONNAUGHT LANE  
NEW DELHI-110 001.


No. F6/2FS/MS/School/2012/1125

Dated : 28/03/12

FIRE SAFETY CERTIFICATE

Certified that the **VIKRAM PUBLIC SCHOOL** located at **L-Block, Prem Nagar-II, Near 40 Feet Road, Nangloi, Delhi-110 041**, comprised of ground plus one upper floor only and less than 9 meters in height, have complied with the fire prevention and fire safety requirement in accordance with Director of Education circular dated 01.03.2001 and verified by the officer concerned of fire service on 21.12.2011 in the presence of Mrs. Sonia, Manager and that the building/ premises is fit for occupancy class **Educational class** with effect from 28/03/12 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 28/03/12 at New Delhi by

  
28/3  
Chief Fire Officer  
Delhi Fire Service

Mrs. Sonia, Manager,  
VIKRAM PUBLIC SCHOOL,  
L-Block, Prem Nagar-II,  
Near 40 Feet Road,  
Nangloi, Delhi-110 041.



Copy to :

The Director,  
Dte. Of Education,  
Old Sectt., Delhi.

Conditions for the validity of fire safety certificate:-

- All the fire safety means of escape facilities shall be maintained in good conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be responsibility of the management.
- Building sanctioning authority may verify any deviation with regard to the construction/ occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.

May kindly peruse letter no.NIL dated 18.10-2011 received from Mrs. Sonia (Manager) Vikram Public School, L Block, Prem Nagar-II Near 40 feet road, Nangloi, Delhi-110041 regarding issue of NOC from fire and safety point of view. The premises was inspected by the undersigned on dated 21.12.11 & observed that the school building is comprised of ground plus one upper floor only. However following fire safety measures are put up on the prescribe Performa

1. Name & address of the building : Vikram Public School L Block, Prem Nagar-II Near  
40 feet road, Nangloi, Delhi-110041 .
2. Type of Occupancy : Class –B (Educational)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2006/1964 dated 07-08-2006.
5. Fire Safety directives letter No. : F16/Estate/CC/Fire safety/2011/3298-3398 dt. 1-3-2001.
6. Date of inspection : 21/12/2011
7. Name of the Inspecting Officers : Sh. S.S. Tuli, A.D.O.
8. Name and designation of officers  
From the building side : Mrs. Sonia (Manager)
9. Year of Construction : 1996
10. Applicant's letter No. : nil dated 18-10-2011

### INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	9 mtr Accessible	9.5 App. Accessible	MR
	• Gate width	4.5 mtrs	9.5 mtr App.	M/R
	• Width of internal road	N.R.	NR	N.R.
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			

	a. Number of staircases	Two	Two	MR	
	• Upper Floors	Two	Two	M/R	
	• Basement	N.A.	N.A.	NR	
	b. Width of staircases	150 Cms each	150 Cms. each	MR	
	• Upper Floors	150 cms each	P	M/R	
	• Basement	150.	P.	MR	
	c. Protection of exits	NR	NR	NA	
	• Fire check door	NR	N.R.	NR.	
	• Pressurization	N/R	N/R	NR	
	d. No. of continuous staircases to terrace	two	two	M/R	
	e. Width of Corridor	1.5mtrs.	2 mtrs.	M/R	
	f. Door size	100cms	100cms	M.R.	
	3.	<b>Compartmentation.</b>			
		• Fire check door	N/R	N/R	N/R
• Sealing of electrical shafts		N/R	N/R	N/R	
• Fire Rating of shaft door		N/R	N/R	N/R	
• Water Curtain		N/R	N/R	N/R	
• Fire Dampers		N/R	N/R	N/R	
4.	<b>Smoke Management System.</b>				
	• Basements	N.A.	N.A.	N/R	
	• Upper floors	N/R	N/R	N/R	
5.	<b>Fire Extinguishers</b>	<b>Required</b>	<b>Provided</b>	<b>MR</b>	
	• Total numbers	4	Four	M/R	


	<ul style="list-style-type: none"> <li>Types</li> <li>IS marking</li> </ul>	Required	ABC type	M/R
		ISI marked	ISI marked	M/R
<b>6.</b>	<b>First-Aid Hose Rees.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	N/R	Two	M/R
		30 m	30 m	11
		5 mm required	5 mm	11
<b>7.</b>	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooter's Location</li> </ul>	N/R	N/R	N/R
		N/R	N/R	N/R
		N/R	N/R	N/R
		N/R	N/R	N/R
		N/R	N/A	N/R
<b>8.</b>	<b>MOEFA</b>	Required	Provided	M/R
<b>9.</b>	<b>Public Address System.</b>	Required	Provided	M/R
<b>10.</b>	<b>Automatic Sprinkler system</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	N.R.	N.R.	N.R.
		N/R	N/R	N.R.
		N/R	N/R	N.R.
<b>11.</b>	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> </ul>	N.R.	N.R.	N.R.
		N.R.	N.R.	N.R.

	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	N.R.	N.R.	N.R.
<b>12.</b>	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	N/R	N/R	N/R
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	N/R	N/R	N/R
<b>13.</b>	<b>Pumping Arrangements.</b>			
	<b>Ground Level</b>			
	➤ Discharge of main pump	N/R	N/R	N/R
	➤ Head of Main pump	N/R	N/R	N/R
	➤ Number of main pumps	N/R	N/R	N/R
	➤ Jockey Pump out put	N/R	N/R	N/R
	➤ Jockey pump head	N/R	N/R	N/R
	➤ Standby pump out put	N/R	N/R	N/R
	➤ Standby pump Head	N/R	N/R	N/R
	➤ Auto Starting/Manual stopping	N/R	N/R	N/R
	➤ Pump Hose Access	N/R	N/R	N/R
	<b>Terrace level</b>			
	➤ Discharge of pump	450 LPM	450LPM	
	➤ Head of the pump	40mtr	40mtr	
	➤ Power supply	Required	Provided	
	➤ Auto Starting of pump	N/R	N/R	N/R
<b>14.</b>	<b>Captive Water Storage for fire fighting.</b>			

	<b>Underground tank capacity</b>			
	➤ Draw -off connection	N/R	N/R	
	➤ Fire service inlet	N/W	N/R	
	➤ Access to tank	N/R	N/R	
	➤ Overhead Tank Capacity	2500 ltrs	2500 ltrs	
<b>15</b>	<b>Exit Signage.</b>	Required	Provided	M/R
<b>16.</b>	<b>Provision of Lifts</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/R
	• Pressurization of Lift lobby	N/A	N/A	N/R
	• Communication In lift Car	N/A	N/A	N/R
	• Fireman's Grounding Switch	N/A	N/A	N/R
	• Lift Signage	N/A	N/A	N/R
<b>17.</b>	<b>Standby power supply</b>			
<b>18.</b>	<b>Refuge Area</b>			
	➤ Total Area	N/R	N/R	
	➤ Location	N/R	N/R	
<b>19.</b>	<b>Fire Control Room</b>			
	➤ Detector System Panel	N/R	N/R	N/R
	➤ Flow Switch Panel	N/R	N/R	N/R
	➤ PA system Panel	N/R	N/R	N/R
	➤ Batter backup	N/R	N/R	N/R


	➤ Building Floor plans	N/R	N/R	N/R
20.	Special Fire Protection Systems for  Protection of special Risks, if any:	N/R	N/R	N/R

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial number.....

Signature of the Inspection Officer  
  
 Inspection Officer  
 S.S. Tuli  
 ADO (M.N.)

Name S.S. Tuli

Designation A.D.O.

Signature of the  


Name SUNIL CHANDRA

Designation D.O.