

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI - 110001


No: F 6/DFS/MS/2012 *School 11252*

Dated:- *10/04/12*

FIRE SAFETY CERTIFICATE

Certified that the *Bright star Convent Public School, A-153, Shastri-*
park ext., Phool bagh Road, Barari, Delhi, comprised of *ground + one*
upper floor owned/occupied by *Bright star Public*
Convent school complied with the fire prevention and fire
safety requirement in accordance with rule 33 of the Delhi Fire Service Rule 2010 and verified
by the officer concerned of Fire Service on *29/3/12* in the presence of
Sh. Ashwani Kumar and that the building/premises is fit for occupancy
Educational building with effect from *10/04/12* for a period of
.....in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under
Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service
Rules, 2010.

Issued on *10/04/12* at New Delhi.


Chief Fire Officer

Delhi Fire Service

Copy to:-

The manager
Bright star Convent Public school,
A-153, Shastri Park ext.,
Phool bagh Road, Barari, Delhi

.....
.....
.....

Note:- Guidelines overleaf may also be taken care of.

INSPECTION REPORT

1. Name & address of the building Bright Star Convent Public School, A-153, Phool bagh
2. Type of Occupancy Education. - Road, Shastri Park Ext., Buzurg, Delhi
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. Nil Dated: —
5. Fire Safety directives letter No F-6/cstat/f.safety/CC/11/3298-3398 dated 3/3/2011
6. Date of inspection 29-3-2012
7. Name of the Inspecting Officers : ADO - SHYAM LAL
8. Name and designation of officers from the building side : Sh. Ashwani Kumar (H.M.)
9. Year of Construction 2003, Ground + one.
10. Applicant's letter No. : 01 dated 16-2-2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Circulars Genl. Director Requirement 1/3/2012	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	6 mtrs.	M/R
	• Gate width	—	2.5 mtrs.	M/R
	• Width of internal road	—	N/A	M/R
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	2	2	M/R
	• Upper Floors	2	2	M/R
	• Basements	Nil	Nil	—
	b. Width of staircases	1.5 mtrs.	1.5 m & 2 mtrs.	M/R
	• Upper Floors	1.5 mtrs.	1.5 m & 2 mtrs.	M/R
	• Basements	Nil	Nil	—
	c. Protection of exits			
	• Fire check door		NR	
	• Pressurization			
	e. No. of continuous staircases to terrace	2	2	M/R
	g. Width of Corridor	—	1.15	M/R
	h. Door Size	1 m	1 m	M/R

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 			
11	Internal Hydrants			NIR
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 			
12	Yard Hydrants.			NIR
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 			
13	Pumping Arrangements.			NR
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 			
14	Captive Water Storage for fire fighting.			NIR
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 			

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 			
15	Exit Signage.	G+1	NIR	
16	Provision of Lifts.		N/A	
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			
17	Standby power supply		NIR	
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 			
19	Fire Control Room		NIR	
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 			
20	Special Fire Protection Systems for Protection of special Risks, if any:		NsL	

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

✗

Signature of the Inspecting Officer

Name

Designation

D.O. (NW) - 21/3/12
- 412
~~DCFO~~

Shyam Lal
31/3/2012

Signature of the Inspecting Officer

Name

SHYAM LAL

Designation

Assist. Dim. Officer.