

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No F 6 / DFS / MS / 2012 / GH / 1309

Dated 12/04/12

**FIRE SAFETY CERTIFICATE**

Certified that the Krishna, Guest House at 45, Arakashan Road, Pahar Ganj, New Delhi comprised of Ground + Four upper floors having 40 guest rooms (Ground floor has 06 guest rooms + Reception + Lobby + Office First to Third floor has 10 Guest rooms at each floor, Forth floor has 04 guest room) was granted NOC by this department vide letter No F 6 / DFS / MS / GH / 2010 / 641 dated 05.03.2010. The premise was re-inspected by the officer concerned of this department on 03.04.2012 in the presence of Mr. Ramesh Kumar and found that the said Guest House have deemed complied with fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Residential" A-I with effect from 12/04/12 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 12/04/12 at New Delhi



Chief Fire Officer  
For Director  
Delhi Fire Service

mem  
etc

Copy to: -

- 1) The Addl. Comm. of Police (Lic) First Floor, Police Station Defence Colony, New Delhi.
- 2) The Owner, Krishna, Guest House at 45, Arakashan Road, Pahar Ganj, New Delhi.

Conditions for the validity of fire safety certificate

- 1) All the means of escape/entry/exit shall be kept free from any obstruction.
- 2) All the fire protection measures shall be maintained in perfect working conditions all the times as seen during inspection.
- 3) All the staff members must know the correct method operation of fire fighting system.
- 4) Any lapse rendering fire fighting system/equipment non-functional shall be risk and responsibility of the management.
- 5) This inspection report may not in any way be treated as regularization of unauthorized construction, if any.
- 6) The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
- 7) This NOC is for Guest Rooms only.

## INSPECTION REPORT

1. Name & address of the building: Hotel KRISHNA, 45, A.K. Road, P.G. Delhi
2. Type of Occupancy: Residential
3. Type of Case: RENEWAL
4. Details of previous NOC: Letter No FC/OFS/MS/GH/20/0/641 dated 5/3/20/0  
N/A
5. Fire Safety directives Letter No.: \_\_\_\_\_
6. Date of inspection: 5/04/12
7. Name of the Inspecting Officer: D.S. Yadav & ATULGARG
8. Name and designation of Officer from the building side: MR Goyal
9. Year of Construction: N/A
10. Applicant's letter No.: RCG/HK/FIRE NOC/20/2 dated 24/03/12

| S No | Minimum standards on fire prevention and fire safety U/R 33 | BBL Requirements | Provided at site | Remarks MR/NMR |
|------|---|------------------|------------------|----------------|
| 1.   | Access of building  |                  |                  |                |
|      | • Road width  | <u>6mts</u>      | <u>Yes</u>       | <u>MR</u>      |
|      | • Gate width  | <u>N/A</u>       | <u>N/A</u>       | <u>N/A</u>     |
|      | • Width of internal road                                    | <u>N/A</u>       | <u>N/A</u>       | <u>N/A</u>     |
| 2.   | Number, width, Type & Arrangements of exits                 |                  |                  |                |
|      | a. Number of staircases                                     |                  |                  |                |
|      | • Upper floors  | <u>1</u>         | <u>1</u>         | <u>MR</u>      |
|      | • Basements   | <u>N/A</u>       | <u>N/A</u>       | <u>N/A</u>     |
|      | b. <u>Width of staircases.</u>                              |                  |                  |                |
|      | • Upper floors  | <u>1.25m</u>     | <u>1.25m</u>     | <u>MR</u>      |
|      | • Basements   | <u>N/A</u>       | <u>N/A</u>       | <u>N/A</u>     |
|      | c. <u>Protection of exits.</u>                              |                  |                  |                |
|      | • Fire check door   | <u>N/A</u>       | <u>N/A</u>       | <u>N/A</u>     |
|      | • Pressurization  | <u>N/A</u>       | <u>N/A</u>       | <u>N/A</u>     |
|      | d. No of continuous staircase to terrace                    | <u>1</u>         | <u>1</u>         | <u>MR</u>      |
|      | e. Width Of Corridor  | <u>N/A</u>       | <u>N/A</u>       | <u>N/A</u>     |
|      | f. Door Size  | <u>N/A</u>       | <u>N/A</u>       | <u>N/A</u>     |
| 3.   | Compartmentation  |                  |                  |                |
|      | • Fire check door   | <u>N/A</u>       |                  |                |

1

1

17

18.

|     |   |                 |         |                   |
|-----|---|-----------------|---------|-------------------|
|     | <ul style="list-style-type: none"> <li>Water Curtain</li> </ul>                 | N/A             | N/A     | N/A               |
|     | <ul style="list-style-type: none"> <li>Fire Dampers</li> </ul>                  | N/A             | N/A     | N/A               |
|     |   | N/A             | N/A     | N/A               |
| 4.  | Smoke managements System  |                 |         |                   |
|     | <ul style="list-style-type: none"> <li>Basements</li> </ul>                     | 30 a/c per hour | N/A     | N/A               |
|     | <ul style="list-style-type: none"> <li>Upper floors</li> </ul>                  | 12 a/c per hour | N/A     | N/A               |
| 5.  | Fire Extinguishers  |                 |         |                   |
|     | <ul style="list-style-type: none"> <li>Total numbers</li> </ul>                 |                 | 10      | YS/MR             |
|     | <ul style="list-style-type: none"> <li>Types</li> </ul>                         |                 | WT, CO2 | MR                |
|     | <ul style="list-style-type: none"> <li>IS marking</li> </ul>                    | ISI marked      | YS      | YS                |
| 6.  | First - Aid Hose Reels  |                 |         |                   |
|     | <ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>   | one             | one     | MR                |
|     | <ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>      | 30              | YS      | MR                |
|     | <ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>               | 5m              | YS      | MR                |
| 7.  | Automatic fire detection and alarming system                                    |                 |         |                   |
|     | <ul style="list-style-type: none"> <li>Type of detectors</li> </ul>             | N/A             | N/A     | <del>MR</del> N/A |
|     | <ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>        | N/A             | N/A     | N/A               |
|     | <ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>    | N/A             | N/A     | N/A               |
|     | <ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>     | N/A             | N/A     | N/A               |
|     | <ul style="list-style-type: none"> <li>Hooters' Location</li> </ul>             | N/A             | N/A     | N/A               |
| 8.  | MOEFA   | YS              | YS      | MR                |
| 9.  | Public Address System   | YS              | YS      | MR                |
| 10. | Automatic Sprinkler System  |                 |         |                   |
|     | <ul style="list-style-type: none"> <li>Basements</li> </ul>                     | N/A             | N/A     | N/A               |
|     | <ul style="list-style-type: none"> <li>Upper Floor</li> </ul>                   | N/A             | N/A     | N/A               |
|     | <ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul> | N/A             | N/A     | N/A               |
| 11. | Internal Hydrants   |                 |         |                   |
|     | <ul style="list-style-type: none"> <li>Size of riser/down- comer</li> </ul>     | 100mm           | YS      | MR                |
|     | <ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>  | 2               | YS      | MR                |
|     | <ul style="list-style-type: none"> <li>Hose Box</li> </ul>                      | 2               | YS      | MR                |
| 12. | Yard Hydrants   |                 |         |                   |
|     | <ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>      | N/A             | N/A     | N/A               |
|     | <ul style="list-style-type: none"> <li>Hose Box</li> </ul>                      | N/A             | N/A     | N/A               |

|     |  |         |         |     |
|-----|--|---------|---------|-----|
| 13. | Pumpings Arrangements  |         |         |     |
|     | <ul style="list-style-type: none"> <li>• Ground Level</li> <li>• Discharge of main pump</li> </ul> | N/A     |         |     |
|     | ➤ Head of main pump  | N/A     |         |     |
|     | ➤ Number of main pumps   | N/A     |         |     |
|     | ➤ Jockey pump out put  | N/A     |         |     |
|     | ➤ Jockey pump head   | N/A     |         |     |
|     | ➤ Standby Pump out put   | N/A     |         |     |
|     | ➤ Standby Pump Head  | N/A     |         |     |
|     | ➤ Auto Staring/Manual stopping   | N/A     |         |     |
|     | ➤ Pump House Access  | N/A     |         |     |
|     | • Terrace level  |         |         |     |
|     | ➤ Discharge of pump  | 450 lpm | 450 lpm | Ys. |
|     | ➤ Head of the pump   | 450 lpm | Ys      | MR  |
|     | ➤ Power supply   | 30      | 30      | MR  |
|     | ➤ Auto starting of pump  | Ys      | Ys      | Ys  |
| 14. | Captive water Storage for fire fighting  |         |         |     |
|     | • Under ground tank capacity   | N/A     |         |     |
|     | ➤ Draw of connection   | N/A     |         |     |
|     | ➤ Fire service inlet   | N/A     |         |     |
|     | ➤ Access to tank   | N/A     |         |     |
|     | • Overhead Tank capacity   | 5000L   | Ys      | MR  |
| 15  | Exit Signage   | Ys      | Ys      | MR  |
| 16. | Provision of Lifts   |         |         |     |
|     | ➤ Pressurization of Lift Shaft   | N/A     |         |     |
|     | ➤ Pressurization of lift lobby   | N/A     |         |     |
|     | ➤ Communication in lift Car  | N/A     |         |     |
|     | ➤ Fireman's Grounding Switch   | N/A     |         |     |
|     | ➤ Lift Signage   | N/A     |         |     |
| 17. | Standby power supply   | Ys      | Ys      | MR  |
| 18. | Refuge Area  |         |         |     |
|     | ➤ Total area   | N/A     | N/A     | N/A |
|     | ➤ Location   | N/A     | N/A     | N/A |

|     |  |     |  |  |
|-----|--|-----|--|--|
| 19. | Fire control room  |     |  |  |
|     | ➤ Detector system panel  | N/A |  |  |
|     | ➤ Flow Switch Panel  | N/A |  |  |
|     | ➤ PA System Panel  | N/A |  |  |
|     | ➤ Batter backup  | N/A |  |  |
|     | ➤ Building Floor Plans   | N/A |  |  |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any; | N/A |  |  |

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers

Signature of the Inspecting Officer

Name

Designation

Signature of the Inspecting Officer

Name

Designation

*Atul Gars*  
ATUL GARS

DD / LI

*D.S. Yadav*

D.S. Yadav

A.D. (center)