

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI - 110 001


No. F6/DFSS/MS/GH/2012/4734

Dated: 21/12/12

**Fire Safety Certificate**

Certified that the 3 -B Houses Guest House at F-31,32,DBM Market, Karol Bagh,New Delhi, is run at first & second floor of the building comprised of ground floor (Commercial),first floor(reception + 06 guest rooms), second floor ( 09 guest rooms) & 3<sup>rd</sup> floor (owner residence) ,total 15 guest rooms, owned/occupied by 3 -B Houses Guest House have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 12.11.12 in the presence of Sh.Satesh Bajaj, owner of the guest house and that first & second floor of the building is fit for occupancy Group A (Residential Building),with effect from 21.12.12 for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,printed overleaf.

Issued on.....21/12/12.....at New Delhi by



Chief Fire Officer  
Delhi Fire Service

OK  
ME

Copy to:-

1. Addl. Commissioner of Police (Lic.),  
First Floor, P.S. Defence Colony,  
New Delhi-110049.
2. Ms. Raman Bajaj  
3 -B Houses Guest House  
F-31,32,DBM Market, Karol Bagh,  
New Delhi -110005.

### CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate can not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

### INSPECTION REPORT

1. Name & address of the building: 3 B Houses Guest House at F-31-32, DBM Market, Karol Bagh, ND-05.
2. Building Comprised of : Ground plus three upper floors.
3. Type of Occupancy : Residential ( Guest House)
4. Type of Case : New
5. Details of Previous NOC : -----
6. Fire Safety directives No : -----
7. Date of Inspection : 12.11.12
8. Name of the Inspecting Officer : DO Virendra Singh
9. Name of the designation of Officer  
From the building side : Sh.Satesh Bazar ( owner)
10. Year of Construction : -----
11. Application / letter No : 59401-04/Addl.C.P./Lic.(H) dated New Delhi 09.10.2012

|    | Minimum Standards on fire prevention and fire safety U/R33  | Old building Requirement | Provided at Site                         | Remarks     |
|----|---|--------------------------|--|-------------|
| 1  | Access to building  |                          |  |             |
|    | <ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>  | -----                    | 06 Mtrs.                                 | MR          |
| 2  | Number, Width, Type and Arrangement of Exits  |                          |  |             |
|    | a. Number of Staircases   | -----                    | -----                                    | -----       |
|    | <ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basement</li> </ul>   | 0 1 No.                  | 01 No.                                   | MR          |
|    | B. Width of Staircases  |                          |  |             |
|    | <ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basement</li> </ul>   | 1.25 M                   | <sup>bet<sup>m</sup></sup> 1.25M & 1.5 M | MR          |
|    | c. Protection of exits  |                          |  |             |
|    | <ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>   | N/A                      | -----                                    | -----       |
|    | e. No. of continuous staircases to terrace  |                          |  |             |
|    | g. Width of Corridor  | N/A                      | 1.80 M                                   | MR          |
|    | h. Door Size  | -----                    | 1.0 M                                    | MR          |
| 3  | Compartmentation.   |                          |  |             |
|    | <ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire rating of shaft door</li> <li>• Water curtain</li> <li>• Fire Dampers</li> </ul> | N/A                      | -----                                    | -----       |
| 4  | Smoke Management System.  |                          |  |             |
|    | <ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper floor</li> </ul>   | -----<br>Required        | -----<br>Natural ventilation             | -----<br>MR |
| 5. | Fire Extinguisher   |                          |  |             |
|    | <ul style="list-style-type: none"> <li>• Total numbers</li> </ul>   | 06 nos.                  | 06 Nos.                                  | MR          |

[ Stair bet<sup>m</sup>, 1.25 to 1.5 m wide ]

|    |  |             |            |       |
|----|--|-------------|------------|-------|
|    | <ul style="list-style-type: none"> <li>types</li> </ul>                            | ABC & Co2   | ABC & Co2  | MR    |
|    | <ul style="list-style-type: none"> <li>IS marking</li> </ul>                       | ISI marked  | ISI marked | MR    |
| 6  | First-aid-Hose Reels.  |             |            |       |
|    | <ul style="list-style-type: none"> <li>Total numbers of each floor</li> </ul>      | 1 no.       | Provided   | MR    |
|    | <ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>         | 30 m        | Provided   | MR    |
|    | <ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>                  | 5 mm        | Provided   | MR    |
| 7  | Automatic fire detection and alarming system.                                      |             |            |       |
|    | <ul style="list-style-type: none"> <li>Type of detectors</li> </ul>                | N/A         | -----      | ----- |
|    | <ul style="list-style-type: none"> <li>Location of main panel</li> </ul>           | N/A         | -----      | ----- |
|    | <ul style="list-style-type: none"> <li>Location of repeater panel</li> </ul>       | N/A         | -----      | ----- |
|    | <ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>        | Required    | DG Set     | MR    |
|    | <ul style="list-style-type: none"> <li>Hooters's location</li> </ul>               | .....       | .....      | ..... |
| 8  | MOEFA  | Required    | provided   | MR    |
| 9  | Public address System.   | Required    | provided   | MR    |
| 10 | Automatic Sprinkler System.  |             |            |       |
|    | <ul style="list-style-type: none"> <li>basement</li> </ul>                         | N/A         | -----      | ----- |
|    | <ul style="list-style-type: none"> <li>upper floor</li> </ul>                      | N/A         | -----      | ----- |
|    | <ul style="list-style-type: none"> <li>sprinkler above false ceiling</li> </ul>    | N/A         | -----      | ----- |
| 11 | Internal Hydrants  |             |            |       |
|    | <ul style="list-style-type: none"> <li>size of riser/down-comer</li> </ul>         | -----       | -----      | ----- |
|    | <ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>     | -----       | -----      | ----- |
|    | <ul style="list-style-type: none"> <li>Hose Box</li> </ul>                         | -----       | -----      | ----- |
| 12 | Yard Hydrants.   |             |            |       |
|    | <ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>         | N/A         | -----      | ----- |
|    | <ul style="list-style-type: none"> <li>Hose Box</li> </ul>                         | N/A         | -----      | ----- |
| 13 | Pumping Arrangements.  |             |            |       |
|    | <ul style="list-style-type: none"> <li>Ground Level</li> </ul>                     | N/A         | -----      | ----- |
|    | <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> </ul>         | N/A         | -----      | ----- |
|    | <ul style="list-style-type: none"> <li>➤ Head of Main Pump</li> </ul>              | N/A         | -----      | ----- |
|    | <ul style="list-style-type: none"> <li>➤ Number of main pumps</li> </ul>           | N/A         | -----      | ----- |
|    | <ul style="list-style-type: none"> <li>➤ Jockey pump out put</li> </ul>            | N/A         | -----      | ----- |
|    | <ul style="list-style-type: none"> <li>➤ Jockey pump head</li> </ul>               | N/A         | -----      | ----- |
|    | <ul style="list-style-type: none"> <li>➤ Standby pump out put</li> </ul>           | N/A         | -----      | ----- |
|    | <ul style="list-style-type: none"> <li>➤ Standby pump Head</li> </ul>              | N/A         | -----      | ----- |
|    | <ul style="list-style-type: none"> <li>➤ Auto Starting /Manual stopping</li> </ul> | N/A         | -----      | ----- |
|    | <ul style="list-style-type: none"> <li>➤ Pump House Access</li> </ul>              | N/A         | -----      | ----- |
|    | <ul style="list-style-type: none"> <li>Terrace Level</li> </ul>                    |             |            |       |
|    | <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> </ul>              | 450 LPM     | Provided   | MR    |
|    | <ul style="list-style-type: none"> <li>➤ Head of the Pump</li> </ul>               | 40 Mtrs     | 40 Mtrs.   | MR    |
|    | <ul style="list-style-type: none"> <li>➤ Power supply</li> </ul>                   | Electricity | Provided   | MR    |
|    | <ul style="list-style-type: none"> <li>➤ Auto Starting of pump</li> </ul>          | Required    | Provided   | MR    |
| 14 | Captive Water Storage for Fire Fighting.   |             |            |       |
|    | <ul style="list-style-type: none"> <li>Underground tank capacity</li> </ul>        | N/A         | -----      | ----- |

|    |  |              |          |       |
|----|--|--------------|----------|-------|
|    | ➤ Draw-off connection  | N/A          | -----    | ----- |
|    | ➤ Fire service inlet   | N/A          | -----    | ----- |
|    | ➤ Access to tank   | N/A          | -----    | ----- |
|    | • Overhead Tank capacity   | 10,000 Ltrs. | Provided | MR    |
| 15 | Exit Signage.  | Required     | Provided | MR    |
| 16 | Provision of Lifts.  |              |          |       |
|    | • Pressurization of Lift Shaft   | N/A          | -----    | ----- |
|    | • Pressurization of Lift lobby   | N/A          | -----    | ----- |
|    | • Communication in lift car  | N/A          | -----    | ----- |
|    | • Firemen's grounding switch   | N/A          | -----    | ----- |
|    | • Lift Signage   | N/A          | -----    | ----- |
| 17 | Standby power supply   | Required     | Provided | MR    |
| 18 | Refuge Area.   |              |          |       |
|    | • Total area   | N/A          | -----    | ----- |
|    | • Location   | N/A          | -----    | ----- |
| 19 | Fire Control Room  |              |          |       |
|    | • Detector system panel  | N/A          | -----    | ----- |
|    | • Flow switch panel  | N/A          | -----    | ----- |
|    | • PA system panel  | N/A          | -----    | ----- |
|    | • Batter backup  | N/A          | -----    | ----- |
|    | • Building Floor Plans   | N/A          | -----    | ----- |
| 20 | Special Fire Protection systems for protection of special Risks, if any: | N/A          | -----    | ----- |
|    |  |              |          |       |

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Signature of the Inspecting Officer

Name

Designation

Signature of the Inspecting Office

Name

Designation

*[Handwritten Signature]*

VIRENDRA SINGH

DO