

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/Schod/2012/4843

Dated: 3/12/2012

Fire Safety Certificate

Certified that MCD Primary Model School (Boys) Jwala Puri
Camp No-5 (I & II) N. Delhi located at Jwala Puri New Delhi

..... was issued fire safety certificate for G.F
only vide this department letter no. F-6/DFS/MS/2009/2844 Dated: 18/9/2009.

The premise was found to be comprised of Ground + one Storey Building
during inspection carried out on 11-8-2012 by the officer from this department and have
complied with the fire prevention & Fire safety requirement in accordance
with Circular no F-16/Estt/CC/Fire Safety/2011/3298-3398 dt. 1-3-2011
issued by the Director of Education

The building premises is fit for occupancy of Educational Bldg for a period of Three years.
Subject to condition mentioned over leaf.

c.c to

- 1) The Principal
M.C. Pr. Model School
Jwala Puri Camp No 5 (I & II)
New Delhi I.D - 104570 & 104671

Yours Faithfully,


Chief Fire Officer
Delhi Fire Service

- 2) The Director of Edu.
North MCD
Civic Centre
Minto Rd. N. Delhi.

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
5. Basement shall be used as per NOC.
6. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: MCP Model School (G & B)
Jwalapuri Camp 5-E/II, ND-82
2. Type of Occupancy: Edu
3. Type of Case: Old/new
4. Details of previous NOC: Letter No FE/DFE/MS/2009/2844 dtd 18/9/09 (9Faly)
5. Fire Safety directives Letter No.: Dir of Edu
6. Date of inspection: 11/9/12 PA - 4080 sqm
7. Name of the Inspecting Officer: ADO (MN) CA -
8. Name and designation of Officer: Smt Shanti Behal Nos - 580
from the building side NOT - 1+13
NOR - 22
9. Year of Construction: -
10. Applicant's letter No.: 16/8/12

to	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
	Access of building			
	• Road width	6m	6m	m/R
	• Gate width	5m	3.70m	<u>NMR</u>
	• Width of internal road	-	-	-
	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	Two	Two	m/R
	• Basements	-	-	-
	b. Width of staircases			
	• Upper floors	Two	125 x 135 cm ✓	m/R
	• Basements			
	c. Protection of exits			
	• Fire check door	N/A		
	• Pressurization			
	d. No of continuous staircase to terrace			

	e. Width Of Corridor			
	f. Door Size	1 m	1 m	n/r
3.	Compartmentation			
	• Fire check door			
	• Sealing of electrical shafts		N/A	
	• Fire Rating of shaft door			
	• Water Curtain			
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	30 a/c per hour		
	• Upper floors	12 a/c per hour		N/A
5.	Fire Extinguishers			
	• Total numbers	one @ 300 m ²	3 ABC	MR
	• Types	3	yes	yes
	• IS marking	ISI marked	yes	yes
6.	First - Aid Hose Reels			
	• Total numbers on each floor			
	• Length of hose reel hose		N/A	
	• Nozzle diameter			
7.	Automatic fire detection and alarming system			
	• Type of detectors			
	• Location of Main Panel			
	• Location of Repeater Panel		N/A	
	• Alternate source of power			
	• Hooters' Location			
8.	MOEFA			
9.	Public Address System			
10.	Automatic Sprinkler System			
	• Basements		N/A	
	• Upper Floor			
	• Sprinkler above false ceiling			
11.	Internal Hydrants			
	• Size of riser/down-comer			

	<ul style="list-style-type: none"> • Number of hydrants per floor • Hose Box 			
12.	Yard Hydrants	N/A		
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 			
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	N/A		
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw of connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N/A		
15	Exit Signage			
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car 	N/A		

	<ul style="list-style-type: none"> ➤ Fireman's Grounding Switch ➤ Lift Signage 			
17.	Standby power supply			
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 			
19.	Fire control room			
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Batter backup ➤ Building Floor Plans 			
20.	Special Fire Protection Systems for Protection of special Risks, if any;			

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers 1, 5

Signature of the Inspecting Officer

Name :

Designation

DD (M)

26/19

Signature of the Inspecting Officer

Name

Designation

SS Tuli
ADD (M)

There is no requirement in gate width in Director of Fire Services circular dt 1-3-11 amended DPA