

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI - 110001

No: F 6/DFS/MS/2012/ *School/4742*

Dated: *21/12/12*

FIRE SAFETY CERTIFICATE

Certified that the *Mari Gold Public School, Khastra No: 559,*
Vill - Katewara, Delhi - 110039
..... comprised of *Ground + one upper floor* occupied
by *Mari Gold Educational & Welfare Society* was issued NOC vide this office letter
No. *F-6/DFS/MS/09/2479*. Dated: *11-8-2009*. The premises was re-inspected by the
officer concerned of this department on *14-12-2012* and observed that all the fire
prevention and fire safety arrangements as provided in the premises found in good working
condition. The premises have therefore, deemed complied with the requirement *Circular,*
Dir. of Educn. 17-1-2005 and the building/premises is fit for occupancy Class
Educational with effect from *21/12/12* for a period of
three years in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under
Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service
Rules, 2010.

Issued on *21/12/12* at New Delhi.

[Signature]
19/12
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. *The Manager*
Mari Gold Public School,
Katewara, Delhi-39

2.
.....
.....

4/N

Renewal

INSPECTION REPORT

1. Name & address of the building : Marigold Public School, Kh. No. 559, Katowara, Delhi
2. Type of Occupancy : Educational
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. F-6/DFS/MS/09/2479 Dated: 11-8-2009
5. Fire Safety directives letter No : Circular, Dir. of Edun. No. 262-362 dt. 17-1-2005
6. Date of inspection : 14-12-2012
7. Name of the Inspecting Officers : ADO - SHYAM LAL
8. Name and designation of officers from the building side : Sh. Bhal Singh (Manager)
9. Year of Construction : 2005, (Ground + 1 with adjoining residence for -
10. Applicant's letter No. : MPS/DFS/203/2012 dt. 30th 2012 - Principal Grr + 2 upper fls

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1.	Access to building		<u>(old case)</u>	
	• Road width	<u>Accessible</u>	<u>6</u>	<u>M/R</u>
	• Gate width	<u>-h-</u>	<u>4.96 m</u>	<u>M/R</u>
	• Width of internal road	<u>-h-</u>	<u>6 m</u>	<u>M/R</u>
	Number, Width, Type & Arrangement of Exits			
a.	Number of staircases	<u>2</u>	<u>2</u>	<u>M/R</u>
	• Upper Floors	<u>2</u>	<u>2</u>	<u>M/R</u>
	• Basements	<u>Nil</u>	<u>Nil</u>	<u>Nil</u>
b.	Width of staircases			
	• Upper Floors	<u>1.5 m</u>	<u>1.18 m & 1.8 m (old case)</u>	<u>M/R</u>
	• Basements	<u>Nil</u>	<u>Nil</u>	<u>Nil</u>
c.	Protection of exits			
	• Fire check door	<u>N/R</u>	<u>N/P</u>	<u>N/A</u>
	• Pressurization	<u>N/R</u>	<u>N/P</u>	<u>N/A</u>
e.	No. of continuous staircases to terrace	<u>One</u>	<u>Provided</u>	<u>M/R</u>
g.	Width of Corridor	<u>R</u>	<u>2.70 m</u>	<u>M/R</u>
h.	Door Size	<u>1 m</u>	<u>1.10 m</u>	<u>M/R</u>

(one door), less than 15 student incl.

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 		N/R	
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	N/R	
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • ISI marking 	10 ABC/CO2 (2.5kg) ISI marked	Provided- ABC yes	m/r m/r m/r
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	One 30 m 5 mm	Provided- Provided Provided	m/r m/r m/r
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 		N/R	
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 		N/R	

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 		NIR	
			NIR	
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 		NIR	
			NIR	
			NIR	
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 		NIR	
			NIR	
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 		NIR	
		220 L/s/min	provided	NIR
		30 m	provided	NIR
			NIR	
			NIR	
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 		NIR	
			NIR	

71N

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	2500 Ltrs.	NIR NIR 3000 Ltrs.	NIR NIR NIR
15	Exit Signage.		NIR	
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 		N/A -h- -h- -h- -h-	
17	Standby power supply		NIR	
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 		N/A -h-	
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 		NIR -h- -h- -h- -h-	
20	Special Fire Protection Systems for Protection of special Risks, if any:	Nic	Nic	Nic

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

D.O. (NID) leave
DCFO (A)

19/12
18/12
17/12/2015

Shyam Lal
ADD (RN)
15/12/2015
(SHYAM LA2)

F.T. M-scell