

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001


NO.F6/DFS/MS/school/2012/4760

Dated: 26/12/2012

**FIRE SAFETY CERTIFICATE**

Certified that **M.C.D. Primary Girls School located at Rouse Avenue-1, New Delhi comprised of ground floor only**, having total 10 rooms and one hall owned/occupied by MCD was inspected by the officer concerned of this department on 10.12.2012 in presence of Mr. Natiq Abbas (Principal) and found that the MCD have complied with the fire prevention and fire safety requirements in accordance with the Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01-03-2011 issued by the Directorate of Education dated 01-03-2011 and that the school building is fit for occupancy class "Educational" with effect from the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed overleaf.

Issued on ~~26/12/2012~~ at New Delhi by.

  
Chief Fire Officer  
Delhi fire service

Copy to: -

1. The Principal, M.C.D. Primary girls school, Rouse Avenue-1, New Delhi
2. The Director of Education, MCD (North), Kashmere Gate, Nigam Bhawan, Delhi

**Conditions for the validity of fire safety certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

## INSPECTION REPORT

1. Name & address of the building : MCD primary <sup>Girls</sup> school, Rouse Avenue 1, New Delhi.
2. Type of Occupancy : Educational.
3. Type of Case : New Case / ~~renewal~~
4. Details of previous NOC : Letter No.     -     Dated:
5. Fire Safety directives letter No : F16/Estate/CC/Fire Safety/2011/3298-3398
6. Date of inspection : 10.12.2012 date 2011/3/2012
7. Name of the Inspecting Officers : M.K. Chattopadhyay, ADO (HO)
8. Name and designation of officers from the building side : Natiq Abbas, principal
9. Year of Construction : 1980
10. Applicant's letter No. : nil dated 15/9/2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06 mt.	18 mt (approx)	MR
	• Gate width	-	4 mt	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	NA	NA	NA
	• Upper Floors	Ground floor only	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases	-	-	-
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	g. Width of Corridor	NA	0.75	NA
	h. Door Size	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
3	<b>Compartmentation.</b>	-	-	-



	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	<p>MA</p> <p>MA</p> <p>MA</p> <p>MA</p> <p>MA</p>	<p>MA</p> <p>MA</p> <p>MA</p> <p>MA</p> <p>MA</p>	<p>MA</p> <p>MA</p> <p>MA</p> <p>MA</p> <p>MA</p>
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	<p>30 a/c per hour</p> <p>12 a/c per hour</p>	<p>MA</p> <p>MA</p>	<p>MA</p> <p>MA</p>
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	<p>03 nos.</p> <p>ABC type</p> <p>ISI marked</p>	<p>provided</p> <p>provided</p> <p>provided</p>	<p>MR</p> <p>MR</p> <p>MR</p>
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	<p>—</p> <p>30 m</p> <p>5 mm</p>	<p>MA</p> <p>MA</p> <p>MA</p>	<p>MA</p> <p>MA</p> <p>MA</p>
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>	<p>MA</p> <p>MA</p> <p>MA</p> <p>MA</p> <p>MA</p>	<p>MA</p> <p>MA</p> <p>MA</p> <p>MA</p> <p>MA</p>	<p>MA</p> <p>MA</p> <p>MA</p> <p>MA</p> <p>MA</p>
8	<b>MOEFA</b>			
9	<b>Public Address System.</b>			
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>	<p>MA</p> <p>MA</p> <p>MA</p>	<p>MA</p> <p>MA</p> <p>MA</p>	<p>MA</p> <p>MA</p> <p>MA</p>
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> </ul>	<p>MA</p>	<p>MA</p>	<p>MA</p>



	<ul style="list-style-type: none"> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>	NA	NA	NA
		NA	NA	NA
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>	NA	NA	NA
		NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>• Ground Level <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> </ul> </li> <li>• Terrace level <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> </ul>	NA	NA	NA
		NA	NA	NA/NA

*[Handwritten signature]*

	<ul style="list-style-type: none"> <li>Communication In lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	Y/A	Y/A	Y/A
17	<b>Standby power supply</b>	Y/A	Y/A	Y/A
18	<b>Refuge Area.</b>	Y/A	Y/A	Y/A
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>Detector System Panel</li> <li>Flow Switch Panel</li> <li>PA System Panel</li> <li>Batter backup</li> <li>Building Floor Plans</li> </ul>	N/A	Y/A	Y/A
		Y/A	Y/A	Y/A
		Y/A	Y/A	Y/A
		Y/A	Y/A	Y/A
		Y/A	Y/A	Y/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	One ABC type fire extinguisher provided in electrical panel.	NR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renew/grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Note:- The school building is comprised of ground floor only having total 10 rooms & one hall. The students are less than 45 in each class as stated by the Principal's letter dated 10-12-2012.

Forwarded pl.

DO (CD)

24-12-12

Signature of the Inspecting Officer  
Name M.K.CHATTOPADHYAY  
Designation ADO (HO)