

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001.**

No. F6/DFS/MS/ EH/2012/4767

Dated 27/12/12

FIRE SAFETY CERTIFICATE

Certified that M/s **McDonald's Family Restaurant, Showroom No. 17-24, Grindlays Cinema, New Friends Colony, New Delhi** at Ground Floor Owned/Occupied by McDonald's family restaurant was granted NOC by this department vide letter No.F.6/MS/DFS/EH/2008/1569 dated 11.06.2008. The premises was re-inspected by the officers concerned of Delhi Fire Service on 09/05/2012 in the presence of Mr./Miss/Mrs. DN Thakur, Manager of the restaurant and that the premises is fit for occupancy class- "Assembly" with effect from 27/12/12 for a period of **Three years**, subject to conditions as mentioned below.

Issued on 27/12/12 at New Delhi by



Chief Fire Officer
Delhi Fire Service

Copy to:

1. The Manager, Mc Donald's family restaurant,
Showroom No. 17-24, Grindlays Cinema, New Friends Colony, New Delhi-110057

Conditions for the validity of Fire Safety Certificate

- a) All the Fire Safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b) Building Sanctioning Authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c) The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d) The Basement shall be used strictly as per the provisions of Building Bye Laws.
- e) The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name and address of the building : Mc DONALD'S FAMILY RESTAURANT at
 : SHOWROOM NO: 17-24, GRINDLAYS CINEMA,
 : NEW FRIENDS COLONY, NEW DELHI- 57
2. Type of Occupancy : "EATING HOME"
3. Type of Case : RENEWAL
4. Details of previous NOC : FB/MS/DFS/EH/2008/1569 Dt. 11.06.2008
5. Fire Safety Directives letter No : NIL
6. Date of Inspection : 09-05-2012
7. Name of the Inspecting Officer : Rajan Kladehra, ADO/MRD.
8. Name and designation of the Officers from the building side : Mr D.N Thakur, Manager
9. Year of Construction : _____
10. Applicant's letter No. : NIL dt 04.04.2012

S. No.	Minimum Standards on Fire Prevention and Fire Safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	20 Mts	20 Mts	M/R
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits	NA (Ground floor only)		
	• Number of Staircase	NA		
	➤ Upper floors			
	➤ Basement			
	• Width of Staircase	NA		
	➤ Upper floors			
	➤ Basement			
	• Protection of Exits	NA		
	➤ Upper floors			
	➤ Basement			
	• No of Continuous Staircases to terrace	NA	NA	NA
	• Width of Corridor	NA	NA	NA
	• Door Size	NA	NA	NA

3	Compartmentation	NA		
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 			
4	Smoke Management System	NA		
	<ul style="list-style-type: none"> • Basements • Upper Floors 	30 a/c Per hour		
		12 a/c Per hour		
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total Number • Types • IS marking 	8 /300 m 2	8 NOS	MIR
			CO ₂ 2ABC	MIR
		ISI mark	YES	MIR
6	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total Number on each floor • Length of hose reel hose • Nozzle diameter 	1 /Per Floor	1	MIR
		30 m	30m	MIR
		5mm	5mm	MIR
7	Automatic Fire Detection and Alarming System			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooter's Location 	Required	Provided	N/A
		4-P	4P	MIR
		NA	NA	NA
		NA	NA	NA
8	MOEFA	Required	Provided	MIR
9	Public Address System	NA	NA	NA
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	NA	NA	NA
		Required	Provided	NA
		NA	NA	NA
11	Internal Hydrant			
	<ul style="list-style-type: none"> • Size of riser/down comer • Number of hydrants per floor • Hose Box 	100 mm	100 mm	MIR
		2	2	MIR
		2	2	MIR
12	Yard Hydrant	NA		
	<ul style="list-style-type: none"> • Total Number of hydrants • Hose Box 			


13 Pumping Arrangements			
Ground Level			
➤ Number of main pump	2 Nos	2 Nos	MIR
➤ Discharge of main pump	2850 cpm	2850 cpm	MIR
➤ Head of main pump	70m	70m	MIR
➤ Jockey pump out put	950 cpm	950 cpm	MIR
➤ Jockey pump Head	70m	70m	MIR
➤ Standby pump out put	2850 cpm	2850 cpm	MIR
➤ Standby Pump Head	70m	70m	MIR
➤ Auto Starting/Manual stopping	Auto	Auto	MIR
➤ Pump House Access	Required	Provided	MIR
Terrace level			
➤ Discharge of pump	NA		
➤ Head of the pump	/		
➤ Power Supply	/		
➤ Auto starting /Manual stopping	/		
14 Captive Water Storage for Fire Fighting			
• Underground tank capacity	2,000,000 cb	2,000,000 cb	MIR
➤ Draw-off connection	Required	Provided	MIR
➤ Fire service inlet	Required	Provided	MIR
➤ Access to tank	Required	Provided	MIR
• Overhead tank capacity	250000 cb	250000 cb	MIR
15 Exit Signage	Required	Provided	NA
16 Provision of Lifts			
• Pressurization of Lift Shaft	/		
• Pressurization of Lift lobby	/		
• Communication in lift Car	/		
• Fireman's Grounding Switch	/		
• Lift Signage	/		
17 Standby Power Supply			
18 Refuge Area			
• Total Area	NA		
• Location	/		
19 Fire Control Room			
• Detector System Panel	/		
• Flow Switch Panel	/		
• PA System Panel	/		
• Battery back up	/		
• Building Floor Plans	/		

20	Special Fire Protection System for Protection of special risk, if any	4 Nos ABC Fire ext	4 Nos ABC Fire ext	MIR
----	---	--------------------	--------------------	-----

The Fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules , It is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / ~~issue shortcomings as noted at~~ serial Number.....

The Restaurant



Signature of Inspecting Officer
Name : RAJAN WADEHRA
Designation: ASST. DIV. OFFICER

DO (South)

