

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI - 110001


No: F 6/DFS/MS/2011/ 4827

Dated:- 31/12/2012

FIRE SAFETY CERTIFICATE

Certified that the Delhi School of Professional Studies & Research, Institutional Area Sec-25, Rohini Delhi 110085 comprised of Basement, Ground + three upper floors owned/occupied by Delhi School of Professional Studies & Research complied with the fire prevention and fire safety requirement in accordance with rule 33 of the Delhi Fire Service Rule 2010 and verified by the officer concerned of Fire Service on 12/12/12 in the presence of Sh. R. S. Singh (Sr. Registrar) and that the building/premises is fit for occupancy Educational building with effect from 31/12/12 for a period of 03 years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 31/12/12 at New Delhi.


31/12
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. Dr. P. S. Popli (Director)
Delhi School of Professional Studies
& Research, Institutional Area
Sec-25, Rohini Delhi 110085.

2.
.....
.....

Note:-Guidelines overleaf may also be taken care of.

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non – functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
5. Basement shall be used as per BBL.
6. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.

Leomin

INSPECTION REPORT

1. Name & address of the building : Delhi School of Professional Studies & Research
2. Type of Occupancy : 9, Institutional area, see-25, Rohini Delhi.
3. Type of Case : Education Bldgs. (B+G+ Three upper floors)
New Case/ Renewal
4. Details of previous NOC : Letter No. Nil Dated: 14.6.03
5. Fire Safety directives letter No : FG/DFS/MS/BR/2003/520 dt 10.3.03
6. Date of inspection : 12.12.2012
7. Name of the Inspecting Officers : DCFO Vipin Kantal
8. Name and designation of officers from the building side : DY Registrar Dr. R-S Singh
9. Year of Construction : 2004
10. Applicant's letter No. : DSPSR/Admin/2012/11/7054 dt 10.12.12

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	N/A	—	—
	• Gate width	5 mt	5 mt	M/R (Complied)
	• Width of internal road	N/A	—	—
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	Two	Two	M/R
	• Basements	- do -	- do -	- do -
	b. Width of staircases			
	• Upper Floors	1.5 mt & one fire escape	1.5 mt 1.4 mt	M/R
	• Basements			
	c. Protection of exits			
	• Fire check door	R	P	M/R
	• Pressurization	N/A	—	—
	e. No. of continuous staircases to terrace			
	g. Width of Corridor	N/A	—	—
	h. Door Size	1.5 mt	P	M/R

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	R N.A. N.A. N.A. N.A.	P — /	MIR — —
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	P N.A.	MIR (complied) —
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	26 No. 13 w/ CO2 13 CO2 ISI marked	P water CO2 CO2 type.	MIR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	1 30 m 5 mm	P P P	MIR MIR MIR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 		N.A. /	
8	MOEFA			
		R	P	MIR
9	Public Address System.			
		N.A.	P	—
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	R	P	MIR

	<ul style="list-style-type: none"> Upper Floor Sprinkler above false ceiling 		N.A	
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	1 (100mm)	P	MIR (Completed)
		one	P	MIR
		one	P	MIR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N.R.	P	-
		-	-	-
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 			
		1620 LPM	P	MIR
		-	-	-
		4	P	MIR (Completed)
		450 LPM	P	MIR
		-	-	-
		1620 LPM	P	-
		-	-	-
		R	P	MIR
		R	P	MIR
		450 LPM	P	MIR
		-	-	-
		R	P	MIR
		R	P	MIR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection 	50,000lt	P	MIR
		R	P	MIR

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	R	P	MIR
		R	P	MIR
15	Exit Signage.	20,000h	P	MIR (completed)
16	Provision of Lifts.	R	P	MIR
	• Pressurization of Lift Shaft	N.A	-	-
	• Pressurization of Lift lobby	N.A	P	MIR
	• Communication In lift Car			
	• Fireman's Grounding Switch	N.A	-	-
	• Lift Signage	R	P	MIR
17	Standby power supply	R	P	MIR
18	Refuge Area.	R	P	MIR
	➤ Total Area		N.A /	
	➤ Location		/	
19	Fire Control Room			
	• Detector System Panel			
	• Flow Switch Panel			
	• PA System Panel		N.A	
	• Batter backup			
	• Building Floor Plans			
20	Special Fire Protection Systems for Protection of special Risks, if any:		no such sp risk at present.	

✓ The fire protection systems provided in the building were test checked and found functional at the time of inspection.

✓ Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

5

Signature of the Inspecting Officer

Kental
Signature of the Inspecting Officer

Name

Name

VIPIN KENTAL

Designation

Designation

DCFO.

DRA M