

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[SEE SUB-RULE (1) OF RULE 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001


No. F6/DFS/MS/school/2012/4743 Dated: 21/12/2012

FIRE SAFETY CERTIFICATE

Certified that the **Queen Mary's School Northend**, located at Model Town-III, Delhi-110009, is comprised of ground plus three upper floors only, was granted NOC by this department vide letter No. F6/DFS/MS/06/2888 dated 28/9/2006 have complied with the fire prevention and fire safety requirements in accordance with the *fire safety directives letter no F6/DFS/MS/DP/2004/333 dt. 11-2-2004* issued earlier by this dept. and verified by the officer concerned of Fire Service on 30-11-12 in the presence of Sh. Sandeep Masih and that the building / premises is fit for occupancy of **Group Class B (Educational)** with effect from 21/12/12 for a period of three years, subject to conditions mentioned over leaf.

Issued on 21/12/12 at New Delhi by

Yours Faithfully


19/12
Chief Fire Officer

Delhi Fire Service


Copy to:

1. Mrs. Anupma Singh (Principal)
Queen Mary's School Northend, located at Model Town-III, Delhi-110009
2. The Director of Education, Old Secretariat, Delhi

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

8/N Renewal

INSPECTION REPORT

1. Name & address of the building : Queen Marys School, Model Town, III, Delhi-
2. Type of Occupancy : Educational
3. Type of Case : New Case / Renewal ✓
4. Details of previous NOC : Letter No F-6/DFS/MS/06/2888 Dated: 28-9-2006.
5. Fire Safety directives letter No : F-6/DFS/MS/04/333 dated 11-2-2004.
6. Date of inspection : 30-11-2012
7. Name of the Inspecting Officers : ADO - SHYAM LAL
8. Name and designation of officers
from the building side : Sh. Andeep Masih (Admn. & Acout officer)
9. Year of Construction : 2003, (Gr. +3)
10. Applicant's letter No. : NIL dated 26-6-2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building	(Old case)		
	• Road width	12 m	12 m	M/R
	• Gate width	04.5m	6 m	M/R
	• Width of internal road	6 m	6 m	M/R
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	6	6	M/R
	• Upper Floors	4	4	M/R
	• Basements	2	2	M/R (old case)

b. Width of staircases <ul style="list-style-type: none"> • Upper Floors • Basements c. Protection of exits <ul style="list-style-type: none"> • Fire check door • Pressurization e. No. of continuous staircases to terrace g. Width of Corridor h. Door width -			
	1.5 m	3 No's = 1.5m 1 No. = 1.53m	M/R
	1.5 m	1.18m & 97cm	M/R (please)
	R	Provided	M/R
	M/R	N/P	N/A
	2	2	M/R
	R	7'	M/R
	1 m	1.14 m	M/R
3	Compartmentation.		
• Fire check door	N/R	N/P	N/A
• Sealing of electrical shafts	- do -	- do -	- do -
• Fire Rating of shaft door	- do -	- do -	- do -
• Water Curtain	- do -	- do -	- do -
• Fire Dampers	- do -	- do -	- do -

Smoke Management System.

• Basements	30 a/c per hour	NIR	N/A
• Upper floors	12 a/c per hour	NIR	N/A

5 Fire Extinguishers

• Total numbers	35	49	MIR
• Types	ABC/CO2 (2.5kg) ISI marked	ABC/CO2, W-CO2	MIR
• IS marking		ISI mark provided	MIR

6 First-Aid Hose Reels.

• Total numbers on each floor	Two	provided	MIR
• Length of hose reel hose	30 m	provided	MIR
• Nozzle diameter	5 mm	provided	MIR

7 Automatic fire detection and alarming system.

• Type of detectors	NIR	N/P	N/A
• Location of Main Panel	-h-	-h-	-h-
• Location of Repeater Panel	-h-	-h-	-h-
• Alternate source of power	-h-	-h-	-h-
• Hooters' Location	-h-	-h-	-h-

8 MOEFA

NIR	N/P	N/A
-----	-----	-----

9 Public Address System.

R	provided	MIR
---	----------	-----

10	Automatic Sprinkler System.			
	• Basement	R	provided	MIR
	• Upper Floor	N/R	N/P	N/A
	• Sprinkler above false ceiling	- -	- -	- -
11	Internal Hydrants			
	• Size of riser/down-comer	Two No's 100mm	provided	MIR
	• Number of hydrants per floor	Two	provided	MIR
	• Hose Box	Two	provided	MIR
12	Yard Hydrants.			
	• Total number of hydrants	N/R	N/P	^{N/A} MIR
	• Hose Box	N/R	N/P	^{N/A} MIR
13	Pumping Arrangements.			
	• Ground Level	N/R	N/P	N/A
	➤ Discharge of main Pump	- -	- -	- -
	➤ Head of Main pump	- -	- -	- -
	➤ Number of main pumps	- -	- -	- -
	➤ Jockey Pump out put	- -	- -	- -
	➤ Jockey pump head	- -	- -	- -
	➤ Standby Pump out put	- -	- -	- -
	➤ Standby Pump Head	- -	- -	- -

➤ Auto Starting/ Manual stopping	N/R	N/P	N/A
➤ Pump House Access	-n-	-du-	-ds-
Terrace level	-	-	-
➤ Discharge of pump	900 lbs/minute	Provided	M/R
➤ Head of the pump	110 m	Provided	M/R
➤ Power Supply	R	Provided	M/R
➤ Auto Starting of pump	R	Provided	M/R
14	Captive Water Storage for fire fighting.		
• Underground tank capacity	50000 lbs.	100000 lbs	M/R
➤ Draw-off connection	N/R	N/P	N/A
➤ Fire service inlet	-n-	-n-	-n-
➤ Access to tank	-n-	-n-	-n-
• Overhead Tank capacity	12000 lbs.	25000 lbs	M/R

15	Exit Signage.	R	provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	-/-	-/-	-/-
	• Communication In lift Car	-/-	-/-	-/-
	• Fireman's Grounding Switch	-/-	-/-	-/-
	• Lift Signage	-/-	-/-	-/-
17	Standby power supply	R	provided	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	-/-	-/-	-/-
19	Fire Control Room			
	• Detector System Panel	N/A	N/P	N/A
	• Flow Switch Panel	-/-	-/-	-/-
	• PA System Panel	-/-	-/-	-/-
	• Batter backup	-/-	-/-	-/-
	• Building Floor Plans	-/-	-/-	-/-
20	Special Fire Protection Systems for Protection of special Risks, if any:	Nil	Nil	Nil

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Name

Designation

Designation

Shyam Lal
30/11/12

SHYAM LAL

Asstt. Dirn. Officer