

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001


NO.F6/DFS/MS/EH/2012/ 07

Dated: 02/01/13

**FIRE SAFETY CERTIFICATE**

Certified that M/s **CIBO Restaurant** (a unit of Khalsa Tent House) located at ground floor of Janpath Hotel, New Delhi-110001 was granted NOC by this department vide letter No. F.6/DFS/MS/EH/09/2329 dated 28-07-2009. The premises was re-inspected by the officer concerned of this department on 28-12-2012 in the presence of Mr. Shreesant, Maintenance manager of the restaurant and found that the said restaurant have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and that the premises / building is fit for occupancy class **Assembly (Restaurant)** with effect from ~~02/01/13~~ for a period of **3(three)** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi fire service Rules,2010.

Issued on ~~02/01/13~~ at New Delhi by.

  
**Chief Fire Officer  
Delhi fire service**

Copy to: -

1. The Medical Officer of Health, NDMC, Health Department, Palika Kendra, New Delhi
2. The Authorized Signatory, M/s CIBO Restaurant (a unit of Khalsa Tent House), Janpath Hotel, New Delhi-110001

**Conditions for the validity of fire safety certificate**

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

INSPECTION REPORT

1. Name & address of the building : CIBO restaurant (a unit of Khalsa tent house), Hotel Janpath,  
New Delhi
2. Type of Occupancy : Eating House
3. Type of Case : Renewal
4. Details of previous NOC : Letter NoF.6/DFS/MS/EH/09/ 2329 Dated: 28-07-2009
5. Fire Safety directives letter No : N/A
6. Date of inspection : 28-12-2012
7. Name of the Inspecting Officers : M.K.Chattopadhyay, ADO(CC)
8. Name and designation of officers  
from the building side : Mr. Shreesant, Maintenance Manager
9. Year of Construction : Prior to 1960 (Janpath hotel)
10. Applicant's letter No. : KTH/DFS/2012 dated 11 12-2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> </ul>	09 mts	More than 20 mts	MR
			Directly accessible from setback area of Janpath hotel	MR
	<ul style="list-style-type: none"> <li>• Width of internal road</li> </ul>	N/A	N/A	-----
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	Ground floor only	-----	-----
		N/A	N/A	-----
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	Ground floor only	-----	-----
		N/A	N/A	-----
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	N/A	N/A	-----
		N/A	N/A	-----
	e. No. of continuous staircases to terrace	N/A	N/A	-----



	g. Width of Corridor	N/A	N/A	-----
	h. Door Size	N/A	N/A	-----
3	<b>Compartmentation.</b>	N/A	N/A	-----
	• Fire check door	N/A	N/A	-----
	• Sealing of electrical shafts	N/A	N/A	-----
	• Fire Rating of shaft door	N/A	N/A	-----
	• Water Curtain	N/A	N/A	-----
	• Fire Dampers	N/A	N/A	-----
4	<b>Smoke Management System.</b>			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	Smoke venting provided in kitchen	MR
5	<b>Fire Extinguishers</b>			
	• Total numbers 12	ISI marked	Provided	MR
	• Types Water CO <sub>2</sub> , CO <sub>2</sub> , ABC		Provided	MR
	• IS marking		Provided	MR
6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	01(ground floor)	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	N/R	Smoke type (Janpath hotel)	MR
	• Location of Main Panel	N/R	Ground floor (Janpath hotel)	MR
	• Location of Repeater Panel	N/R	Ground floor	MR
	• Alternate source of power	N/R	UPS	MR
	• Hooters' Location	N/R	reception	-----
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	Not required	N/A	-----
10	<b>Automatic Sprinkler System.</b>			
	• Basement	N/A	N/A	-----
	• Upper Floor	Not required	Provided	MR

*[Handwritten signature]*

	• Sprinkler above false ceiling	N/A	N/A	-----
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	N/A	N/A	-----
	• Number of hydrants per floor	N/A	N/A	-----
	• Hose Box	N/A	N/A	-----
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	Not required	Provided	MR
	• Hose Box	Not required	Provided	MR
13	<b>Pumping Arrangements.</b>			
	• Ground Level			
	➤ Discharge of main Pump	Not required	2850 LPM (Janpath hotel)	MR
	➤ Head of Main pump	Not required	70 mts (Janpath hotel)	MR
	➤ Number of main pumps	Not required	One	MR
	➤ Jockey Pump out put	-----	380 LPM(Janpath hotel)	MR
	➤ Jockey pump head	-----	55 mts(Janpath hotel)	MR
	➤ Standby Pump out put	-----	-----	-----
	➤ Standby Pump Head	-----	-----	-----
	➤ Auto Starting/ Manual stopping	Yes	Yes	MR
	➤ Pump House Access	Yes	Yes	MR
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	-----
	➤ Head of the pump	N/A	N/A	-----
	➤ Power Supply	N/A	N/A	-----
	➤ Auto Starting of pump	N/A	N/A	-----
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	-----	2,00,000 ,Its	MR
	➤ Draw-off connection	Yes	Yes (Janpath hotel)	MR
	➤ Fire service inlet	Yes	Yes (Janpath hotel)	MR
	➤ Access to tank	Yes	Yes (Janpath hotel)	MR
	• Overhead Tank capacity	-----	10,000 Its (Janpath hotel)	MR

15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N/A	N/A	-----
	• Pressurization of Lift lobby	N/A	N/A	-----
	• Communication In lift Car	N/A	N/A	-----
	• Fireman's Grounding Switch	N/A	N/A	-----
	• Lift Signage	N/A	N/A	-----
17	<b>Standby power supply</b>	Required	1500, 600 KVA	MR
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	-----
	➤ Location	N/A	N/A	-----
19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	-----
	• Flow Switch Panel	N/A	N/A	-----
	• PA System Panel	N/A	N/A	-----
	• Batter backup	N/A	N/A	-----
	• Building Floor Plans	N/A	N/A	-----
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	ABC type fire extinguisher provided near elect. Small panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renew Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer  
Name M.K.Chattopadhyay  
Designation :- ADO(CC)

DO (CD)  
C.F.P.  
ADO (CC)  
21-01-13  
2/1/13