

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE,
NEW DELHI-110001**

No. F6/MS/DFS/GH/2012/35

Dated: 03/01/13

FIRE SAFETY CERTIFICATE

Certified that the Hare Krishna, Guest House, 1572-73, Main Bazar, Pahar Ganj, New Delhi-110055 comprised of ground floor (reception + lobby + 01 guest room), 1st floor to 3rd floor (06 guest rooms at each floor), 4th floor (05 guest rooms), total 24 guest rooms, was granted NOC by this department vide letter No. F6/DFS/MS/GH/2009/2110 dated 15-07-09. The premises was re-inspected by the officer concerned of this department on 22-12-2012 in the presence of Sh. Harpreet Singh Gujral (owner) and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of 24 guest rooms with effect from 03/01/2013 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued 03/01/13 at New Delhi by.



CHIEF FIRE OFFICER
DELHI FIRE SERVICE

9c Real 21/13

Copy to :-

1. The Addl. Commissioner of Police (Lic.), First Floor, P.S. Defence Colony, New Delhi-110049:wrt..57502-03/Addl.C.P./Lic.(H) New Delhi dated 01-10-12
2. M/s Hare Krishna, Guest House, 1572-73, Main Bazar, Pahar Ganj, New Delhi-110055.
3. Dy. Commissioner, MCD, Sadar Pahar Ganj Zone, Idgah Road, Delhi with a request to get height of the building measured and send intimation to Delhi Fire Service.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

INSPECTION REPORT

1. Name & address of the building : *Ware Krishna guest house, 1572-73, Main Bazar, Pahar Ganj, New Delhi - 110055*

2. Type of Occupancy : *Lodging house.*

3. Type of Case : *Nil/Case/Renewal ✓*

4. Details of previous NOC : *Letter No. F6/D.F.S./M.S/G.H/2009/ Dated 15-07-09*

5. Fire Safety directives letter No : *- N.A. -*

6. Date of inspection : *22-12-12*

7. Name of the Inspecting Officers : *D.Pal Singh Yadav.*

8. Name and designation of officers from the building side : *Shri Harpreet Singh Gul-jal (owner)*

9. Year of Construction : *1991 starting year.*

10. Applicant's letter No. : *NIL dated 04-10-12*

No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ <u>P.B.I.</u> Requirement	Provided at site	Remarks
	Access to building			MURMIF old case P.S. Area
	• Road width	<i>- N.A. -</i>	<i>40 Feet approx.</i>	M.R
	• Gate width	<i>- N.A. -</i>		
	• Width of internal road	<i>- N.A. -</i>		
	Number, Width, Type & Arrangement of Exits			
a.	Number of staircases			
	• Upper Floors	<i>ONE</i>	<i>TWO</i>	<i>M.R</i>
	• Basements	<i>- N.A. -</i>		
b.	Width of staircases			
	• Upper Floors	<i>0.80 mtr</i>	<i>(1) 74cms to 83cms</i>	<i>M.R</i>
	• Basements	<i>- N.A. -</i>	<i>(2) 110cms to 120cms</i>	
c.	Protection of exits			
	• Fire check door	<i>- N.A. -</i>		
	• Pressurization	<i>- N.A. -</i>		
e.	No. of continuous staircases to terrace	<i>01</i>	<i>01</i>	<i>M.R</i>
g.	Width of Corridor	<i>- N.A. -</i>		
h.	Door Size	<i>- N.A. -</i>		

contd:-

Hare Krishna guest house,
1572-73, main Bazar, Pahar Ganj,
New Delhi - 110055

MM

old case

PSS Area

3	Compartmentation.			
	• Fire check door	- N.A -		
	• Sealing of electrical shafts	- N.A -		
	• Fire Rating of shaft door	- N.A -		
	• Water Curtain	- N.A -		
	• Fire Dampers	- N.A -		
4	Smoke Management System.			
	• Basements	30 a/c per hour	- N.A -	- N.A -
	• Upper floors	12 a/c per hour	natural ventilation	M.R
5	Fire Extinguishers			
	• Total numbers	10 Nos	10 Nos	M.R
	• Types	-	CO ₂ type & w. CO ₂ type	M.R
	• IS marking	ISI marked	provided.	M.R
6	First-Aid Hose Reels.			
	• Total numbers on each floor	one	one	M.R
	• Length of hose reel hose	30 m	provided.	M.R
	• Nozzle diameter	5 mm	provided.	M.R
7	Automatic fire detection and alarming system.			
	• Type of detectors	- N.A -		
	• Location of Main Panel	- N.A -		
	• Location of Repeater Panel	- N.A -		
	• Alternate source of power	- N.A -		
	• Hooters' Location	- N.A -		
8	MOEFA	yes	provided	M.R
9	Public Address System.	yes	provided.	M.R
10	Automatic Sprinkler System.			
	• Basement	- N.A -		

contd:-

Mare Krishna guest house,
1572-73, Main Bazar Pahar Ganj,
New Delhi - 110055

old case
P.S. No. 1200

	<ul style="list-style-type: none"> Upper Floor Sprinkler above false ceiling 	- N.A -		
		- N.A -		
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	yes	Provided	M.R
		one	Provided	M.R
		one	Provided	M.R
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	- N.A -		
		- N.A -		
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terra e level Discharge of pump Head of the pump Power Supply Auto Starting of pump 	- N.A -		
		- N.A -		
		- N.A -		
		- N.A -		
		- N.A -		
		- N.A -		
		- N.A -		
		- N.A -		
		- N.A -		
		225 LPM	225 LPM	M.R
		30 mtrs	30 mtrs	M.R
		Electricity	Electricity	M.R
		-	switch provided at ground floor	M.R
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection 	- N.A -		
		- N.A -		

contd:-

7/11

Hare Krishna guest house,
1572-73, main Bazar,
Pahar Ganj, New Delhi-110055

old case
P.S. Area

	• Fire service inlet	- N.A -		
	➤ Access to tank	- N.A -		
	• Overhead Tank capacity	5000 litres	5000 litres	M.R
15	Exit Signage.	yes	Provided	M.R
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	- N.A -		
	• Pressurization of Lift lobby	- N.A -		
	• Communication In lift Car	- N.A -		
	• Fireman's Grounding Switch	- N.A -		
	• Lift Signage	- N.A -		
17	Standby power supply	yes	Provided.	M.R
18	Refuge Area.			
	➤ Total Area	- N.A -		
	➤ Location	- N.A -		
19	Fire Control Room			
	• Detector System Panel	- N.A -		
	• Flow Switch Panel	- N.A -		
	• PA System Panel	- N.A -		
	• Batter backup	- N.A -		
	• Building Floor Plans	- N.A -		
20	Special Fire Protection Systems for Protection of special Risks, if any:	- N.A -		

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers~~.....

contd: -

Hase Krishna guest house,
1572-73, main Bazar,
Pahar Ganj, New Delhi-110055

Signature of the Inspecting Officer

Name

Designation

[Signature]
22-12-12

Signature of the Inspecting Officer

Name DHARM VIR SINGH YADAV

Designation D.O (C.D)