

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUATERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

NO.F6/DFS/MS/school/2012/107

Dated: 7/1/2013

FIRE SAFETY CERTIFICATE

Certified that **Sarvodaya Kanya Vidyalaya located at Bulbuli Khana, Asaf Ali Road, New Delhi-2** comprised of ground floor only, having total 60 rooms owned/occupied by MCD was inspected by the officer concerned of this department on 24.12.2012 in presence of Mrs. Surekha Murgai (Principal) and found that the MCD have complied with the fire prevention and fire safety requirements in accordance with the Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01-03-2011 issued by the Directorate of Education dated 01-03-2011 and that the school building is fit for occupancy class "Educational" with effect from the date of issue of this certificate for a period of three years, subject to compliance of the following conditions .

Issued on 7/1/2013 at New Delhi by.


Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Principal, Sarvodaya Kanya Vidyalaya, Bulbuli Khana, Asaf Ali Road, New Delhi-2
2. The Director of Education, MCD (North), Kashmere Gate, Nigam Bhawan, Delhi

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Govt. Sarvodaya Kanya Vidyalaya, Bulbuli Khone
 2. Type of Occupancy : Educational Asyaf Ali Rd.
 3. Type of Case : New Case/ Renewal
 4. Details of previous NOC : Letter No. — Dated: —
 5. Fire Safety directives letter No : F-16/Estali/cc/Fire Safety/2011/3298-3398 dated 01/03/11
 6. Date of inspection : 24.12.12
 7. Name of the Inspecting Officers : ADO M.K. Chattopadhyay,
 8. Name and designation of officers from the building side : Surekha Murgai, principal
 9. Year of Construction : 1925
 10. Applicant's letter No. : 711/SKV/BBK dated 6-11-12

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBR Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mt	18 mt	MR
	• Gate width	4.5 mt	provided	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	—	—	—
	• Upper Floors	Ground floor only	—	—
	• Basements	N/A	N/A	N/A
	b. Width of staircases	—	—	—
	• Upper Floors	Ground floor only	—	—
	• Basements	N/A	N/A	N/A
	c. Protection of exits	N/A	N/A	N/A
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	N/A	N/A	N/A
		N/A	N/A	N/A
3	Compartmentation.	Not required		



20

	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management System.	Low-rise bldg, Not required		
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	N/A	N/A
		12 a/c per hour	N/A	N/A
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	60MB ABC, CO ₂	provided	MR
		ISI marked	provided	MR
			provided	MR
6	First-Aid Hose Reels.	Not required		
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	— 30 m 5 mm	N/A N/A N/A	N/A N/A N/A
7	Automatic fire detection and alarming system.	Not required		
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	N/A	N/A	N/A

g

	<ul style="list-style-type: none"> • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
17	Standby power supply	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	<i>Required</i>	<i>01 ABC type fire extingisher provided near elect. panel</i>	<i>MR</i>

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules as per the directives of Education Department vide Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01-03-2011 it is recommended to grant fire safety certificate under rule 35 of the Delhi Fire Service rules 2010 /issue shortcomings as noted at serial numbers.....

Note:-The school building is comprised of Ground floor

having total 60 rooms. The student are less than 45 in each class as

stated by the Principal vide letter dated 28/6/2011.

Submitted please
26-12-12
 DEFO on leave
 C.F.O.

[Signature]
 Signature of the Inspecting Officer
 Name (M.K. CHATTOPADHYAY)
 Designation :- Assistant Divisional Officer