

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001.

No. FG/DFS/MS/2013/LPG/71

Dated: 04/01/2013

FIRE SAFETY CERTIFICATE

Certified that the godown building for LPG in the name and style of **M/s Westend Gas Service** located at Site No-3, Opp. Virender Nagar, Behind IOC Petrol Pump, Janakpuri, New Delhi comprised of ground floor only owned/ occupied by M/s Westend Gas Service. The premises was inspected by the officers concerned of this department on 29.12.2012 in the presence of Sh. D.D. Pandey (Site Incharge) and found that the said godown have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the godown building / premises is fit for occupancy (LPG Godown) w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....4/1/13..... at New Delhi



CHIEF FIRE OFFICER
DELHI FIRE SERVICE

opc
mw

Copy to:-

1. The TM(LPG) Piyala,
Bharat Petroleum Corporation Ltd,
Post Office Asaoti, Teshil Ballabgarh, Faridabad-121102
(Ref. No. G. 5 (Godown) Dated 23.02.2012)
2. Sh. Rajinder Arora,
Westend Gas Service,
WZ-69-C, Todapur, New Delhi-110012.

Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in