

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI-110001


No.F6/DFS/MS/EH/2012/160

Dated : 09/01/13

FIRE SAFETY CERTIFICATE

Certified that the D 'Destination Bar Lounge (Unit of Bee Gee Catering Pvt. Ltd.),214-216 Local Shopping Complex,Aurbindo Place Market,Hauz Khas,New Delhi-110016. comprised of Basement, Ground + 2 Upper Floors but the Restaurant is running on 2<sup>nd</sup> floor only owned/occupied by Bee Gee Catering Pvt. Ltd. have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 & verify by the officer concerned of fire service on 26/12/12 in the presence of Mr. Birender Gusain and that the premises fit for occupancy class Group – D Assembly Building with effect from 09/01/13 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules,2010 subject to conditions printed below.

Issued 09/01/13 at New Delhi by.

  
Chief Fire Officer  
Delhi Fire Service

- Copy to:- (1) Dy. Health Officer,  
South Zone, South Delhi Municipal Corporation,  
Aurobindo Marg,Green Park,New Delhi.
- (2) D'Destination Bar Lounge (Unit of Bee Gee Catering Pvt. Ltd.),  
214-216 Local Shopping Complex,Aurbindo Place market,  
Hauz Khas,New Delhi-110016.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

N/1-  
INSPECTION REPORT

1. Name & address of the building:- D' Destination Bar Lounge (Unit of Bee Gee Catering Pvt. Ltd.),214-216 Local Shopping Complex,Aurbindo Place Market,Hauz Khas,New Delhi-110016.
2. Type of occupancy:- Group – D Assembly Building (Eating House)
3. Type of case:- New
4. Details of previous NOC:-No
5. Fire safety directives No.- No
6. Date of inspection:- 26/12/12
7. Name of the inspecting officer:-A.D.O. S.S. Kaushik , D.O. Dharm Pal Bhardwaj
8. Name & designation of officer  
From the building side:- Mr. Birender Gusain.
9. Year of construction:- 1985.
10. Applicant's letter No:-Nil dated 01/11/12 Basement, Ground + 2 Upper Floors but the Restaurant is running on 2<sup>nd</sup> floor only (DHO/SZ/2012/D-1422 dt 25-10-12)

| S.No. | Minimum Standards on fire Prevention and fire safety U/R 33 | Requirement        | Provided at site     | Remarks MR/NMR  |
|-------|---|--------------------|----------------------|-----------------|
| 1.    | <b>Access to Building</b>                                   |                    |                      |                 |
|       | 1) Road width   | 12 mtr.            | Provided             | MR              |
|       | 2) Gate width   | N/A                | N/A                  | N/A             |
|       | 3)Width of internal road                                    | N/A                | N/A                  | N/A             |
| 2.    | <b>Number, Width Type &amp; Arrangement of Exits</b>        |                    |                      |                 |
|       | A. Number of staircases                                     |                    |                      |                 |
|       | 1. Upper floors   | Required 2 Nos.    | 2 Nos.               | MR              |
|       | 2. Basements  | N/A                | N/A                  | N/A             |
|       | B. Width of staircase                                       |                    |                      |                 |
|       | 1. Upper floors   | Required 1.25 mtr. | 1.25 mtr. each       | MR Old Building |
|       | 2. Basements  | N/A                | N/A                  | N/A             |
|       | C. Protection of exits                                      |                    |                      |                 |
|       | 1. Fire check door  | N/A                | N/A                  | N/A             |
|       | 2. Pressurization   | N/A                | N/A                  | N/A             |
|       | D. No. of continuous staircase to terrace                   | Required           | Two                  | MR              |
|       | E. Width of corridor  | N/A                | N/A                  | N/A             |
|       | F. Door size  | Required 2 mtr.    | 2 mtr.               | MR              |
| 3.    | <b>Compartmentation</b>                                     |                    |                      |                 |
|       | 1) Fire check door  | N/A                | N/A                  | N/A             |
|       | 2) Sealing of electrical shafts                             | N/A                | N/A                  | N/A             |
|       | 3) Fire rating of shaft door                                | N/A                | N/A                  | N/A             |
|       | 4) Water curtain  | N/A                | N/A                  | N/A             |
|       | 5) Fire Dampers   | N/A                | N/A                  | N/A             |
| 4.    | <b>Smoke Management System</b>                              |                    |                      |                 |
|       | 1) Basements  | 30 a/c per hour    | N/A                  | N/A             |
|       | 2) Upper floors   | 12 a/c per hour    | Exhaust fan provided | MR              |
| 5.    | <b>Fire Extinguishers</b>                                   |                    |                      |                 |
|       | 1) Total numbers  | ISI Marked         | 10 Nos.              | MR              |
|       | 2) Types  |                    | ABC, Co2 & W.Co2     | MR              |
|       | 3) ISI marking  |                    | Yes                  | MR              |

-4/2-

|     |   |          |                         |     |
|-----|---|----------|-------------------------|-----|
| 6.  | <b>First-Aid Hose Reel</b>                            |          |                         |     |
|     | 1) Total number of each floor                         | Required | 1 at each floor         | MR  |
|     | 2) Length of hose reel hose                           | 30 m     | Yes                     | MR  |
|     | 3) Nozzle diameter                                    | 5 mm     | Yes                     | MR  |
| 7.  | <b>Automatic Fire Detection &amp; Alarming System</b> |          |                         |     |
|     | 1) Type of detectors                                  | NR       | Smoke detector provided | MR  |
|     | 2) Location of main panel                             | NR       | Near Kitchen            | MR  |
|     | 3) Location of repeater panel                         | N/A      | N/A                     | N/A |
|     | 4) Alternate source of power                          | N/A      | N/A                     | N/A |
|     | 5) Hooter's Location                                  | Required | Near centre & Entrance  | MR  |
| 8.  | <b>MOEFA</b>  | Required | Provided                | MR  |
| 9.  | <b>Public Address System</b>                          | N/A      | N/A                     | N/A |
| 10. | <b>Automatic Sprinkler System</b>                     |          |                         |     |
|     | 1) Basement   | N/A      | N/A                     | N/A |
|     | 2) Upper floors                                       | Required | Provided                | MR  |
|     | 3) Sprinkler above false ceiling                      | N/A      | N/A                     | N/A |
| 11. | <b>Internal Hydrants</b>                              |          |                         |     |
|     | 1) Size of riser/down-comer                           | Required | 100 mm                  | MR  |
|     | 2) Number of hydrants per floor                       | Required | 1 Nos. at each floor    | MR  |
|     | 3) Hose box   | Required | 1 Nos.                  | MR  |
| 12. | <b>Yard Hydrants</b>                                  |          |                         |     |
|     | 1) Total number of hydrants                           | N/A      | N/A                     | N/A |
|     | 2) Hose box   | N/A      | N/A                     | N/A |

|     |  |                  |               |     |
|-----|--|------------------|---------------|-----|
| 13. | <b>Pumping Arrangement</b>                     |                  |               |     |
|     | 1) Ground level                                | N/A              | N/A           | N/A |
|     | a) Discharge of main pump                      | N/A              | N/A           | N/A |
|     | b) Head of main pump                           | N/A              | N/A           | N/A |
|     | c) Number of main pump                         | N/A              | N/A           | N/A |
|     | d) Jockey pump out put                         | N/A              | N/A           | N/A |
|     | e) Jockey pump head                            | N/A              | N/A           | N/A |
|     | f) Stand by pump output                        | N/A              | N/A           | N/A |
|     | g) Stand by pump head                          | N/A              | N/A           | N/A |
|     | h) Auto starting/Manual stopping               | N/A              | N/A           | N/A |
|     | 2) Terrace level                               |                  |               |     |
|     | a) Discharge of pump                           | Required 450 LPM | 450 & 225 LPM | MR  |
|     | b) Head of pump                                | Required 35 mtr. | 35 mtr.       | MR  |
|     | c) Power supply                                | Required         | Yes           | MR  |
|     | d) Auto starting of pump                       | Required         | Yes           | MR  |
| 14. | <b>Captive Water Storage for Fire Fighting</b> |                  |               |     |
|     | 1) Under ground tank capacity                  | N/A              | N/A           | N/A |
|     | a) Draw-off connection                         | N/A              | N/A           | N/A |
|     | b) Fire service inlet                          | N/A              | N/A           | N/A |
|     | c) Access to tank                              | N/A              | N/A           | N/A |
|     | d) Over head tank capacity                     | 10,000 ltrs.     | 10,000 Ltr.   | MR  |
| 15. | <b>Exit Signage.</b>                           | Required         | Provided      | MR  |
| 16. | <b>Provision of Lifts.</b>                     |                  |               |     |

- 113 -

|  |                                 |     |     |     |
|--|---------------------------------|-----|-----|-----|
|  | a) Pressurization of lift shaft | N/A | N/A | N/A |
|  | b) Pressurization of lift lobby | N/A | N/A | N/A |
|  | c) Communication in lift car    | N/A | N/A | N/A |
|  | d) Fireman's switch             | N/A | N/A | N/A |

|     |   |          |          |     |
|-----|---|----------|----------|-----|
|     | e) Lift signage   | N/A      | N/A      | N/A |
| 17. | <b>Stand by Power Supply</b>  | Required | Provided | MR  |
| 18. | <b>Refuge Area</b>  | N/A      | N/A      | N/A |
|     | Total area location   | N/A      | N/A      | N/A |
| 19. | <b>Fire Control Room</b>  | N/A      | N/A      | N/A |
|     | a) Detector system panel  | N/A      | N/A      | N/A |
|     | b) Flow switch panel  | N/A      | N/A      | N/A |
|     | c) PA system panel  | N/A      | N/A      | N/A |
|     | d) Battery backup   | N/A      | N/A      | N/A |
|     | e) Building floor plan  | N/A      | N/A      | N/A |
| 20. | <b>Special Fire Protection System for Protection of special Risk, if any:</b> |          |          | N/A |

This is a old DDA Shopping Complex where the restaurant is situated.  
The fire protection system provided in the building were checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/-

Accordingly DFA is put up please.

Signature of the inspecting officer

Signature of the inspecting officer

Name

Dhampal Bhandari

Name: S.S.Kaushik.

Designation

Divisional Officer

Designation: - Assistant Divisional Officer.