

C/7

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI - 110001

No: F 6/DFS/MS/2011/*School/167*

Dated:- *08/01/13*

FIRE SAFETY CERTIFICATE

Certified that the *MCD Primary Boys/Girls School P-1 Block, Sultan Puri Delhi* comprised of *Ground + one* *Upper floor* owned/occupied by *M.C.D. Primary B/Girls School*.
Complied with the fire prevention and fire safety requirement in accordance with Director of Education circular Dated:-01/03/2011 and verified by the officer concerned of Fire Service on *20/11/12* in the presence of *Ms. Anita* and that the building/premises is fit for occupancy *Educational* building with effect from *08/01/13* for a period of *Three years* in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on *08/01/13* at New Delhi.

ST
Chief Fire Officer
Delhi Fire Service
92 SH

Copy to:-

1. *The Principal*
MCD B/Girls School
P-1 Block, Sultan Puri Delhi
2. *The Addl. Director (Edn.)*
North MCD Civic Centre
Minto Road, N-Delhi

Note:-This fire safety certificate is subject to compliance of the condition printed over leaf.

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
5. Basement shall be used as per NOC.
6. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

M2

INSPECTION REPORT

1. Name & address of the building: MCD Primary B/G. School, P-1 Block, Sultan Puri - Delhi -
2. Type of Occupancy: Educational
3. Type of Case: ~~New Case/Renewal~~
4. Details of previous NOC: Letter No. Nil Dated: _____
5. Fire Safety directives letter No: Circular, Dir. of Edun - 1/3/2012.
6. Date of inspection: 20-12-2012
7. Name of the Inspecting Officers: ADO - SHYAM LAL
8. Name and designation of officers from the building side: Ms. Anita. (Teacher)
9. Year of Construction: 1998 (Ground + one)
10. Applicant's letter No. MCPGS/P-1/161/9-7-12 dated 9-7-2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Circular, Dir. of Edun. 1/3/2011		Remarks MR/NMR
		Requirement	Provided at site	
1	Access to building			
	• Road width	Accessible	9 m ✓	M/R
	• Gate width	—	4 m ✓	M/R
	• Width of internal road	—	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	1	1	M/R
	• Upper Floors	1	1 ✓	M/R
	• Basements	Nil	Nil ✓	Nil
	b. Width of staircases			
	• Upper Floors	1.5 m	1.5 m ✓	M/R
	• Basements	Nil	Nil	Nil
	c. Protection of exits			
	• Fire check door		N/R	
	• Pressurization		N/R	
	e. No. of continuous staircases to terrace		N/R	
	g. Width of Corridor	R	2.20 m ✓	M/R
	h. Door Size	1 m	1 m with door fitting ✓	M/R

43

3	Compartmentation.			
	• Fire check door		NIR	
	• Sealing of electrical shafts		NIR	
	• Fire Rating of shaft door			
	• Water Curtain			
	• Fire Dampers			
4	Smoke Management System.			
	• Basements	30 a/c per hour	NIR	
	• Upper floors	12 a/c per hour	NIR	
5	Fire Extinguishers			
	• Total numbers	08	08 ✓	MIR
	• Types	ABC/CO2(2.5kg)	ABC ✓	MIR
	• IS marking	ISI marked	yes ✓	MIR
6	First-Aid Hose Reels.			
	• Total numbers on each floor		NIR	
	• Length of hose reel hose	30m		
	• Nozzle diameter	5 mm		
7	Automatic fire detection and alarming system.			
	• Type of detectors		NIR	
	• Location of Main Panel			
	• Location of Repeater Panel			
	• Alternate source of power			
	• Hooters' Location			
8	MOEFA		NIR	
9	Public Address System.		NIR	
10	Automatic Sprinkler System.			
	• Basement		NIR	

N/Y

10	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 		<p>N/R</p> <p>N/R</p>	
11	<p>Internal Hydrants</p> <ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 		<p>N/R</p> <p>1</p>	
12	<p>Yard Hydrants.</p> <ul style="list-style-type: none"> • Total number of hydrants • Hose Box 		<p>N/R</p> <p>N/R</p>	
13	<p>Pumping Arrangements.</p> <ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 		<p>N/R</p>	
14	<p>Captive Water Storage for fire fighting.</p> <ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 		<p>N/R</p> <p>N/R</p>	

N/S

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 		NIR	
15	Exit Signage.		NIR	
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 		N/A	
17	Standby power supply		NIR	
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 		N/A	
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 		NIR	
20	Special Fire Protection Systems for Protection of special Risks, if any:	Nil	Nil	Nil

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.

D-20 (NW) - leave

[Signature]
 ADO (CRN)