

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001

NO.F6/DFS/MS/GH/2013/ 170

Dated: 09/01/2013

**FIRE SAFETY CERTIFICATE**

Certified that Shanti, Guest House, 3838, Tel Mandi, Paharganj, New Delhi comprised of ground floor (Reception + 05 guest rooms + 02 stores), first floor (03 guest rooms + owner's residence), second floor (05 guest rooms + 01 staff room + staff kitchen) & third floor (1 staff room + 01 store room) was granted NOC by this department vide letter No. F.6/DFS/MS/GH/2009/2237 dated 24-07-2009. The premises was re-inspected by the officer concerned of this department on 30-12-2012 in the presence of Mr. Gopal Krishan, Manager of the guest house and found that the said guest house have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and that the premises / building is fit for occupancy class **residential (guest house)** with effect from 9/1/13 for a period of **3(three)** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi fire service Rules,2010.

Issued on 9/1/13 at New Delhi by.

  
Chief Fire Officer  
Delhi Fire Service

Copy to: -

1. The Addl.C.P (Lic.), Police Station, Defence Colony, 1<sup>st</sup> floor, New Delhi w.r.t. your letter No.57604-05/Addl.C.P./Lic(H) dated 01-10-12
2. The Manager, Shanti, Guest House, 3838, Tel Mandi, Paharganj, New Delhi

**Conditions for the validity of fire safety certificate**

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

INSPECTION REPORT

1. Name & address of the building : Shanti Guest House, 3838, Tel Mandi, Paharganj,  
 2. Type of Occupancy : Lodging House / ~~Eating House~~ / Club Not bell  
 3. Type of Case : Renewal / ~~New case~~  
 4. Details of previous NOC : Letter No. Fo/DR/MS/GH/2009/2237 Dated: 24/3/2009  
 5. Fire Safety directives letter No : —  
 6. Date of inspection : ~~28/12~~ 30/12/2012  
 7. Name of the Inspecting Officers : Sh. M.K. Chattopadhyay, ADO (HQ)  
 8. Name and designation of officers from the building side : Shri Gopal Krishna, Manager  
 9. Year of Construction : 1980  
 10. Applicant's letter No. : 57604-05/ Addl. CP/UC(H) dated 1/10/2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ <del>SBI</del> Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	<u>spl area</u>	<u>10mt</u>	<u>MR</u>
	• Gate width	<u>—</u>	<u>Directly accessible from the road.</u>	<u>MR</u>
	• Width of internal road	<u>NA</u>	<u>NA</u>	<u>NA</u>
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	<u>—</u>	<u>—</u>	<u>—</u>
	• Upper Floors	<u>01</u>	<u>01</u>	<u>MR</u>
	• Basements	<u>NA</u>	<u>NA</u>	<u>NA</u>
	b. Width of staircases	<u>—</u>	<u>—</u>	<u>—</u>
	• Upper Floors	<u>0.80mt</u>	<u>1.06mt</u>	<u>MR</u>
	• Basements	<u>NA</u>	<u>NA</u>	<u>NA</u>
	c. Protection of exits	<u>N/A</u>	<u>N/A</u>	<u>-----</u>
	• Fire check door	<u>N/A</u>	<u>N/A</u>	<u>-----</u>
	• Pressurization	<u>N/A</u>	<u>N/A</u>	<u>-----</u>
	e. No. of continuous staircases to terrace	<u>01</u>	<u>01</u>	<u>MR</u>
	g. Width of Corridor	<u>N/A</u>	<u>N/A</u>	<u>-----</u>
	h. Door Size	<u>N/A</u>	<u>N/A</u>	<u>-----</u>
		<u>N/A</u>	<u>N/A</u>	<u>-----</u>
3	<b>Compartmentation.</b>			
	• Fire check door	<u>N/A</u>	<u>N/A</u>	<u>-----</u>

J

	<ul style="list-style-type: none"> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>	N/A	N/A	-----
		N/A	N/A	-----
		N/A	N/A	-----
		N/A	N/A	-----
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	30 a/c per hour 12 a/c per hour	<del>N/A</del> M/A	M/A M/A
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers 06</li> <li>Types water CO<sub>2</sub>, CO<sub>2</sub></li> <li>IS marking</li> </ul>	ISI marked	provided provided provided	MR MR MR
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	01 30 m 5 mm	provided provided provided	MR MR MR
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	----- ----- ----- ----- -----
8	<b>MOEFA</b>			
9	<b>Public Address System.</b>			
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	M/A N/A N/A	M/A N/A N/A	M/A ----- -----
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	M/A M/A M/A	M/A N/A M/A	M/A M/A M/A

*[Handwritten signature]*

12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	N/A	N/A	-----
	• Hose Box	N/A	N/A	-----
13	<b>Pumping Arrangements.</b>			
	• Ground Level	N/A	N/A	-----
	➤ Discharge of main Pump	N/A	N/A	-----
	➤ Head of Main pump	N/A	N/A	-----
	➤ Number of main pumps	N/A	N/A	-----
	➤ Jockey Pump out put	N/A	N/A	-----
	➤ Jockey pump head	N/A	N/A	-----
	➤ Standby Pump out put	N/A	N/A	-----
	➤ Standby Pump Head	N/A	N/A	-----
	➤ Auto Starting/ Manual stopping	N/A	N/A	-----
	➤ Pump House Access	N/A	N/A	-----
	• Terrace level	N/A	N/A	-----
	➤ Discharge of pump	225 LPM	provided	MR
	➤ Head of the pump	25 <del>ft</del> mt	provided	MR
	➤ Power Supply	Required	provided 15 kVA	MR
	➤ Auto Starting of pump	-	provided near Ground Floor	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	N/A	N/A	-----
	➤ Draw-off connection	N/A	N/A	-----
	➤ Fire service inlet	N/A	N/A	-----
	➤ Access to tank	N/A	N/A	-----
	• Overhead Tank capacity	25000 ltr	25000 ltr	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N/A	N/A	-----
	• Pressurization of Lift lobby	N/A	N/A	-----
	• Communication In lift Car	N/A	N/A	-----
	• Fireman's Grounding Switch	N/A	N/A	-----

*[Handwritten Signature]*

	• Lift Signage	N/A	N/A	-----
17	Standby power supply	Required	15 kVA	M2
18	Refuge Area.			
	➤ Total Area	N/A	N/A	-----
	➤ Location	N/A	N/A	-----
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	-----
	• Flow Switch Panel	N/A	N/A	-----
	• PA System Panel	N/A	N/A	-----
	• Batter backup	N/A	N/A	-----
	• Building Floor Plans	N/A	N/A	-----
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	One CO <sub>2</sub> type fire extinguisher provides near elect panel.	M2

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant / renew Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

DO (ED)  
 info on leave  
 Forwarded pl  
 2-1-13  
 C.F.O.  
 2/1  
 8/1/13

Signature of the Inspecting Officer  
 Name M.K.CHATTOPADHYAY  
 Designation :- Asstt. Div. Officer (HQ)

F.T. m.s. cell