

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110001**


No.F6/MS/DFS/2012/141

Dated : 09/01/13

FIRE SAFETY CERTIFICATE

Certified that the **Defence Colony (WA) Club** located at **C-600, Chetna Marg, Defence Colony, New Delhi-110024**..comprised of **Ground + 1 Upper Floor** was granted NOC by this department vide letter No.F6/DFS/MS/10/1240 dated **28/04/10** The premises was re-inspected by the officer concerned of this department on **20/12/12** in the presence of **Mr. Suresh Kumar** and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Group - D Assembly Building** with effect from 09/01/13 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued 09/01/13 at New Delhi by.


Chief Fire Officer
Delhi Fire Service

Copy to:- (1) The D.E.O.(Club)
Office of the Commissioner of Excise
Entt. & Luxury Tax, Govt. of NCT of Delhi,
L Block, Vikas Bhawan, I.P. Estate, New Delhi.

(2) Defence Colony (WA) Club,
C-600, Chetna Marg, Defence Colony, New Delhi-110024.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

N/12
INSPECTION REPORT

1. Name & address of the building:- Defence Colony (WA) Club, C-600, Chetna Marg, Defence Colony, New Delhi-110024.
2. Type of occupancy:- Group – D Assembly Building
3. Type of case:- Renewal
4. Details of previous NOC:-No. F6/DFS/MS/10/1240 dated 28/04/10
5. Fire safety directives No.- No
6. Date of inspection:- 20/12/12
7. Name of the inspecting officer:-A.D.O. S.S. Kaushik
8. Name & designation of officer
From the building side:- Mr. Suresh Kumar.
9. Year of construction:- 1976
10. Applicant's letter No:- DCC/44/Fire dated 19/11/12 Ground + 1 Upper Floor

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement NBC/BBL	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	12 mtr.	Provided	MR
	2) Gate width	5 mtr.	Provided	MR
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	Required	3 Nos.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	Required	117 cms., 105 cms. & 59 cms..	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	One	one	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1 mtr.	1 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	N/A	N/A
	2) Upper floors	12 a/c per hour	Exhaust fan	MR
5.	Fire Extinguishers			
	1) Total numbers	ISI Marked	25 Nos.	MR
	2) Types		ABC, Co2 & W.Co2	MR
	3) ISI marking		Yes	MR

6.	First-Aid Hose Reel			
	1) Total number of each floor	One at each floor	One at each floor	MR
	2) Length of hose reel hose	30 m	Yes	MR
	3) Nozzle diameter	5 mm	Yes	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Yes	Provided	MR
9.	Public Address System	Yes	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	Yes	Provided	MR
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	Yes	100 mm	MR
	2) Number of hydrants per floor	Yes	1 Nos.	MR
	3) Hose box	Yes	1 Nos.	MR
12.	Yard Hydrants			
	1) Total number of hydrants	Yes	4 Nos.	MR
	2) Hose box	Yes	4 Nos.	MR
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	Required	900 LPM & 180 LPM	MR
	b) Head of pump	35 mtr.	35 mtr.	MR
	c) Power supply	Yes	Provided	MR
	d) Auto starting of pump	Yes	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	Yes	Provided	MR
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	5,000 ltrs.	5,000 Ltr.	MR
15.	Exit Signage.	Yes	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A

	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Yes	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	Yes	Provided	MR
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The shortcomings communicated vide letter dated 04/04/12 found complied
The fire protection system provided in the building were checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/-----

Accordingly DFA is put up please.

Signature of the inspecting officer

Signature of the inspecting officer

Name

Name:- S.S. Kaushik.

Designation

Designation:- Assistant Divisional Officer.

D. S. Singh

[Signature]

[Signature]
28/12/12