

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No. F6/DFS/MS/School/2013/209

Dated: 11/01/13

FIRE SAFETY CERTIFICATE

Certified that the Toronto Public School, Plot No-6, G-Block, Madanpur Khadar Extn-III, New Delhi, comprised of ground floor only Owned/Occupied by Toronto Public School have complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 and verified by officer concerned of Delhi Fire Service on 21/12/2012 in the presence of Mr. Sabbir Khan, Chairman of the school and that the building/premises is fit for occupancy class-B "Educational building" with effect from 11/01/13 for a period of THREE years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010.

Issued on 11/01/13 at New Delhi by



Chief Fire Officer
Delhi Fire Service

ofc
m.

Copy To: -

1. The Directorate of Education, Govt. of NCTD, Old Secretariat, New Delhi.
2. The Chairman, Toronto Public School, Plot no-6, G-Block, Madanpur Khadar Extn-III New Delhi-110076.

Conditions for the validity of fire safety Certificate

- a) All the Fire Safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
- b) Building Sanctioning Authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c) The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d) The Basement shall be used strictly as per the provisions of Building Bye Laws.
- e) The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : TORONTO PUBLIC SCHOOL
 : PLOT NO: 6, G-Block,
 : Madampun Khadar Extn-III, New Delhi-76
2. Type of Occupancy : Educational
3. Type of Case : New
4. Details of previous NOC : Nil Dt. —
5. Fire Safety Directives letter No : Ste. of Edn. Circular dt 01/03/2011
6. Date of Inspection : 21/12/2012
7. Name of the Inspecting Officer : Rajan Wadhwa, A20/Med.
8. Name and designation of the Officers from the building side : Mr. Sabbir Khan (Chairman)
9. Year of Construction : 2009 (Ground Floor only)
10. Applicant's letter No. : Nil dt 29/11/2012

S. No.	Minimum Standards on Fire Prevention and Fire Safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	<u>Accessible</u>	<u>9 mts</u>	<u>M/R</u>
	• Gate width	<u>NA</u>	<u>NA</u>	<u>NA</u>
	• Width of internal road	<u>NA</u>	<u>NA</u>	<u>NA</u>
2	Number, Width, Type & Arrangement of Exits			
	• Number of Staircase		<u>NA</u>	
	➤ Upper floors			
	➤ Basement			
	• Width of Staircase		<u>NA</u>	
	➤ Upper floors			
	➤ Basement			
	• Protection of Exits		<u>NA</u>	
	➤ Upper floors			
	➤ Basement			
	• No of Continuous Staircases to terrace	<u>NA</u>	<u>NA</u>	<u>NA</u>
	• Width of Corridor	<u>NA</u>	<u>NA</u>	<u>NA</u>
	• Door Size / Width	<u>1.0 mts</u>	<u>1.0 mts</u>	<u>M/R</u>


3	Compartmentation				NA
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 				
4	Smoke Management System				NA
	<ul style="list-style-type: none"> • Basements • Upper Floors 				
5	Fire Extinguishers				
	<ul style="list-style-type: none"> • Total Number • Types • IS marking 	<u>One / 300 m²</u> ABC / CO2 ISI mark	03 Nos ABC YES	MIR MIR MIR	
6	First-Aid Hose Reels				NA
	<ul style="list-style-type: none"> • Total Number on each floor • Length of hose reel hose • Nozzle diameter 	_____/Per Floor 30 m 5mm			
7	Automatic Fire Detection and Alarming System				NA
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooter's Location 				
8	MOEFA				NA
9	Public Address System				NA
10	Automatic Sprinkler System				NA
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 				
11	Internal Hydrant				NA
	<ul style="list-style-type: none"> • Size of riser/down comer • Number of hydrants per floor • Hose Box 				
12	Yard Hydrant				NA
	<ul style="list-style-type: none"> • Total Number of hydrants • Hose Box 				

13	Pumping Arrangements	<p>Ground Level</p> <p>NA</p> <p>➤ Number of main pump</p> <p>➤ Discharge of main pump</p> <p>➤ Head of main pump</p> <p>➤ Jockey pump out put</p> <p>➤ Jockey pump Head</p> <p>➤ Standby pump out put</p> <p>➤ Standby Pump Head</p> <p>➤ Auto Starting/Manual stopping</p> <p>➤ Pump House Access</p> <p>Terrace level</p> <p>NA</p> <p>➤ Discharge of pump</p> <p>➤ Head of the pump</p> <p>➤ Power Supply</p> <p>➤ Auto starting /Manual stopping</p>
14	Captive Water Storage for Fire Fighting	<p>NA</p> <p>• Underground tank capacity</p> <p>➤ Draw-off connection</p> <p>➤ Fire service inlet</p> <p>➤ Access to tank</p> <p>• Overhead tank capacity</p>
15	Exit Signage	
16	Provision of Lifts	<p>NA</p> <p>• Pressurization of Lift Shaft</p> <p>• Pressurization of Lift lobby</p> <p>• Communication in lift Car</p> <p>• Fireman's Grounding Switch</p> <p>• Lift Signage</p>
17	Standby Power Supply	
18	Refuge Area	<p>NA</p> <p>• Total Area</p> <p>• Location</p>
19	Fire Control Room	<p>NA</p> <p>• Detector System Panel</p> <p>• Flow Switch Panel</p> <p>• PA System Panel</p> <p>• Battery back up</p> <p>• Building Floor Plans</p>

20	Special Fire Protection System for Protection of special risk, if any	NA	NA	NA
----	---	----	----	----

The Fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules , It is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / ~~issue shortcomings as noted at serial Number.....~~.....



Signature of Inspecting Officer

Name : RAJAN WADEHRA

Designation: A. D. O. (M.Rd.)