

C/184

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI - 110001



No: F 6/DFS/MS/2013/ school/278

Dated:- 17/01/13

FIRE SAFETY CERTIFICATE

Certified that the Anubhav Public School, Gali No. 2 Vthranchal Enclave East Nizam Bazaar located at East Nizam Bazaar Delhi comprised of Ground + Two upper floors occupied by Anubhav Public School was issued NOC vide this office letter No. F-6/DFS/MS/2006/3177 Dated 26-10-2006. The premises was re-inspected by the officer concerned of this department on 21/12/12 and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore, deemed complied with the Circular of Director Education No 262-362 dt. 17-1-2005/premises is fit for occupancy Class Educational with effect from 17/01/13 for a period of Three years in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 17/01/13 at New Delhi.


151
Chief Fire Officer
Delhi Fire Service
etc 

Copy to:-

1. The Principal
Anubhav Public School
Vthranchal Enclave
Gali No. 2, East Nizam Bazaar Delhi Rly
2. The Addl. Director (Edu)
North West Civic Centre
M. Min Road N. Delhi

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
5. Basement shall be used as per NBC.
6. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

RenewalINSPECTION REPORT

1. Name & address of the building: Anubhav Public School, Gali No. 2, Uttaranchal Enclave, Sant Nagar, Barrack, Delhi-84.
2. Type of Occupancy: Educational.
3. Type of Case: New Case/ Renewal
4. Details of previous NOC: Letter No F-6/MS/DFS/06/3177 Dated: 26-10-2006
5. Fire Safety directives letter No: Circular, Dir. of Edun. 17-1-2005, No. 262-362.
6. Date of inspection: 21-12-2012
7. Name of the Inspecting Officers: ADO - SHYAM LAL
8. Name and designation of officers from the building side: Smt. Susheela. (Principal)
9. Year of Construction: 2002, (Grr+2)
10. Applicant's letter No.: AP-10/2012 dated 10-12-2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	<u>Circular, Dir. of Edun-17-1-2005</u> Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	<u>Accessible</u>	<u>5 m</u>	<u>M/R</u>
	• Gate width	<u>-h-</u>	<u>2 m</u>	<u>M/R</u>
	• Width of internal road	<u>-h-</u>	<u>N/A</u>	<u>N/A</u>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	<u>2</u>	<u>2</u>	<u>M/R</u>
	• Upper Floors	<u>2</u>	<u>2</u>	<u>M/R</u>
	• Basements	<u>Nil</u>	<u>Nil</u>	<u>Nil</u>
	b. Width of staircases			
	• Upper Floors	<u>1.5 m</u>	<u>1.2 m & 1.05 m</u>	<u>M/R (old case)</u>
	• Basements	<u>Nil</u>	<u>Nil</u>	<u>Nil</u>
	c. Protection of exits			
	• Fire check door	<u>N/R</u>	<u>N/P</u>	<u>N/A</u>
	• Pressurization	<u>N/R</u>	<u>N/P</u>	<u>N/A</u>
	e. No. of continuous staircases to terrace	<u>R</u>	<u>one</u>	<u>M/R</u>
	g. Width of Corridor	<u>R</u>	<u>1 m</u>	<u>M/R (old case)</u>
	h. Door Size	<u>1 m</u>	<u>1 m with door fitting</u>	<u>M/R (old case)</u>

3	Compartmentation.			
	• Fire check door	N/R	N/P	N/A
	• Sealing of electrical shafts	N/R	N/P	N/A
	• Fire Rating of shaft door	N/R	N/P	N/A
	• Water Curtain	N/R	N/P	N/A
	• Fire Dampers	N/R	N/P	N/A
4	Smoke Management System.			
	• Basements	30 a/c per hour	N/R	N/A
	• Upper floors	12 a/c per hour	N/R	N/A
5	Fire Extinguishers			
	• Total numbers	05	05	M/R
	• Types	ABC / CO ₂ (2.5kg)	ABC	M/R
	• IS marking	ISI marked	yes	M/R
6	First-Aid Hose Reels.			
	• Total numbers on each floor	one at each	provided.	M/R
	• Length of hose reel hose	30 m	provided	M/R
	• Nozzle diameter	5 mm	provided	M/R
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/R	N/P	N/A
	• Location of Main Panel	N/R	N/P	N/A
	• Location of Repeater Panel	N/R	N/P	N/A
	• Alternate source of power	N/R	N/P	N/A
	• Hooters' Location	N/R	N/P	N/A
8	MOEFA	N/R	N/P	N/A
9	Public Address System.	N/R	N/P	N/A
10	Automatic Sprinkler System.			
	• Basement	N/R	N/P	N/A

	<ul style="list-style-type: none"> Upper Floor 	N/R	N/P	N/A
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N/R	N/P	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	N/R	N/P	N/A
	<ul style="list-style-type: none"> Number of hydrants per floor 	N/R	N/P	N/A
	<ul style="list-style-type: none"> Hose Box 	N/R	N/P	N/A
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	N/R	N/P	N/A
	<ul style="list-style-type: none"> Hose Box 	N/R	N/P	N/A
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level 	N/R	N/P	N/A
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	N/R	N/P	N/A
	<ul style="list-style-type: none"> ➤ Head of Main pump 	N/R	N/P	N/A
	<ul style="list-style-type: none"> ➤ Number of main pumps 	N/R	N/P	N/A
	<ul style="list-style-type: none"> ➤ Jockey Pump out put 	N/R	N/P	N/A
	<ul style="list-style-type: none"> ➤ Jockey pump head 	N/R	N/P	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	N/R	N/P	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	N/R	N/P	N/A
	<ul style="list-style-type: none"> ➤ Auto Starting/ Manual stopping 			
	<ul style="list-style-type: none"> ➤ Pump House Access 	N/R	N/P	N/A
	<ul style="list-style-type: none"> Terrace level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump 	225 LB/minute	Provided	MIR ✓
	<ul style="list-style-type: none"> ➤ Head of the pump 	30 m	Provided	MIR
	<ul style="list-style-type: none"> ➤ Power Supply 	N/R	N/P	N/A
	<ul style="list-style-type: none"> ➤ Auto Starting of pump 	R	Provided	MIR ✓
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity 	N/R	N/P	N/A
	<ul style="list-style-type: none"> ➤ Draw-off connection 	N/R	N/P	N/A

	➤ Fire service inlet	N/R	N/P	N/A
	➤ Access to tank	N/R	N/P	N/A
	• Overhead Tank capacity	5000 lbs.	Provided.	m/r ✓
15	Exit Signage.	R	Provided	m/r
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/R	N/P	N/A
	• Pressurization of Lift lobby	N/R	N/P	N/A
	• Communication In lift Car	N/R	N/P	N/A
	• Fireman's Grounding Switch	N/R	N/P	N/A
	• Lift Signage	N/R	N/P	N/A
17	Standby power supply			
18	Refuge Area.			
	➤ Total Area	N/R	N/P	N/P
	➤ Location	N/R	N/P	N/P
19	Fire Control Room			
	• Detector System Panel	N/R	N/P	N/A
	• Flow Switch Panel	N/R	N/P	N/A
	• PA System Panel	N/R	N/P	N/A
	• Batter backup	N/R	N/P	N/A
	• Building Floor Plans	N/R	N/P	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	NIL	NIL	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers...

D.O. (N/A) leave
Dcto (EP)

CFO
Recd
26/12

Shyam Lal
ADDCRN
22/12/2012
(SHYAM LAL)