

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001

NO.F.6/DFS/MS/EH/2013/236

Dated: 15/01/13

**FIRE SAFETY CERTIFICATE**

Certified that **Bikanerwala Food Court restaurant** located at first floor of Rajiv Gandhi Handicrafts Bhawan, Baba Kharak Singh Marg, New Delhi have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi fire service Rules 2010 and verified by the officer concerned of Delhi Fire Service on **14.12.2012** in presence of Shri Vijay Singh, Manager of the restaurant and that the building/premises is fit for occupancy class Assembly (restaurant) with effect from ~~15/01/13~~ for a period of **3(three)** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ~~15/01/13~~ at New Delhi by.



**Chief Fire Officer  
Delhi fire service**



Copy to: -

1. The Medical Officer of Health & Licensing Authority, Health Department, NDMC, Parliament Street, New Delhi
2. The Director (Handicrafts), Govt. of India, Ministry of Textile, Office of the Development Commissioner (Handicraft), West Block No. 7, R.K.Puram, New Delhi

**Conditions for the validity of fire safety certificate**

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

old case

INSPECTION REPORT

1. Name & address of the building : Bikanerwala Food Court restaurant (1<sup>st</sup> floor), Rajiv Gandhi Handicrafts Bhawan, Baba Kharak Singh Marg, New Delhi
2. Type of Occupancy: Assembly (restaurant)
3. Type of Case : Renewal
4. Details of previous NOC : F6/MS/DFS/2008/987 dated 08.04.2008
5. Fire safety directives letter No : N/A
6. Date of inspection: 30.12.2012
7. Name of the Inspecting Officers: Dharamvir Singh Yadav DO (CD) and M.K.Chattopadhyay ADO (CC)
8. Name and designation of officers  
from the building side : Mr. Vijay Singh (Manager)
9. Year of Construction :2007-08
10. Applicant's letter No. : Letter No.7/7/8/88/MSS/17372 dated 05.11.2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6 Meter	12 mts, 09 mts	MR
	• Gate width	-----	4.5 mts	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, width, type & arrangement of exits			
	a. Number of staircases	✓	✓	✓
	• Upper Floors	02	02	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases	✓	✓	✓
	• Upper Floors	1.5 Meter	1.5 Meter each	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits	✓	✓	✓
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	02 No.	02 No.	MR
	e. Width of Corridor	N/A	N/A	N/A



	f. Door Size	1.5 mts	1.5 mts	MR
3	Compartmentation			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	Not Required	Not Required	-----
		Not Required	Not Required	-----
		Not Required	Not Required	-----
		Not Required	Not Required	-----
		Not Required	Not Required	-----
4	Smoke Management System			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour	N/A	N/A
		12 a/c per hour	Smoke venting	MR
			Provided in the kitchen	
5	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	06 No. CO <sub>2</sub> , Water CO <sub>2</sub> ISI marked	Provided	MR
			provided	MR
			Yes	MR
6	First-Aid Hose Reels			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	01 No 30 m 20 mm	Stair cases entry provided	MR
			Provided	MR
			Provided	MR
7	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>	conventional	Provided	MR
		Fire Control Room	Provided	MR
		Near staircase	Provided	MR
		DG	Provided	MR
		-----	Staircases entry	MR
8	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>	Required	Provided	MR

by

	<ul style="list-style-type: none"> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	Required	Provided	MR
		Not Required	Not Required	-----
11	Internal Hydrants			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	100 mm	100 mm	MR
	<ul style="list-style-type: none"> <li>Number of hydrants</li> </ul>	01 No.	provided	MR
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	01 No.	provided	MR
12	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	Not Required	Not Required	-----
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	Not Required	Not Required	-----
13	Pumping Arrangements			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main pump</li> <li>Head of main pump</li> <li>Number of main pumps</li> <li>Jockey pump out put</li> <li>Jockey pump head</li> <li>Standby pump out put</li> <li>Standby pump Head</li> <li>Auto starting/ manual stopping</li> <li>Pump house access</li> </ul> </li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> </ul> </li> </ul>			
		2280 LPM	2850 LPM	MR
		70 mts	70 mts	MR
		1 No.	1 No.	MR
		180 LPM	180 LPM	MR
		70 mts	70 mts	MR
		2280 LPM	2850 LPM	MR
		70 mts	70 mts	MR
		Required	Provided	MR
		Ground Floor	Provided	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
		Required	Provided	MR
	Auto Starting Of Pump	Required	Provided	MR
14	Captive Water Storage for firefighting			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> </ul>	100 KL	100 KL	MR

J

	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Open Ground	Provided	MR
	• Overhead Tank capacity	10 KL	10 KL	MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	DG Supply	MR
18	Refuge Area			
	➤ Total Area	Not Required	Open Terrace	-----
	➤ Location	Not Required		-----
19	Fire Control Room			
	• Detector System Panel	Required	Provided	MR
	• Flow Switch Panel	Required	Provided	MR
	• PA System Panel	Required	Provided	MR
	• Battery backup	Required	Provided	MR
	• Building Floor Plans	Required	Provided	MR
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	Two CO <sub>2</sub> type fire extinguishers found provided near elect. panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renew Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Dharamvir Singh Yadav  
DO(CD)

M.K.Chattopadhyay  
ADO (CC)