

CJ.7

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/School/2013/293 Dated: 17/01/2012

FIRE SAFETY CERTIFICATE

Certified that the **De Indian Public School** located at **Pocket-11, Sector-24, Rohini, Delhi-110 085**, is comprised of basement, ground plus two upper floors only, occupied by **De Indian Public School**, was issued NOC vide this office letter no. **F6/DFS/MS/2009/1600** dated **03-06-2009**. The premises was re-inspected by the officer concerned of this department on **01/11/2012** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore, deemed complied with the Director of Education circular no. **262-362 Dated 17.01.2005** and the building /premises is it for occupancy **Class-B (Educational)** with effect from 17/01/13 for a period of three years in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule, 2010.



Issued on 17/01/13 at New Delhi by


17/1
Chief Fire Officer
Delhi Fire Service

Copy to:

1. Mrs. Seema Awasthi (Headmistress)
De Indian Public School located at Pocket-11, Sector-24, Rohini, Delhi-110 085
2. The Director of Education, Old Secretariat, Delhi

Note :- For general fire safety directives please over leaf.



9717996877

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

N/11

May kindly peruse letter no. DIPS/2011-12/28 dated 26-09.12 received from the Headmistress, regarding issue of NOC from fire and safety point of view. In r/o **De Indian Public School located at Pocket-11, Sector-24, Rohini, Delhi-110 085**. The premises was inspected by the undersigned on dated 01.11.12 & observed that the school building is comprised of basement, ground plus two upper floors only. However following fire safety measures are put up on the prescribe Performa

1. Name & address of the building : **De Indian Public School located at Pocket-11, Sector-24, Rohini, Delhi-110 085**
2. Type of Occupancy : Class -B (Educational)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2009/1600 dated 03-06-2009.
5. Fire Safety directives letter No. : N.A.
6. Date of inspection : 01/11/2012
7. Name of the Inspecting Officers : Divisional Officer Sunil Chawdhary
8. Name and designation of officers
From the building side : Mrs. Seema Awasthi
9. Year of Construction :
10. Applicant's letter No. : DIPS/2011-12/28 dated 01.11.2012

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building	Required	Provided	M/R
	• Road width	Accessible	Provided	M/R
	• Gate width	Accessible	Provided	M/R
	• Width of internal road	Accessible	Provided	M/R
2.	Number, Width, Type & Arrangement of Exits			

M/12

a. Number of staircases	<ul style="list-style-type: none"> Upper Floors 	Two	Two	M/R	
		Two	Two	M/R	
	b. Width of staircases	<ul style="list-style-type: none"> Upper Floors 	1.5 mtr	160 cm, 130 cm	M/R NOC already issued
			1.5 mtr	160 cm, 137 cm	M/R
	c. Protection of exits	<ul style="list-style-type: none"> Fire check door 	N.A.	N.A.	N.A.
			N.A.	N.A.	N.A.
	d. No. of continuous staircases to terrace				
	e. Width of Corridor		2mtrs.	2 mtrs.	M.R.
	f. Door size		1.5 mtr	90 cm & 93 cm	M.R.
	3. Compartmentation.				
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N.A.	N.A.	N.A.	
N.A.		N.A.	N.A.		
N.A.		N.A.	N.A.		
N.A.		N.A.	N.A.		
N.A.		N.A.	N.A.		
4. Smoke Management System.					
<ul style="list-style-type: none"> Basements Upper floors 	N.A.	N.A.	Not applicable		
	N/R	N/R	Not applicable		
5. Fire Extinguishers		Required	Provided	MR	
<ul style="list-style-type: none"> Total numbers 	20 nos.	22	M/R		

2/13

	<ul style="list-style-type: none"> Types IS marking 	ISI marked ABC type Yes	provided provided	M/R M/R
6.	First-Aid Hose Rees.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	2 30 m 5 mm required	Provided provided Provided	M/R M/R M/R
7.	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's Location 	N.A. N.A. N.A. N.A. N.A.	N.A. N.A. N.A. N.A. N.A.	N.A. N.A. N.A. N.A. N.A.
8.	MOEFA	Required	Provided	M/R
9.	Public Address System.	Required	Provided	M/R
10.	Automatic Sprinkler system			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	Required N.A. N.A.	Provided N.A. N.A.	M/R N.A. N.A.
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor 	2 2	Provided Provided	M/R M/R

N/14

	<ul style="list-style-type: none"> Hose Box 	2	Provided	M/R
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> Hose Box 	N.A.	N.A.	N.A.
13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	N.A.	N.A.	N.A.
	➤ Head of Main pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey Pump out put	180 LPM	Provided	M.R.
	➤ Jockey pump head	40	Provided	M.R.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting/Manual stopping	N.A.	N.A.	N.A.
	➤ Pump Hose Access	N.A.	N.A.	N.A.
	Terrace level			
	➤ Discharge of pump	900 LPM	Provided	M/R
	➤ Head of the pump	40 mtr	Provided	M/R
	➤ Power supply	Required	Provided	M.R.
	➤ Auto Starting of pump	N/R	N/R	N/R
14.	Captive Water Storage for fire fighting.			

N/15

	Underground tank capacity			
	➤ Draw -off connection	N/R	N/R	Not applicable
	➤ Fire service inlet	N/R	N/R	Not applicable
	➤ Access to tank	N/R	N/R	Not applicable
	➤ Overhead Tank Capacity	5,000 ltrs	5,000 ltrs	M.R.
15	Exit Signage.	Required	Provided	M/R
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	N/A	N/A	Not applicable
	• Pressurization of Lift lobby	N/A	N/A	Not applicable
	• Communication In lift Car	N/A	N/A	Not applicable
	• Fireman's Grounding Switch	N/A	N/A	Not applicable
	• Lift Signage	N/A	N/A	Not applicable
17.	Standby power supply			
18.	Refuge Area			
	➤ Total Area	N/R	N/R	Not applicable
	➤ Location	N/R	N/R	Not applicable
19.	Fire Control Room			
	➤ Detector System Panel	N/R	N/R	Not applicable
	➤ Flow Switch Panel	N/R	N/R	Not applicable
	➤ PA system Panel	N/R	N/R	Not applicable
	➤ Batter backup	N/R	N/R	Not applicable

P/16

	➤ Building Floor plans	N/R	N/R	Not applicable
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N/R	N/R	Not applicable

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/



Signature of the Inspection Officer

Signature of the Inspection Officer

Name Sunil Chowdhary

Name

Designation D.O. (MN)

Designation