

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001


No F 6 / DFS / MS / School / 2013 / 301

DATED 18/01/13

FIRE SAFETY CERTIFICATE

Certified that the M C Primary Girls Model School located at Block A Shastri Nagar, New Delhi – 52 comprised of three blocks with ground floor only owned / occupied by M C Primary School complied with the fire prevention and fire safety requirement in accordance with Director of Education Circular dated 01.03.2011 and verified by the officer concerned of Fire Service on 23.07.2012 in the presence of Smt Shoba Vashist (Principal) and that the building / premises is fit for occupancy class Group “B” Educational Building with effect from 18/01/13 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 18/01/13 at New Delhi


12/1
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. Smt Shoba Vashist (Principal),
M C Primary School,
Shastri Nagar, New Delhi – 52
2. The Director of Education,
North MCD, Dr SPM Civic Centre,
Minto Road, New Delhi - 02

NOTE : - Guidelines overleaf may also be taken care of.

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non functional of fire safety measures, management shall be responsible.
4. Any deviation with regard to construction, electric installation etc may be got verified from the concerned authorities.
5. Basement shall be used as per NBC.
6. This NOC may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
8. The mezzanine floor shall not be used for assembly purpose.

Double Shift . 3 Blocks (GF only)

INSPECTION REPORT

1. Name & address of the building : MCP School, A-Block Shastri Nagar, ND
 2. Type of Occupancy : Edu
 3. Type of Case : New Case/ Renewal
 4. Details of previous NOC : Letter No. Dated:
 5. Fire Safety directives letter No : Dir of Edu
 6. Date of inspection : 4/10/12
 7. Name of the Inspecting Officers : ADO S S Tuli
 8. Name and designation of officers from the building side : Smt Shobha Vashist Principal
 9. Year of Construction : 1979
 10. Applicant's letter No. : NIL dtd 16/7/12
- PA - 3849 m² , CA - 2789 m² NUR - 13 NOS - 195

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<p>Accessible</p> <p>—</p> <p>—</p>	<p>Acessible</p> <p>—</p> <p>—</p>	<p>m/R</p> <p>—</p> <p>—</p>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			/
	<ul style="list-style-type: none"> • Upper Floors • Basements 			
	b. Width of staircases			/
	<ul style="list-style-type: none"> • Upper Floors • Basements 			
	c. Protection of exits			/
	<ul style="list-style-type: none"> • Fire check door • Pressurization 			
	e. No. of continuous staircases to terrace			/
	g. Width of Corridor			
	h. Door Size	1 mtr	single 1mtr	m/R
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 			/

M

5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	are @ 300 m ² ISI marked (10)	10 yes yes	m/R m/R m/R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	30 m 5 mm	N/A	
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 		N/A	
8	MOEFA			
9	Public Address System.	Regd	P	m/R
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 		N/A	
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 		N/A	
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 		N/A	
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump 		N/A	

14	Captive Water Storage for fire fighting.	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 				
15	Exit Signage.					
16	Provision of Lifts.					
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 					
17	Standby power supply					
18	Refuge Area.					
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 					
19	Fire Control Room					
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 					
20	Special Fire Protection Systems for Protection of special Risks, if any:					

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Name

Designation

DO (M/N)

Signature of the Inspecting Officer

Name

Designation

SS Tuli
ADD (M/N)

18-X-12

put up Plea.