

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/school/2013/297 Dated: 18/01/2013

**FIRE SAFETY CERTIFICATE**

Certified that the Vanasthali Public School Ghewra Nizampur Pur Main Road, Delhi located at Nizampur Delhi comprised of Ground + one upper floor occupied by Vanasthali Public School was issued NOC vide this office letter no. F.6/DFS/MS/09/1889 Dated 26/6/2009. The premises was re-inspected by the officer concerned of this department on 01/01/2013 and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore, deemed complied with the Director of Education circular Dated 01/03/2011 and the building/ premises is fit for occupancy Class Educational with effect from 18/01/2013 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 18/01/13 at New Delhi.

  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE

*etc*

Copy to:

1. The Manager, Vanasthali Public School, Ghewra Nizampur Pur Main Road, Delhi.
2. The Director (Education), Govt. of NCT of Delhi, Old Sectt., Delhi.

**Following fire safety directives must be adhered to**

1. All the Means of escape shall be kept free of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation with regards to construction, electrical installation etc. may be got verified from the concerned authorities.
5. Basement shall be used as per NBC.
6. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **[www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)**

- N/S -

**INSPECTION REPORT**

1. Name & address of the building : Vanasthali Public School, Ghevra - Nizampur Road, Nizampur, Delhi
2. Type of Occupancy : Educational (G+1) (Ground + First floor only)
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. F6/DFS/MS/09/1889 Dated: 26/6/09
5. Fire Safety directives letter No : Nil
6. Date of inspection : 04/1/2013
7. Name of the Inspecting Officers : ADO (WP) S.K. Dua
8. Name and designation of officers from the building side : Mr. Manuj jain
9. Year of Construction : 2000
10. Applicant's letter No. : Nil dated 2/12/2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06 mtr.	12 mtr.	MR
	• Gate width	4.5 mtr.	Provided	MR
	• Width of internal road	-	-	-
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	02	Provided	MR
	• Upper Floors	02	Provided	MR
	• Basements	N/A	N/A	-
	b. Width of staircases			
	• Upper Floors	Old Case	1.4 mtrs	Old case
	• Basements	N/A	N/A	-
	c. Protection of exits			
	• Fire check door	N/R	N/P	-
	• Pressurization	N/R	N/P	-
	e. No. of continuous staircases to terrace	01	02	M/R
	g. Width of Corridor	1.5 mtrs.	Provided	M/R old case
	h. Door Size	1.0 mtrs.	1.0 mtr.	M/R old case.



- M/G -

3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>			
<i>Not Required</i>				
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour 12 a/c per hour		
<i>Not Required</i>				
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	12 ISI marked ABC & CO <sub>2</sub>	12 Provided Provided	MR MR MR
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	NR 30 m 5 mm	Provided Provided Provided	MR MR MR
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>			
<i>Not Required</i>				
8	<b>MOEFA</b>	NR	NA	-
9	<b>Public Address System.</b>	NR	NA	-
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>			
<i>Not Required</i>				
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> </ul>	NR	NA	-

- M7 -

	<ul style="list-style-type: none"> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>	<del>Not Required</del>		Required
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>	<del>Not Required</del>		Required
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>• Ground Level               <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> </ul> </li> <li>• Terrace level               <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>	<del>Not Required</del>		
		NIR	450 LPM	MIR
		NR	40 MTR	MIR
		NIR	Provided	MIR
		NR	Not Provided	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity               <ul style="list-style-type: none"> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> </ul> </li> <li>• Overhead Tank capacity</li> </ul>	<del>Not Required</del>		
		NR	2000 x 2 = 4000 lbs.	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> </ul>	<del>Not Required</del>		Required

- N/S -

	<ul style="list-style-type: none"> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	<del>Not Required</del>		
17	<b>Standby power supply</b>	NR	Provided	MR
18	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	<del>Not Required</del>		
19	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>	<del>Not Required</del>		
20	Special Fire Protection Systems for Protection of special Risks, if any:	No	-	-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~

*S.K. Dua*  
09/10/2013  
Signature of the Inspecting Officer

Name *S. K. Dua*  
Designation *ADD (WP)*

Signature of the Inspecting Officer  
Name  
Designation