

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/School/2013/365 Dated: 24/01/2013


FIRE SAFETY CERTIFICATE

Certified that the Guru Tegh Bahadur Public School, is comprised of Ground floor only with 29 rooms, located at 'M' Block, (Zone c-19), Model Town-IV, Delhi-110009 have complied with the fire prevention and fire safety requirements in accordance with the Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 10/01/2013 in the presence of Sh Amarjot Singh Sethi, Secretary and that the building / premises is fit for occupancy of Group Class B (Educational) with effect from 24/01/13 for a period of three years, subject to conditions mentioned below.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 24/01/13 at New Delhi by


25/1
Chief Fire Officer
Delhi Fire Service

Copy to:

1. Sh Amarjot Singh Sethi, Secretary, Guru Tegh Bahadur Public School 'M' Block, (Zone C-19), Model Town-IV, Delhi-110009 ID 1309189.
2. The Director of Education, Old Secretariat, Delhi

INSPECTION REPORT

1. Name & address of the building : Guru Tegh Bahadur Public School, 'M' Block, Model Town IV, Delhi 110009, **ID-1309189**
 2. Type of Occupancy : Group Class B (Educational)
 3. Type of Case : New Case (**Presently Ground Floor Only**)
 4. Details of previous NOC : Nil
 5. Fire Safety directives letter No : *FG/DFS/MS/BP/2003/2529 dtd 20/X/2003*
 6. Date of inspection : 10/01/2013
 7. Name of the Inspecting Officers : Divisional Officer (NW)
 8. Name and designation of officers
from the building side : Sh Amarjot Singh Sethi, Secretary
 9. Year of Construction :
 10. Applicant's letter No. : Nil Dated 12/11/2012
- Plot Area- 4.25 acre, Covered Area-3140 sq mtr, No of class Rooms-29, No of students -772**

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	N/A	N/A	N/A
	• Upper Floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	b. Width of staircases	N/A	N/A	N/A
	• Upper Floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	c. Protection of exits	N/A	N/A	N/A
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	1 mtr	1mtr	MR
3	Compartmentation.	N/A	N/A	N/A
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A

14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15	Exit Signage.	N/A	N/A	N/A
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks. if any:	N/A	N/A	N/A

The directives were issued vide LWD F&DPS/BP/2003/2529 dtd 20/7/2003 for G+ three Storey Bldg, but the present bldg is G+ only. New bldg is under construction.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Name

Designation

Signature
14/11/13
S. Tuli

Signature of the Inspecting Officer

Name

Designation

Signature
D. P. W. 27