

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001


NO.F6/DFS/MS/ *School/2013/388*

Dated: *24/01/13*

**FIRE SAFETY CERTIFICATE**

Certified that **Kendriya Vidyalaya located at Gole market, New Delhi** owned/occupied by Kendriya Vidyalaya Sangathan and main building is comprised of ground floor plus three upper floors and adjoining Science block is comprised of ground plus one upper floor have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi fire service Rules 2010 and verified by the officer concerned of Delhi fire service on 07.01.2013 alongwith Dr. Jitender, Vice Principal and that the building/premises is fit for occupancy **class group B (Educational building)** with effect from ~~24/01/13~~ for a period of **3(three)** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ~~24/01/13~~ at New Delhi by.

  
Chief fire officer  
Delhi fire service

*g/c*  
*me*

Copy to: -

1. The Dy. Commissioner, Kendriya Vidyalaya Sangathan, (DR), JNU Campus, New Delhi
2. The Principal, Kendriya Vidyalaya, Gole market, New Delhi
3. The Directorate of Education, Old Secretariat, Delhi

Conditions for the validity of fire safety certificate

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The School Management shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

**INSPECTION REPORT**

1. Name & address of the building : Kendriya Vidyalaya, Gole Market, New Delhi-110001
2. Type of Occupancy : Educational (School)
3. Type of Case : New Case
4. Details of previous NOC : Letter No. N/A dated N/A
5. Fire Safety directives Letter No. : N/A
6. Date of inspection : 07-01-2013
7. Name of the Inspecting Officer : Sh. D.S. Yadav (D.O.)
8. Name and designation of Officer  
from the building side : Dr. Jitender (Vice Principal)
9. Year of Construction : 1981
10. Applicant's letter No. : Nil Dated 18-10-2012

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL <i>circular</i> Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	More than 6 mtrs.	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	01	03	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.50 mtrs & 0.75 mtrs.	03 nos. 130 cms. each	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	01	01	MR
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	N/A	N/A	N/A
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	Natural Ventilation	N/A
5.	Fire Extinguishers			

Kendriya Vidyalaya, Gole Market, New Delhi-110001

	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Batter backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer

Name

Designation

*Depto on leave*

*C.F.O*

Signature of the Inspecting Officer

Name

Designation

*Dharmvir Singh Yadav*  
*Divisional officer (central)*

*Pl speak*

*Yadav*  
*29-1-13*