

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[SEE SUB-RULE (1) OF RULE 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001


No. F6/DFS/MS/2013/413

Dated: 29/01/2013

**FIRE SAFETY CERTIFICATE**

Certified that the Skylark Industries Pvt. Ltd. located at B-1 Udyog Nagar Ind. Area, Peeragarhi Chowk, New Delhi. The building is comprised of basement, ground plus two upper floors, owned/occupied by Skylark Industries Pvt. Ltd., have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 12-01-2013 in the presence of Mr. Vinod Goyal (name and address of the owner or his representative) and that the building/premises is fit for **Class-G (G1) Industrial** occupancy with effect from .....29/01/13.....for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on.....29/01/13.....at New Delhi by

  
Chief Fire Officer  
Delhi Fire Service

Copy to:  
Mr. Vindo Goyal  
Skylark Industries Pvt. Ltd.  
B-1 Udyog Nagar Ind. Area, Peeragarhi Chowk, New Delhi

Note :- For general fire safety directives please over leaf.

Following fire safety directives must be adhered to:-

- 1) All the fire safety arrangement provided their in shall be maintained in good working conditions at all time.
- 2) Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock.
- 4) Any deviation, with regards to construction etc shall be verified b y the concerned building sanctioning agency.
- 5) The basement shall be used strictly as per the provision of building Bye-Laws.
- 6) This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
- 8) *The travel distance after occupation of Bldg shall not increase as mentioned in BBL 1983.*

1. Name & address of the building : Skylark Industries Pvt. Ltd. located at B-1 Udyog Nagar Ind. Area, Peeragarhi Chowk, New Delhi
2. Type of Occupancy : Class-G (G1) Industrial
3. Type of Case : New Case
4. Details of previous NOC : N/A
5. Fire Safety directives letter No. : F6/DFS/MS/BP/2009/1793 dated 17-06-09 ✓
6. Date of inspection : 23-01-2013
7. Name of the Inspecting Officers : DCFO(W), DO (W), ADO (MN) ✓
8. Name and designation of officers : Mr. Vinod Goyal
- From the building side :
9. Year of Construction : 1996-Admn. Altrn. In 2012 ✓
10. Applicant's letter No. : nil dated 17-01-2013

### INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	09mtrs	Provided. ✓	M.R
	• Gate width	5 mtr	Provided ✓	M.R ✓
	• Width of internal road	-	-	-
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	03	03 ✓	M.R.
	• Basement	03	03 ✓	M.R.
	b. Width of staircases			
	• Upper Floors	125 mtr	1.5, 1.27, 1.80 mtr ✓	M.R.
	• Basement	1.5 mtr	2.95, 1.08, 1.89 mtr ✓	M.R.

c. Protection of exits	• Fire check door	Required	Provided ✓	M.R. ✓
	• Pressurization	N.R.	With wired glass	M.R.
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	1.5 mtr	Halls only ✓	M.R.
	f. Door size	1.0 mtrs	Provided ✓	M.R.
	3.	<b>Compartmentation.</b>		
• Fire check door	Required	Provided ✓	M.R.	
	• Sealing of electrical shafts	Required	Provided ✓	M.R.
	• Fire Rating of shaft door	Required	Provided ✓	M.R.
	• Water Curtain	Required	Provided ✓	M.R.
	• Fire Dampers	Required	Provided ✓	M.R.
4.	<b>Smoke Management System.</b>			
• Basements	Required	Provided	M.R.	
	• Upper floors	Required	Provided	M.R. ✓
5.	<b>Fire Extinguishers</b>			
• Total numbers	25	35 ✓	M.R.	
	• Types	ABC & CO <sub>2</sub> type	provided	M.R. ✓
	• IS marking	required	provided	M.R.
6.	<b>First-Aid Hose Rees.</b>			
• Total numbers on each floor	2	provided ✓	M.R.	
	• Length of hose reel hose	30 m	provided ✓	M.R.

	• Nozzle diameter	5 mm	provided	M.R.
<b>7.</b>	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	Heat & smoke	Provided	M.R.
	• Location of Main Panel	On ground floor	Provided	M.R.
	• Location of Repeater Panel	On ground floor	Provided	M.R.
	• Alternate source of power	Required	Provided	M.R.
	• Hooter's Location	On each floor	Provided	M.R.
<b>8.</b>	<b>MOEFA</b>	required	Provided	M.R.
<b>9.</b>	<b>Public Address System.</b>	Required	Provided	M.R.
<b>10.</b>	<b>Automatic Sprinkler system</b>			
	• Basement	Required	Provided	M.R.
	• Upper Floor	Required	Provided	M.R.
	• Sprinkler above false ceiling	N.R.	N.A.	N.A.
<b>11.</b>	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	150 mm	Provided	M.R.
	• Number of hydrants per floor	02	Provided	M.R.
	• Hose Box	02	Provided	M.R.
<b>12.</b>	<b>Yard Hydrants.</b>			
	• Total number of hydrants	05	Provided	M.R.

	• Hose Box	05	Provided	M.R.
<b>13.</b>	<b>Pumping Arrangements.</b>			
	<b>Ground Level</b>			
	➤ Discharge of main pump	2280 LPM	Provided /	M.R.
	➤ Head of Main pump	70 mtr	Provided /	M.R.
	➤ Number of main pumps	02	Provided /	M.R.
	➤ Jockey Pump out put	180 LPM	Provided /	M.R.
	➤ Jockey pump head	70 mtr	Provided /	M.R.
	➤ Standby pump out put	2280 LPM	Provided /	M.R.
	➤ Standby pump Head	70 mtr	Provided /	M.R.
	➤ Auto Starting/Manual stopping	Required	Provided /	M.R.
	➤ Pump Hose Access	Required	Provided /	M.R.
	<b>Terrace level</b>			
	➤ Discharge of pump	900 LPM	Provided /	M.R.
	➤ Head of the pump	40 mtr	provided /	M.R.
	➤ Power supply	Required	Provided /	M.R.
	➤ Auto Starting of pump	Required	Provided /	M.R.
<b>14.</b>	<b>Captive Water Storage for fire fighting.</b>			
	<b>Underground tank capacity</b>	1,00,000 ltrs	Provided filled with water /	M.R. ✓
	➤ Draw -off connection	required	provided /	M.R.
	➤ Fire service inlet	required	provided /	M.R.

	➤ Access to tank			
		required	provided	M.R.
	➤ Overhead Tank Capacity			
		10,000 ltr	Provided	M.R.
15	Exit Signage.	required	provided	M.R. ✓
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	Lift machines are to be installed in lift wells which are closed. Pressurization is provided	Provided same ✓	M.R. ✓
	• Pressurization of Lift lobby	N.R.	N.R.	N.R.
	• Communication In lift Car	N.R.	N.R.	N.R.
	• Fireman's Grounding Switch	N.R.	N.R.	N.R.
	• Lift Signage	N.R.	N.R.	N.R.
17.	Standby power supply	Required	250 K.V.A. D.G set	M.R.
18.	Refuge Area	N.R.	N.R	N.R.
	➤ Total Area	N.R.	N.R.	N.R.
	➤ Location	N.R.	N.R.	N.R.
19.	Fire Control Room			
	➤ Detector System Panel	required	provided ✓	M.R.
	➤ Flow Switch Panel	required	provided ✓	M.R.
	➤ PA system Panel	required	provided ✓	M.R.
	➤ Batter backup	required	provided ✓	M.R.
	➤ Building Floor plans	required	provided ✓	M.R.

20.	Special Fire Protection Systems for  Protection of special Risks, if any:	N.R.	N.R.	N.R.
-----	---	------	------	------

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/

Signature of the Inspection Officer

Name Sunil Chowdhary

Designation D.O. (M.N.)

FSC 107

Signature of the Inspection Officer

Name S.K. Dua

Designation ADO (WP)