## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001.

NO F 6 / DFS / MS / 2013 / FW / 428

DATED 31/01/13

## FIRE SAFETY CERTIFICATE

- 1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2. Any loss of life or property due to non functional of fire safety measures shall be at the responsibility of the management.
- 3. The trained fire fighting staff should be available round the clock when shop is open.
- 4. Any deviation w.r.t construction etc shall be verified by concerned building sanctioning authority.
- 5. This certificate may not be treated in any case for regularization of unauthorized construction, if any.

Issued on 31 01 13 at New Delhi

Chief Fire Officer Delhi Fire Service

ou

Copy to

- 1. The Asstt Commissioner, MCD, Rohini Zone, Sec 5 Rohini, New Delhi 85 w.r.t Letter No D 417 / AC / RZ / 2011 Dated 27.02.2012
- 2. M/s Gaurav Fire Works, Shop No C-148, Rishi Nagar, Rani Bagh, Delhi 34

Grant of NOC for sale and storage of fire works (In areas other than walled city & congested areas)

> Inspection report (part -A) To be filled in by the inspecting officer

1. Name & address of the licensee

: Smt Gulshan Dhawan

2. Address of the licensed premises

: M/s Gaurav Fire Works, C-148, Rishi

Nagar, Rani Bagh, Delhi

3. License No and validity period

: DE-33/E

4. Authority by which license was issued

: Explosive department Faridabad

5. Name and designation of the officer: S.S.Tuli, Assistant Divisional Officer

6. Date and time of inspection

: Inspected on 17/10/2012

7. Period for which license is to be issued renewed and the authorized quantity

: 300 Kg Fire works and 1200 Kg Chinese

8. Recommendations of the inspecting: Recommended Officer for issue/ rejection of NOC with reason

(Signature of the inspection officer) (Assistant Divisional Officer)

Remarks of Divisional Officer

Remarks of DOFO / CEO

Orders of D.

Orders of D.

Orders of Director

Issue NOC\* / Reject

\* NOC is issued subject to condition that status quo shall be maintained and the conditions laid down under Indian Explosive rules 1983/ conditions laid down by MCD/ Police are complied with.

> Director Delhi Fire Service

## INSPECTION PROFORMA

S. No.		Remarks
1.	Construction features	-
	1. Minimum floor area 9 mtr and maximum floor area 25	Complied
	sq mtr.  2. Premises not allowed under staircase/means of exit.	Complied
	3. Business permissible only at ground floor.	On GF only
	4. The licensed premises shall have independent entrance and exit.	Provided
	5. The premises in which fire work is kept shall be used only for possession and sale of fire works and shall not be used for other purpose.	Presently used for possession and sale of fire works
	6. The shop shall be pucca construction.	Pucca construction
	7. The premise shall be situated at a distance of 15 mtr from any such premises used for similar explosives/inflammable or hazardous materials.	Presently there is no such premises
	8. Extension of premises is prohibited	There is no extension provided at present.
2.	Approach Road (a minimum of 09 meter wide road is reqd.)	Complied being old case
3.	Type of Electric wiring and electrical fitting.	Provided
	1. Electrical wiring in conduit.	Tiovided
	2. Provision of ELCB / MCB / FUSES.	Provided
4.	Fire protection arrangements:	
	a. Fire extinguishers are ISI marked viz.	
	1. Water CO2 {9 ltrs capacity}	Provided
	2. DCP Extinguisher 5 Kgs capacity	Provided
	b. Minimum two sand and two water buckets	Provided

2171

Bugh 17/4/12