

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No. F6/DFS/MS/School/2013/ 425

Dated: 31/01/13

FIRE SAFETY CERTIFICATE

Certified that the **New Way Public School, R-786/7, Veer Abdul Hameed Joga Bai Extn, Okhla, New Delhi**, comprised of ground floor only **Owned/Occupied** by New Way Public School was granted NOC by this department vide letter No.F.6/DFS/MS/2009/1518 DT 28/05/2009. The school building was re-inspected by officer concerned of Delhi Fire Service on 15/01/2013 in the presence of Sh. Rizwan Ahmed, Director of the school and observed that fire safety norms as required under rule 33 of Delhi Fire Service Rules, 2010 are deemed complied and that the building / premises is fit for occupancy class-B "**Educational building**" with effect from 31/01/13 for a period of THREE years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010.

Issued on 31/01/13 at New Delhi by


CHIEF FIRE OFFICER
DELHI FIRE SERVICE

gk
m

Copy To: -

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.
2. The Director, New Way Public School,
R-786/7, Veer Abdul Hameed Joga Bai Extn, Okhla, New Delhi

Conditions for the validity of fire safety Certificate

1. All the Fire Safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning Authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The Basement shall be used strictly as per the provisions of Building Bye Laws.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : New Way Public School,
: R-786/7, Veer Abdul Hameed
: Doga Bai Estn., Okhla, New Delhi- 25
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : FG/DFS/MS/2009/1518 Dt. 28/05/2009
5. Fire Safety Directives letter No : Nil Dt. _____
6. Date of Inspection : 15/01/2013
7. Name of the Inspecting Officer : Rajan Wadehra, ADO/M.Ed.
8. Name and designation of the Officers from the building side : Mr. Rizwan Ahmed, Director
9. Year of Construction : 2004 (Ground floor only)
10. Applicant's letter No : NWPS/12/2012 dt 07/12/2012

S. No.	Minimum Standards on Fire Prevention and Fire Safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	6.5 mts	MR
	• Gate width	5.0 mts	5.0 mts	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	• Number of Staircase	NA		
	➤ Upper floors	NA		
	➤ Basement			
	• Width of Staircase	NA		
	➤ Upper floors	NA		
	➤ Basement			
	Protection of Exits	NA		
	➤ Upper floors	NA		
	➤ Basement			
	• No of Continuous Staircases to terrace	NA	NA	NA
	• Width of Corridor	NA	NA	NA
	• Door Size / Width	1.0 mts	1.0 mts	MR

3	Compartmentation	NA		
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 	/	/	/
4	Smoke Management System	NA		
	<ul style="list-style-type: none"> • Basements • Upper Floors 	/	/	/
5	Fire Extinguishers	NA		
	<ul style="list-style-type: none"> • Total Number • Types • IS marking 	071 / 300 m ² ABC / CO2 ISI mark	04 3ABC, 1CO2 Yes	MR MR MR
6	First-Aid Hose Reels	NA		
	<ul style="list-style-type: none"> • Total Number on each floor • Length of hose reel hose • Nozzle diameter 	/Per Floor 30 m 5mm	/	/
7	Automatic Fire Detection and Alarming System	NA		
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooter's Location 	/	/	/
8	MOEFA	NA		
9	Public Address System	NA		
10	Automatic Sprinkler System	NA		
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	/	/	/
11	Internal Hydrant	NA		
	<ul style="list-style-type: none"> • Size of riser/down comer • Number of hydrants per floor • Hose Box 	/	/	/
12	Yard Hydrant	NA		
	<ul style="list-style-type: none"> • Total Number of hydrants • Hose Box 	/	/	/

13	Pumping Arrangements	NA		
	Ground Level			
	➤ Number of main pump			
	➤ Discharge of main pump			
	➤ Head of main pump			
	➤ Jockey pump out put			
	➤ Jockey pump Head			
	➤ Standby pump out put			
	➤ Standby Pump Head			
	➤ Auto Starting/Manual stopping			
	➤ Pump House Access			
	Terrace level			
	➤ Discharge of pump			
	➤ Head of the pump			
	➤ Power Supply			
	➤ Auto starting /Manual stopping			
14	Captive Water Storage for Fire Fighting	NA		
	• Underground tank capacity			
	➤ Draw-off connection			
	➤ Fire service inlet			
	➤ Access to tank			
	• Overhead tank capacity			
15	Exit Signage			
16	Provision of Lifts	NA		
	• Pressurization of Lift Shaft			
	• Pressurization of Lift lobby			
	• Communication in lift Car			
	• Fireman's Grounding Switch			
	• Lift Signage			
17	Standby Power Supply	NA		
18	Refuge Area	NA		
	• Total Area			
	• Location			
19	Fire Control Room	NA		
	• Detector System Panel			
	• Flow Switch Panel			
	• PA System Panel			
	• Battery back up			
	• Building Floor Plans			

20	Special Fire Protection System for Protection of special risk, if any	NA	NA	NA
----	---	----	----	----

The Fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules , It is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / ~~issue shortcomings as noted at~~ serial Number..... ~~.....~~ X ~~.....~~



Signature of Inspecting Officer
Name : RAJAN WADEHRA
Designation: A. D. O. (M.Rd.)