

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No.

F.6/DFS/MS/school/2013/417

Dated: 30/01/2013

FIRE SAFETY CERTIFICATE

Certified that the St. Martin's Public School located at A-2, Paschim Vihar, New Delhi comprised of Ground + Three upper floors occupied by St. Martin's Public School was issued NOC vide this office letter no. F.6/DFS/MS/09/349 Dated 05/2/2009. The premises was re-inspected by the officers concerned of this department on 24/01/2013 and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore, deemed complied with the Director of Education circular Dated 01/03/2011 and the building/ premises is fit for occupancy Class Educational with effect from 30/01/2013 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 30/01/13 at New Delhi.


CHIEF FIRE OFFICER
DELHI FIRE SERVICE



Copy to:

1. The Chair Person, St. Martin's Public School, A-2, Paschim Vihar, New Delhi.
2. The Director (Education), Govt. of NCT of Delhi, Old Sectt. Delhi.

P.T.O

Following fire safety directives must be adhered to

1. All the Means of escape shall be kept free of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation with regards to construction, electrical installation etc. may be got verified from the concerned authorities.
5. Basement shall be used as per NBC.
6. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **www.dfs.delhigovt.nic.in**

- M/S -

INSPECTION REPORT

1. Name & address of the building : St. Martin's Public School
2. Type of Occupancy : Educational
3. Type of Case : New Case/ Renewal ✓
4. Details of previous NOC : Letter No. F-6/DFS/MS/09/349 Dated: 05/02/2009
5. Fire Safety directives letter No : -
6. Date of inspection : 24/1/2013
7. Name of the Inspecting Officers : ADO (WP)
8. Name and designation of officers from the building side : Mr. Upender Kumar, Caretaker
9. Year of Construction : 2005
10. Applicant's letter No. : SMPS/8743/01/2013 dt: 19/1/2013

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6 mtr.	Provided	MR
	• Gate width	4.5 mtr	Provided	MR
	• Width of internal road	NR	N/A	-
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	3	3	MR
	• Upper Floors	3	3	MR
	• Basements	N/A	-	-
	b. Width of staircases			
	• Upper Floors	old case	⊗ Provided (3)	MR
	• Basements	N/A	-	-
	c. Protection of exits			
	• Fire check door	NR	NP	-
	• Pressurization	NR	NP	-
	e. No. of continuous staircases to terrace	03	03	MR
	g. Width of Corridor	1.5 mtr.	Provided	MR
	h. Door Size	1.0 mtr.	Provided	MR

⊗ Three No. of Staircases have been provided. width is as = 1) 1.70 mts. 2) 1.48 mts. 3) 1.32 mts. } As

< N/6 -

M

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NI		
Not Required				
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	NI/R Open to sky	- MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	16 ABC Step & CO ₂ Step. ISI marked	18 Provided Provided	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	02 30 m 5 mm	Provided Provided Provided	MR MR MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 			
Not Required				
8	MOEFA	NR	NP	-
9	Public Address System.	NR	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 			
Not Required				
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	100 mm	Provided	MR

	<ul style="list-style-type: none"> Number of hydrants per floor Hose Box 	02	Provided	MR
		02	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	05	Provided	MR
		05	Provided	MR
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 			
			Not Required	
		450 LPM	Provided	MR
		180 LPM	Provided	MR
		40 mtr.	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	-	-	-
		Required	Provided	MR
		Required	Provided	MR
		-	-	-
		5,000 lbs.	10,000 lbs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby 			
			Not Required	

- N/S -

	<ul style="list-style-type: none"> • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			
17	Standby power supply		Not Required	MR
18	Refuge Area.			
	➤ Total Area		Not Required	
	➤ Location			
19	Fire Control Room			
	• Detector System Panel	NR	NP	-
	• Flow Switch Panel	NR	NP	-
	• PA System Panel	Required	Provided	MR
	• Batter backup	Required	Provided	MR
	• Building Floor Plans	NR	NP	-
20	Special Fire Protection Systems for Protection of special Risks, if any:	No	-	-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers~~.....

[Handwritten Signature]

Signature of the Inspecting Officer

Name S. K. Dua

Designation ADO (WP)

Signature of the Inspecting Officer

Name

Designation