


NO. F6/DFS/MS/School/2013 / 530

Dated: 08/02/13

FIRE SAFETY CERTIFICATE

Certified that **Govt. Boys Secondary School, Sarai Kale Khan, New Delhi**, comprised of ground only **Owned/occupied** by Govt. Boys Secondary School have complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No. F-16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 and verified by the officers concerned of Fire Service on 12.12.2012 in the presence of Mr. Subhash Singh, Vice Principal of the school and that the building is fit for occupancy class B "Educational building" with effect from 08/02/13 for a period of **Three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 08/02/13 at New Delhi by


Chief Fire Officer
Delhi Fire Service
e/cv

Copy to,

1. The Director, Education, G. N.C.T Delhi, Old Secretariat, New Delhi
2. The Principal Govt. Boys Secondary School, Sarai Kale Khan, New Delhi

Conditions for the validity of fire safety certificate

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The basement shall be used strictly as per the provisions of Building Bye laws.
- e. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules-2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name and address of the building : GOVT. BOYS SECONDARY SCHOOL,
: SARAI KALE KHAN, NEW DELHI-110013
2. Type of Occupancy : Class- B "EDUCATIONAL"
3. Type of Case : New
4. Details of previous NOC : NIL
5. Fire Safety directives letter No : Directorate of Education Circular Dt: 01/03/2011
6. Date of Inspection : 12/12/2012
7. Name of the Inspecting Officers : Rajan Wadehra, ADO/M.Rd
8. Name and Designation of
Officers From the building side : Sh. Subhash Singh, Vice-Principal
9. Year of Construction : 1970, (Ground floor only)
10. Applicants letter No : NIL

S.No.	Minimum Standards on Fire Prevention and Fire Safety U/R 33	D o E cir 01.03.11	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	9 Mtrs	MR
	• Gate width	NR	5 Mtrs	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	• Number of staircase			
	➤ Upper Floors	NA	NA	NA
	➤ Basements	NA	NA	NA
	• Width of Staircases			
	➤ Upper Floors	NA	NA	NA
	➤ Basements	NA	NA	NA
	• Protection of exits			
	➤ Fire check door	NA	NA	NA
	➤ Pressurization	NA	NA	NA
	• No. of continuous staircases to terrace	NA	NA	NA
	• Width of Corridor	NA	NA	NA
	• Door width/Size	1.0 Mtrs	1.0 Mtrs	MR
3	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire rating of shaft door	NA	NA	NA
	• Water curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System			
	• Basements	NA	NA	NA
	• Upper Floors	NA	NA	NA
5	Fire Extinguishers			

N/2

7/2

	<ul style="list-style-type: none"> Total Number Types IS marking 	01/300m2	4 NOS	MR
		ABC/CO2	ABC	MR
		ISI mark	YES	MR
6	Firs-Aid Hose Reels			
	<ul style="list-style-type: none"> Total Number on each floor Length of hose reel hose Nozzle diameter 	NA	NA	NA
		30 m	NA	NA
		5mm	NA	NA
7	Automatic Fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	MOEFA	NA	PROVIDED	MR
9	Public Address System	NA	NA	NA
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down comer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12	Yard Hydrants			
	<ul style="list-style-type: none"> Total Number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Number of main pump Discharge of main pump Head of main pump Jockey pump out put Jockey pump Head Standby pump out put Standby Pump Head Auto Starting/Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto starting /Manual stopping 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14	Captive Water Storage for Fire Fighting			

N/3


	<ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
15	Exit Signage	NA	NA	NA
16	Provision of Lifts			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication in lift Car • Fireman's Grounding Switch • Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17	Standby Power Supply	NA	NA	NA
18	Refuge Area			
	<ul style="list-style-type: none"> • Total Area • Location 	NA	NA	NA
		NA	NA	NA
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery back up • Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20	Special Fire Protection System for Protection of special risk, if any	NA	NA	NA


The Fire protection systems provided in the building were checked and found functional / ~~non-~~ functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules , It is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial number.....

Accordingly, DFA/FT letter is put up for signature, if approved please.

DOCS


21/12/12



Signature of Inspecting Officer
Name: RAJAN WADEHRA
Designation: ADO (M.Rd.)