

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[SEE SUB-RULE (1) OF RULE -35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001


No F6/DFS/MS/EH/2013/521

Dated: 07/02/13

**FIRE SAFETY CERTIFICATE**

Certified that the **M/s My Café And Lounge** located on G.F and F.F. of four storied building located at F-89, Vishal Enclave, Rajouri Garden, New Delhi-110027, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of Fire Service on **05-11-2012** in the presence of **Mr. Aman** of the Restaurant and that the building/premises is fit for occupancy **Class-D (Assembly)** with effect from 07/02/13 for a period of three years in accordance with rule 36 unless under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 07/02/13 at New Delhi by

  
Chief Fire Officer  
Delhi Fire Service

o/c dm

Copy to:

The Director

M/s My Café and Lounge

F-89 Vishal Enclave, Rajouri Garden, New Delhi-110027

Note:- for general fire safety directives please over leaf.

Following fire safety directives must be adhered to:

1. All the fire safety arrangements provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation, with regard to construction etc. Shall be verified by the concerned building sanctioning agency.
5. Basement shall be used strictly as per the provisions of Building Bye Laws.
6. This certificate cannot be treated in any case for regularisation of unauthorised construction, Unauthorised use of land if any.
7. The owner/ occupier shall submit a declaration every year in form K provided in the first schedule of Delhi Fire Service Rule 2010. This is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

2/11

May Kindly peruse letter no. nil dated 03/10/2012 received from the Director, My Café regarding issue of NOC in favor of their M/s My Café And Lounge located at F-89 Vishal Enclave Rajouri Garden, New Delhi-110027. The premise was inspected by the undersigned from fire safety point of view & the status is put up below on prescribed Performa.

- 1. Name & address of the building : M/s **My Café And Lounge** located at F-89 Vishal Enclave Rajouri Garden, New Delhi-110027.
- 2. Type of Occupancy : Class-D (Assembly)
- 3. Type of Case : New
- 4. Details of previous NOC : N.A.
- 5. Fire Safety directives letter No. : N.A.
- 6. Date of inspection : 05.11.2012
- 7. Name of the Inspecting Officers : D.O. Sunil Chawdhary
- 8. Name and designation of officers  
From the building side : Sh. Aman
- 9. Year of Construction : 2002-2003
- 10. Applicant's letter No. : nil date 03/10/2012

**INSPECTION REPORT**

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	06 mtrs	12 mtr ✓	M/R
	• Gate width	4.5 mtr	Provided ✓	M/R
	• Width of internal road	As per sanction plan	Provided ✓	M/R
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	2	2 ✓	M.R
	• Basement	N.A.	N.A. ✓	N.A.



2/12

	b. Width of staircases			
	• Upper Floors	1.5 mtr & 1.25 mtr	Provided ✓	M.R. ✓
	• Basement	N.A.	N.A.	N.A. ✓
	c. Protection of exits			
	• Fire check door	N.R.	N.R.	N.R. ✓
	• Pressurization	N.R.	N.R.	N.R.
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	Required	Halls only ✓	M.R. ✓
	f. Door size	2 mtrs	Provided ✓	M.R.
3.	<b>Compartmentation.</b>			
	• Fire check door	N.R.	N.R.	N.R.
	• Sealing of electrical shafts	N.R.	N.R.	N.R.
	• Fire Rating of shaft door	N.R.	N.R.	N.R.
	• Water Curtain	N.R.	N.R.	N.R.
	• Fire Dampers	N.R.	N.R.	N.R.
4.	<b>Smoke Management System.</b>			
	• Basements	N.A	N.A	N.A.
	• Upper floors	Required	Provided ✓	M.R. ✓
5.	<b>Fire Extinguishers</b>			
	• Total numbers	10 for the restaurant	15 ✓	M.R. ✓
	• Types	DCP & CO <sub>2</sub> Required	provided ✓	M.R. ✓
	• IS marking	required	provided ✓	M.R. ✓

<b>6.</b>	<b>First-Aid Hose Rees.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	1	Provided ✓	M.R.
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30 m required	Provided ✓	M.R.
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	5 mm required	provided ✓	M.R.
<b>7.</b>	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	Required	Provided ✓	MR.
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	Ground Floor	Provided ✓	MR.
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	At each Floor	Provided ✓	MR.
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	Required	Provided ✓	MR.
	<ul style="list-style-type: none"> <li>Hooter's Location</li> </ul>	Required	Provided ✓	MR.
<b>8.</b>	<b>MOEFA</b>	Required	Provided ✓	M.R.
<b>9.</b>	<b>Public Address System.</b>	N.R.	N.R.	N.R.
<b>10.</b>	<b>Automatic Sprinkler system</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N.A.	N.R.	N.R.
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	Required.	Provided. ✓	M.R.
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	N.R.	N.R.	N.R.
<b>11.</b>	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	100 mm	Provided ✓	M.R.
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	1	Provided ✓	M.R.
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	1	Provided ✓	M.R.

2/14

<b>12.</b>	<b>Yard Hydrants.</b>			
	• Total number of hydrants	N.R.	N.R.	N.R.
	• Hose Box	N.R.	N.R.	N.R.
<b>13.</b>	<b>Pumping Arrangements.</b>			
	<b>Ground Level</b>			
	➤ Discharge of main pump	2280 LPM.	Provided. ✓	M.R.
	➤ Head of Main pump	40 mtr..	Provided. ✓	M.R.
	➤ Number of main pumps	2(two).	Provided. ✓	MR
	➤ Jockey Pump out put	180 LPM.	Provided. ✓	MR
	➤ Jockey pump head	40 mtr..	Provided. ✓	MR
	➤ Standby pump out put	2280 LPM.	Provided. ✓	MR
	➤ Standby pump Head	40 mtr..	Provided. ✓	M.R.
	➤ Auto Starting/Manual stopping	Required.	Provided. ✓	M.R.
	➤ Pump Hose Access	Required.	Provided. ✓	M.R.
	<b>Terrace level</b>			
	➤ Discharge of pump	900 LPM	Provided ✓	M.R.
	➤ Head of the pump	30 mtr	Provided ✓	M.R.
	➤ Power supply	Required	Provided ✓	M.R.
	➤ Auto Starting of pump	Required	Provided ✓	M.R.
<b>14.</b>	<b>Captive Water Storage for fire fighting.</b>			
	<b>Underground tank capacity</b>	50,000 ltr..	Provided at terrace. ✓	MR



	➤ Draw-off connection	Not Required N.R.	Not Provided N.R.	N.R.
	➤ Fire service inlet	Not Required	Not Provided	MR
	➤ Access to tank	Not Required	Not Provided	M.R.
	➤ Overhead Tank Capacity	10,000 ltrs	Provided	M.R.
15	<b>Exit Signage.</b>	Required	Provided	M.R.
16.	<b>Provision of Lifts</b>			
	• Pressurization of Lift Shaft	N.R.	N.R.	N.R.
	• Pressurization of Lift lobby	N.R.	N.R.	N.R.
	• Communication In lift Car	N.R.	N.R.	N.R.
	• Fireman's Grounding Switch	N.R.	N.R.	N.R.
	• Lift Signage	N.R.	N.R.	N.R.
17.	<b>Standby power supply</b>	Required	Provided	M.R.
18.	<b>Refuge Area</b>	N.R.	N.R.	N.R.
	➤ Total Area	N.R.	N.R.	N.R.
	➤ Location	N.R.	N.R.	N.R.
19.	<b>Fire Control Room</b>			
	➤ Detector System Panel	N.R.	N.R.	N.R.
	➤ Flow Switch Panel	N.R.	N.R.	N.R.
	➤ PA system Panel	N.R.	N.R.	N.R.
	➤ Batter backup	N.R.	N.R.	N.R.
	➤ Building Floor plans	N.R.	N.R.	N.R.

2/15  
dh

dh

dh  
dh  
dh

2/16

20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R.	N.R.	N.R.
-----	---	------	------	------

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/



Signature of the Inspection Officer

Signature of the Inspection Officer

Name Sunil Chowdhary

Name

Designation D.O. (MN)

Designation