

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/2013/school/551.

Dated: 08/02/2013

FIRE SAFETY CERTIFICATE

Certified that the Happy English School, Sharad Vihar, Karkardooma, Delhi -92, comprised of ground plus two upper floors was granted NOC by this department vide Letter No-F6/MS/DFS/06/2539 dated 15.09.06. School building was re-inspected by the officer concerned of this department on 18.01.13 in the presence of Mrs. Arti Khungar, Principal of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy Group B "Educational Building" with effect from 8/2/13.... renewed for a period of three years, subject to conditions printed overleaf.

Issued on..... 8/2/13..... at New Delhi by


Chief Fire Officer
Delhi Fire Service


8/2/13

To,

The Principal
Happy English School,
Sharad Vihar, Karkardooma, Delhi -92.

Copy to:-

The Joint Director of Education
(Land & Estate)
Directorate of Education,
Lucknow Road, Delhi -54.

CONDITIONS:

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Happy English School, Sharad Vihar, Karkardooma, Delhi -92.
2. Building is comprised of : G+2
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : Letter No- F6/MS/DFS/06/2539 Dated 15.09.06
6. Fire Safety direction letter No : Delhi Fire Service Act, 2007 and Rules 2010.
7. Date of Inspection : 18.01.13
8. Name of the Inspecting Officers: : Suresh singh (ADO)
9. Name of the designation of Officer
from the building side : Mrs. Arti Khungar, Principal
10. Year of Construction : 1990
11. Applicant's letter No : HES/2012/NOC dated 12.12.12

S.No	Minimum Standards on fire prevention and fire safety U/R33	Old Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	12 m	Old Accepted
	Gate width
	Width of internal road
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	2 no.	2 no.	Old Accepted
	Upper Floor	2 no.	2 no.	Old Accepted
	Basement
	B. Width of Staircases	1.2 m each	Old Accepted
	Upper Floor	1.2 m	Old Accepted
	Basement
	c. Protection of exits
	Fire check door
	Pressurization
	e. No. of continuous staircases to terrace	01 no.	01 no.	Old Accepted
g. Width of Corridor	1.5 m	3 m	Old Accepted	
h. Door Size	1 m	1 m	Old Accepted	
3	Compartmentation.	Required	Provided	
	Fire check door
	Sealing of electrical shafts
	Fire rating of shaft door
	Water curtain
	Fire Dampers
4	Smoke Management System.	Ventilated		
	Basement	30a/c per hour
	Upper floor	12 a/c per hour

5.	Fire Extinguisher	Required	Provided	
	Total numbers	11 no.	11 no.	Old Accepted
	types	Co2 & ABC	Co2 & ABC	Old Accepted
	IS marking	ISI marked	ISI marked	Old Accepted
6	First-aid-Hose Reels.			
	Total numbers of each floor	01 no.	Old Accepted
	Length of hose reel hose	30 m	Old Accepted
	Nozzle diameter	5 mm	Old Accepted
7	Automatic fire detection and alarming system. N/A			
	Type of detectors
	Location of main panel
	Location of repeater panel
	Alternate source of power
	Hooters's location
8	MOEFA	Yes
9	Public address System.	Yes
10	Automatic Sprinkler System.	N/A		
	basement
	upper floor
	sprinkler above false ceiling
11	Internal Hydrants	N/A		
	size of riser/down-comer
	Number of hydrants per floor
	Hose Box
12	Yard Hydrants.	N/A		
	Total number of hydrants
	Hose Box
13	Pumping Arrangements.	Required	Provided	
	• Ground Level
	➤ Discharge of main Pump
	➤ Head of Main Pump
	➤ Number of main pumps
	➤ Jockey pump out put
	➤ Jockey pump head
	➤ Standby pump out put
	➤ Standby pump Head
	➤ Auto Starting /Manual stopping
	➤ Pump House Access
	• Terrace Level
	➤ Discharge of pump	450 LPM	Old Accepted
	➤ Head of the Pump	40 m	Old Accepted
	➤ Power supply
	➤ Auto Starting of pump

IRN/5

Happy English School, Sharad Vihar, Karkardooma, Delhi -92.

14	Captive Water Storage for Fire Fighting.	Required	Provided	
	Underground tank capacity
	Draw-off connection
	Fire service inlet
	Access to tank
	Overhead Tank capacity	5,000 Liters	Old Accepted
15	Exit Signage.	Required	Provided	Old Accepted
16	Provision of Lifts.	N/A		
	Pressurization of Lift Shaft
	Pressurization of Lift lobby
	Communication in lift car
	Firemen's grounding switch
	Lift Signage
17	Standby power supply	N/A
18	Refuge Area.	N/A		
	Total area
	Location
19	Fire Control Room	N/A		
	Detector system panel
	Flow switch panel
	PA system panel
	Batter backup
	Building Floor Plans
20	Special Fire Protection systems for protection of special Risks, if any:	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the Rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Singh

Signature of the Inspecting Officer

Name Suresh SinghDesignation ADODo (East)Submitted for approval please.Khudi