

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No F6/DFS/MS/2013/ *Motel / 623*

Dated:.. *13/2/13*...

**FIRE SAFETY CERTIFICATE**

Certified that the **Fortune Park(A unit of penguin Farms Pvt. Ltd.)** located <sup>at</sup> **Khasra No. 421,422,423, Main Village Ghitorni, New Delhi**, comprised of Basement & Ground Floor Only was granted NOC by this department vide letter No. F6/MS/DFS/GH/2010/761 dated 12/03/2010. Re-inspection was carried out by the officer concerned of this department on 28/01/13 in presence of **Mr. Dev Dutt (Chief Engineer)** and found that the said Motel have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and the building/premises is fit for occupancy **Class-D Assembly Building** with effect from - *13/2/13*----- for a period of three years in accordance with rule 36 unless under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on *13/2/13* at New Delhi by

  
Chief Fire Officer  
Delhi Fire Service

Copy to: - (1) The Executive Engineer (Bldg.)-II, South Zone,  
MCD, Bldg. Department, South Zone, Green Park, New Delhi.  
(2) Additional CP (licensing), 1<sup>st</sup> floor, P.S. Defense Colony, ND.  
(3) Fortune Park, (A unit of Penguin farms Pvt. Ltd.)  
Khasra No. 421,422,423, Main Village, Ghitorni, New Delhi.

Following fire safety directives must be adhered to:

1. All the fire safety arrangements provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation, with regard to construction etc. Shall be verified by the concerned building sanctioning agency.
5. Basement shall be used strictly as per the provisions of Building Bye Laws.
6. This certificate cannot be treated in any case for regularisation of unauthorised construction, Unauthorised use of land if any.
7. The owner/ occupier shall submit a declaration every year in form K provided in the first schedule of Delhi Fire Service Rule 2010. This is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. In case of the temporary structure is erected the party should apply separately to this department.

- 2/4 -

INSPECTION REPORT

1. Name & address of the building:- Fortune Park, Khasra No. 421,422,423, Main Village Ghitorni, New Delhi.
2. Type of occupancy:- Group – D Assembly Building
3. Type of case:- Renewal
4. Details of previous NOC:- No. F6/MS/DFS/GH/2010/761 dated 12/03/10
5. Fire safety directives No.- No
6. Date of inspection:- 28/01/13.
7. Name of the inspecting officer:- A.D.O. S.S. Kaushik
8. Name & designation of officer  
From the building side:- Mr. Dev Dutt (Chief Engineer)
9. Year of construction:- 1991.
10. Applicant's letter No:-70091/Addl.C.P./Lic.(H) dated 12/12/12 Basement & Ground Floor only

Farm House Old Case

| S.No.     | Minimum Standards on fire Prevention and fire safety U/R 33 | Requirement     | Provided at site      | Remarks MR/NMR |
|-----------|---|-----------------|-----------------------|----------------|
| <b>1.</b> | <b>Access to Building</b>                                   |                 |                       |                |
|           | 1) Road width   | 12 mtr.         | Provided              | MR             |
|           | 2) Gate width   | Required        | 5 mtr.                | MR             |
|           | 3) Width of internal road                                   | N/A             | N/A                   | N/A            |
| <b>2.</b> | <b>Number, Width Type &amp; Arrangement of Exits</b>        |                 |                       |                |
|           | A. Number of staircases                                     |                 |                       |                |
|           | 1. Upper floors   | N/A             | N/A                   | N/A            |
|           | 2. Basements  | Required        | 2 Nos.                | MR             |
|           | B. Width of staircase                                       |                 |                       |                |
|           | 1. Upper floors   | N/A             | N/A                   | N/A            |
|           | 2. Basements  | Required        | 1.50 mtr. & 1.17 mtr. | MR             |
|           | C. Protection of exits                                      |                 |                       |                |
|           | 1. Fire check door  | N/A             | N/A                   | N/A            |
|           | 2. Pressurization   | N/A             | N/A                   | N/A            |
|           | D. No. of continuous staircase to terrace                   | Required        | 2 Nos.                | MR             |
|           | E. Width of corridor  | N/A             | N/A                   | N/A            |
|           | F. Door size  | Required        | 1 mtr.                | MR             |
| <b>3.</b> | <b>Compartmentation</b>                                     |                 |                       |                |
|           | 1) Fire check door  | Yes             | Provided              | MR             |
|           | 2) Sealing of electrical shafts                             | N/A             | N/A                   | N/A            |
|           | 3) Fire rating of shaft door                                | N/A             | N/A                   | N/A            |
|           | 4) Water curtain  | N/A             | N/A                   | N/A            |
|           | 5) Fire Dampers   | N/A             | N/A                   | N/A            |
| <b>4.</b> | <b>Smoke Management System</b>                              |                 |                       |                |
|           | 1) Basements  | 30 a/c per hour | Exhaust fan           | MR             |
|           | 2) Upper floors   | 12 a/c per hour | Exhaust fan           | MR             |
| <b>5.</b> | <b>Fire Extinguishers</b>                                   |                 |                       |                |
|           | 1) Total numbers  | ISI Marked      | 60 Nos.               | MR             |
|           | 2) Types  |                 | ABC, Co2 & W.Co2      | MR             |

M/S-

|            |   |                   |                     |     |
|------------|---|-------------------|---------------------|-----|
|            | 3) ISI marking  |                   | Yes                 | MR  |
| <b>6.</b>  | <b>First-Aid Hose Reel</b>                            |                   |                     |     |
|            | 1) Total number                                       | 3 Nos.            | 3 Nos.              | MR  |
|            | 2) Length of hose reel hose                           | 30 m              | Yes                 | MR  |
|            | 3) Nozzle diameter                                    | 5 mm              | Yes                 | MR  |
| <b>7.</b>  | <b>Automatic Fire Detection &amp; Alarming System</b> |                   |                     |     |
|            | 1) Type of detectors                                  | Required<br>Smoke | Smoke               | MR  |
|            | 2) Location of main panel                             | Required          | Basement            | MR  |
|            | 3) Location of repeater panel                         | N/A               | N/A                 | N/A |
|            | 4) Alternate source of power                          | Required          | Yes                 | MR  |
|            | 5) Hooter's Location                                  | Required          | Near every exit     | MR  |
| <b>8.</b>  | <b>MOEFA</b>  | Required          | Provided            | MR  |
| <b>9.</b>  | <b>Public Address System</b>                          | Required          | Provided            | MR  |
| <b>10.</b> | <b>Automatic Sprinkler System</b>                     |                   |                     |     |
|            | 1) Basement   | Required          | Provided            | MR  |
|            | 2) Upper floors                                       | Required          | Provided            | MR  |
|            | 3) Sprinkler above false ceiling                      | N/A               | N/A                 | N/A |
| <b>11.</b> | <b>Internal Hydrants</b>                              |                   |                     |     |
|            | 1) Size of riser/down-comer                           | Required          | 150 mm<br>Provided  | MR  |
|            | 2) Number of hydrants per floor                       | 3 Nos.            | 3 Nos.              | MR  |
|            | 3) Hose box   | 3 Nos.            | 3 Nos.              | MR  |
| <b>12.</b> | <b>Yard Hydrants</b>                                  |                   |                     |     |
|            | 1) Total number of hydrants                           | Required          | 12 Nos.<br>Provided | MR  |
|            | 2) Hose box   | Required          | 12 Nos.<br>Provided | MR  |
| <b>13.</b> | <b>Pumping Arrangement</b>                            |                   |                     |     |
|            | 1) Ground level                                       |                   |                     |     |
|            | a) Discharge of main pump                             | 1620 LPM          | 1620 LPM            | MR  |
|            | b) Head of main pump                                  | 40 mtr.           | 40 mtr.             | MR  |
|            | c) Number of main pump                                | One               | One                 | MR  |
|            | d) Jockey pump out put                                | 180 LPM           | 180 LPM             | MR  |
|            | e) Jockey pump head                                   | 40 mtr.           | 40 mtr.             | MR  |
|            | f) Stand by pump output                               | 1620 LPM          | 1620 LPM            | MR  |
|            | g) Stand by pump head                                 | 40 mtr.           | 40 mtr.             | MR  |
|            | h) Auto starting/Manual stopping                      | N/A               | N/A                 | N/A |
|            | 2) Terrace level                                      |                   |                     |     |
|            | a) Discharge of pump                                  | N/A               | N/A                 | N/A |
|            | b) Head of pump                                       | N/A               | N/A                 | N/A |
|            | c) Power supply                                       | N/A               | N/A                 | N/A |
|            | d) Auto starting of pump                              | N/A               | N/A                 | N/A |
| <b>14.</b> | <b>Captive Water Storage for Fire Fighting</b>        |                   |                     |     |
|            | 1) Under ground tank capacity                         | N/A               | 1,00,000 ltrs.      | MR  |
|            | a) Draw-off connection                                | Required          | Provided            | MR  |
|            | b) Fire service inlet                                 | Required          | Provided            | MR  |
|            | c) Access to tank                                     | Required          | Provided            | MR  |
|            | d) Over head tank capacity                            | 10,000 ltrs.      | 10,000 ltrs.        | MR  |

M/G

|     |                                 |          |          |     |
|-----|---------------------------------|----------|----------|-----|
| 15. | <b>Exit Signage.</b>            | Required | Provided | MR  |
| 16. | <b>Provision of Lifts.</b>      |          |          |     |
|     | a) Pressurization of lift shaft | N/A      | N/A      | N/A |
|     | b) Pressurization of lift lobby | N/A      | N/A      | N/A |
|     | c) Communication in lift car    | N/A      | N/A      | N/A |
|     | d) Fireman's switch             | N/A      | N/A      | N/A |

|     |   |          |              |     |
|-----|---|----------|--------------|-----|
|     | e) Lift signage   | N/A      | N/A          | N/A |
| 17. | <b>Stand by Power Supply</b>  | Required | D.G. 320 X 2 | MR  |
| 18. | <b>Refuge Area</b>  | N/A      | N/A          | N/A |
|     | Total area location   | N/A      | N/A          | N/A |
| 19. | <b>Fire Control Room</b>  |          |              |     |
|     | a) Detector system panel  | Yes      | Yes          | MR  |
|     | b) Flow switch panel  | N/A      | N/A          | N/A |
|     | c) PA system panel  | Yes      | Yes          | MR  |
|     | d) Battery backup   | Yes      | Yes          | MR  |
|     | e) Building floor plan  | N/A      | N/A          | N/A |
| 20. | <b>Special Fire Protection System for Protection of special Risk, if any:</b> |          |              | N/A |

The fire protection system provided in the building were checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/-----

Accordingly DFA is put up please.

Signature of the inspecting officer


Signature of the inspecting officer


Name :-

Name:- S.S. Kaushik

Designation:-

Designation:-Assistant Divisional Officer

  
31/11/13

  
30/11/13