

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI - 110001



No: F 6/DFS/MS/2013/ School/615

Dated:- 13/02/13

FIRE SAFETY CERTIFICATE

Certified that the Govt. Boys Sr. Sec. School  
Dhaka Delhi comprised of Ground + one  
upper floor owned/occupied by Govt. Boys  
Sr. Sec. School Dhaka Delhi. Complied with the fire prevention and fire  
safety requirement in accordance with Director of Education circular Dated:-01/03/2011 and  
verified by the officer concerned of Fire Service on 11/12/12 in the presence of  
Shri Kishan Bhargava and that the building/premises is fit for occupancy  
Educational (Principal) building with effect from 13/02/13 for a period of  
Three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under  
Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service  
Rules, 2010.

Issued on 13/02/13 at New Delhi.

  
Chief Fire Officer  
Delhi Fire Service  
ok 

Copy to:-

1. The Principal  
Govt. Boys Sr. Sec. School  
Dhaka Delhi
2. The Addl. Director (Ed.)  
Govt. of NCT of Delhi  
old Sectt. Delhi

Note:-This fire safety certificate is subject to compliance of the condition printed over leaf.

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non – functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
5. Basement shall be used as per BBL.
6. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.

N/3

1.D-1308007

**INSPECTION REPORT**

1. Name & address of the building : Govt. Boys Sr. Sec. School Dhaka Dhaka  
 2. Type of Occupancy : Educational  
 3. Type of Case : New Case/ Renewal  
 4. Details of previous NOC : Letter No.        Dated:         
 5. Fire Safety directives letter No :         
 6. Date of inspection : 11/12/12  
 7. Name of the Inspecting Officers : DO (NW) S. S. Tuli  
 8. Name and designation of officers from the building side : Shri Kishan Bharamdasi (Principal)  
 9. Year of Construction : 1998  
 10. Applicant's letter No. : SB 555 / Dhaka / 926 dt - 11/12/12

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	<u>Accessible</u>	<u>Accessible</u>	<u>M.R.</u>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	<u>2 Nos</u>	<u>Provided</u>	<u>M.R.</u>
	<ul style="list-style-type: none"> <li>Upper Floors</li> <li>Basements</li> </ul>			
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>Upper Floors</li> <li>Basements</li> </ul>	<u>150 C.M</u>	<u>Discom @ 160cm</u>	<u>M/R</u>
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Pressurization</li> </ul>	<u>-</u>	<u>-</u>	<u>-</u>
	e. No. of continuous staircases to terrace	<u>-</u>	<u>-</u>	<u>-</u>
	g. Width of Corridor	<u>-</u>	<u>-</u>	<u>-</u>
	h. Door Size	<u>1 Mtr</u>	<u>1 Mtr</u>	<u>M.R.</u>
3	Compartmentation.			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>			
4	Smoke Management System.			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	<u>30 a/c per hour</u>	<u>12 a/c per hour</u>	

N/4

5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	6	11	m/r
		ISI marked	ABC	m/r
			yes	m/r
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	30 m		
		5 mm		
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>			
8	<b>MOEFA</b>			
9	<b>Public Address System.</b>			
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>			
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>			
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>			
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>			

N/S

4 Captive Water Storage for fire fighting.			
<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>			
15	Exit Signage.		
16	Provision of Lifts.		
<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>			
17	Standby power supply		
18	Refuge Area.		
	➤ Total Area		
	➤ Location		
19	Fire Control Room		
<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>			
20	Special Fire Protection Systems for Protection of special Risks, if any:		

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Name

Designation

*Signature*  
SSTuli  
DO(NW)

Signature of the Inspecting Officer

Name

Designation

*Signature*  
DO(NW)

le rocks #