

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI - 110001

No: F 6/DFS/MS/2013/*School/601*

Dated:- *13/02/13*

FIRE SAFETY CERTIFICATE

Certified that the *MCD Primary Co-Ed. School, Jat Khos*  
*Delhi* ..... comprised of *Ground + one*  
*upper floor* ..... owned/occupied by *M.C.D. Primary*  
*Co-Ed. School* ..... Complied with the fire prevention and fire  
safety requirement in accordance with Director of Education circular Dated:-01/03/2011 and  
verified by the officer concerned of Fire Service on *30-1-12* in the presence of  
*Sh. Jagdish Singh* and that the building/premises is fit for occupancy  
*Educational* ..... building with effect from *13/02/13* for a period of  
*Three years* in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under  
Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service  
Rules, 2010.

Issued on *13/02/13* at New Delhi.

*142*  
Chief Fire Officer  
Delhi Fire Service  
*Shy*

Copy to:-

- The Principal,*  
*MCD Primary Co-Ed. School,*  
*Jat Khos Delhi*
- The Adtl. Director (Edu.)*  
*North MCD Civic Centre*  
*Min. to. Res. New Delhi*

Note:-This fire safety certificate is subject to compliance of the condition printed over leaf.

- MINISTRY OF NATIONAL  
BUILDINGS
1. All the means of escape shall be kept free of all type of obstruction all the time.
  2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
  3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non – functional of fire safety measures, management shall be responsible.
  4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
  5. Basement shall be used as per BBL.
  6. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.

INSPECTION REPORT

1. Name & address of the building : MCD Primary Co. Edn. School, Jat Khor, Delhi
2. Type of Occupancy : Educational
3. Type of Case : ~~New Case/ Renewal~~
4. Details of previous NOC : Letter No. Nil Dated: \_\_\_\_\_
5. Fire Safety directives letter No : Circular, Dir. of Edun. 1/3/2011
6. Date of inspection : 30-1-2013
7. Name of the Inspecting Officers : ADO - SHYAM LAL
8. Name and designation of officers from the building side : Sh. Jagdish Singh
9. Year of Construction : 2012 (Gr.+1) ✓
10. Applicant's letter No. : Nil dated 11-12-2012

No.	Minimum Standards on fire prevention and fire safety U/R 33	Provided at site	Remarks
		<u>Circular, Dir. of Edun. 1/3/2013 Requirement</u>	<u>MR/NMR</u>

Access to building

• Road width	<u>Accessible</u>	<u>6 m</u> ✓	<u>M/R</u> ✓
• Gate width	<u>-/-</u>	<u>3.6 m</u> ✓	<u>M/R</u> ✓
• Width of internal road	<u>-/-</u>	<u>5 m</u> ✓	<u>M/R</u> ✓

Number, Width, Type & Arrangement of Exits

a. Number of staircases	<u>2</u>	<u>2</u> ✓	<u>M/R</u> ✓
• Upper Floors	<u>2</u>	<u>2</u> ✓	<u>M/R</u> ✓
• Basements	<u>Nil</u>	<u>Nil</u>	<u>Nil</u>
b. Width of staircases			
• Upper Floors	<u>1.5 m</u>	<u>1.85 m each</u> ✓	<u>M/R</u> ✓
• Basements	<u>Nil</u>	<u>Nil</u> ✓	<u>Nil</u>
c. Protection of exits			
• Fire check door		<u>NIR</u>	
• Pressurization		<u>NIR</u>	
d. No. of continuous staircases to terrace		<u>NIR</u>	
e. Width of Corridor	<u>R</u>	<u>2.10 m</u> ✓	<u>M/R</u>
f. Door Size	<u>1 m</u>	<u>1.13 m</u> ✓	<u>M/R</u> ✓

(Two door each class)

<b>Compartmentation.</b>			
• Fire check door		NIR	
• Sealing of electrical shafts			
• Fire Rating of shaft door			
• Water Curtain			
• Fire Dampers			
<b>Smoke Management System.</b>			
• Basements	30 a/c per hour	NIR	
• Upper floors	12 a/c per hour		
<b>Fire Extinguishers</b>			
• Total numbers	03	03 /	MIR /
• Types	ABC/CO2(2.5kg)	ABC /	MIR /
• ISI marking	ISI marked	yes /	MIR /
<b>First-Aid Hose Reels.</b>			
• Total numbers on each floor		NIR	
• Length of hose reel hose	30 m		
• Nozzle diameter	15 mm		
<b>Automatic fire detection and alarming system.</b>			
• Type of detectors		NIR	
• Location of Main Panel			
• Location of Repeater Panel			
• Alternate source of power			
• Hooters' Location			
<b>MOEFA</b>			
<b>Public Address System.</b>			
		NIR	
		NIR	
<b>Automatic Sprinkler System.</b>			
• Basement		NIR	

	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>			NIR		
15	Exit Signage.			NIR		
16	Provision of Lifts.			N/A		
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>					
	Standby power supply			NIR		
17	Reluge Area.			N/A		
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>					
18	Fire Control Room			NIR		
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>					
19	Special Fire Protection Systems for Protection of special Risks, if any:			NiL	NiL	NiL

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers... X

~~Do. - Leave~~  
Debo (ps)

Devi  
12/1/13

Shybal  
31/1/2013  
ADOC(RN)  
(SHYAMLAL)