

C/7

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI - 110001

No: F 6/DFS/MS/2013/ *school/631*

Dated:- *13/02/13*

FIRE SAFETY CERTIFICATE

Certified that the *MCD Primary Girls school, Ghewra Delhi*
..... comprised of *Ground + one*
upper floor owned/occupied by *MCD Primary*
Girls school Complied with the fire prevention and fire
safety requirement in accordance with Director of Education circular Dated:-01/03/2011 and
verified by the officer concerned of Fire Service on *30/1/13* in the presence of
Smt. Sumitra Devi and that the building/premises is fit for occupancy
Educational building with effect from *13/02/13* for a period of
03 years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under
Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service
Rules, 2010.

Issued on *13/02/13* at New Delhi.

Copy to:-

1 *The Principal*
MCD P. Girls school
Ghewra Delhi

2 *The Addl. Director (Edu.)*
North MED Civic Centre
Minic Rd, New Delhi.


Chief Fire Officer
Delhi Fire Service

etc 

Note:-This fire safety certificate is subject to compliance of the condition printed over leaf.

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non – functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
5. Basement shall be used as per BBL.
6. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.

N/S

INSPECTION REPORT

1. Name & address of the building : MCD Primary Girls School, Ghevra, Delhi-81
2. Type of Occupancy : Educational
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. Nil Dated: _____
5. Fire Safety directives letter No : Circular Dir. of Edun. 1/3/2011
6. Date of inspection : 30-1-2013
7. Name of the Inspecting Officers : ADO - SHYAM LAL
8. Name and designation of officers from the building side : Smt. Sunita Devi (Principal)
9. Year of Construction : 2009 (Gr. +1)
10. Applicant's letter No. : Nil dated 10-12-2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	<u>Accessible</u>	<u>5 m</u>	<u>MR</u> ✓
	• Gate width	<u>—</u>	<u>3.38m</u>	<u>MR</u> ✓
	• Width of internal road	<u>—</u>	<u>N/A</u>	<u>N/A</u>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	<u>2</u>	<u>2</u>	<u>MR</u> ✓
	• Upper Floors	<u>2</u>	<u>2</u>	<u>MR</u> ✓
	• Basements	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
	b. Width of staircases			
	• Upper Floors	<u>1.5 m</u>	<u>1.75m & 1.7m.</u>	<u>MR</u> ✓
	• Basements	<u>Nil</u>	<u>Nil</u>	<u>Nil</u>
	c. Protection of exits			
	• Fire check door		<u>N/A</u>	
	• Pressurization		<u>/</u>	
	e. No. of continuous staircases to terrace	<u>NR</u>	<u>N/A</u>	<u>N/A</u>
	g. Width of Corridor	<u>R</u>	<u>2.45 m</u>	<u>MR</u> ✓
	h. Door Size	<u>1 m</u>	<u>1.12 m</u>	<u>MR</u> ✓

N/O

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 		NIR	
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	NIR /	
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • ISI marking 	05 ABC/CO2(2:5kg) ISI marked	05 ABC YES	NIR ✓ NIR ✓ NIR ✓
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	30 m 5 mm	NIR /	
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 		NIR /	
8	MOEFA			NIR
9	Public Address System.			NIR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 			NIR

N/7

	<ul style="list-style-type: none">• Upper Floor• Sprinkler above false ceiling		NIR	
11	Internal Hydrants			
	<ul style="list-style-type: none">• Size of riser/down-comer• Number of hydrants per floor• Hose Box		NIR	
12	Yard Hydrants.			
	<ul style="list-style-type: none">• Total number of hydrants• Hose Box		NIR	
13	Pumping Arrangements.			
	<ul style="list-style-type: none">• Ground Level<ul style="list-style-type: none">➤ Discharge of main Pump➤ Head of Main pump➤ Number of main pumps➤ Jockey Pump out put➤ Jockey pump head➤ Standby Pump out put➤ Standby Pump Head➤ Auto Starting/ Manual stopping➤ Pump House Access• Terrace level<ul style="list-style-type: none">➤ Discharge of pump➤ Head of the pump➤ Power Supply➤ Auto Starting of pump		NIR	
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none">• Underground tank capacity➤ Draw-off connection		NIR	
			NIR	

N/P

	➤ Fire service inlet	N/R	N/P	N/A
	➤ Access to tank	N/R	N/P	N/A
	• Overhead Tank capacity		N/R	
15	Exit Signage.		N/R	
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/R	N/P	N/A
	• Pressurization of Lift lobby	N/R	N/P	N/A
	• Communication In lift Car	N/R	N/P	N/A
	• Fireman's Grounding Switch	N/R	N/P	N/A
	• Lift Signage	N/R	N/P	N/A
17	Standby power supply		N/R	
18	Refuge Area.			
	➤ Total Area	N/R	N/P	N/P
	➤ Location	N/R	N/P	N/P
19	Fire Control Room			
	• Detector System Panel	N/R	N/P	N/A
	• Flow Switch Panel	N/R	N/P	N/A
	• PA System Panel	N/R	N/P	N/A
	• Batter backup	N/R	N/P	N/A
	• Building Floor Plans	N/R	N/P	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	NIL	NIL	N/A

✓ The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Do (AW)
 DCFO (W)
 F.T.
 m.s. cell
 Singh
 11/2/13
 CPD
 01/2
 Venkatesh
 4/2
 Shyam Lal
 ADO (RN)
 30/11/2013
 (SHYAMLAL)
 Puro
 7/2