

49

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI - 110001

No: F 6/DFS/MS/2013/ *school/ 630*

Dated:- *13/02/13*

FIRE SAFETY CERTIFICATE


Certified that the *MCD Primary Girls School Nehru Vihar*
Delhi comprised of *Ground only -*
(10 sheds) owned/occupied by *MCD Ps.*
Girls school Complied with the fire prevention and fire
safety requirement in accordance with Director of Education circular Dated:-01/03/2011 and
verified by the officer concerned of Fire Service on *2/2/13* in the presence of
Smt. Poonam Rani and that the building/premises is fit for occupancy
Educational building with effect from *13/02/13* for a period of
0.3 years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under
Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service
Rules, 2010.

Issued on *13/02/13* at New Delhi.

Copy to:-

1 *The Principal*
MCD Ps. Girls school
Nehru Vihar Delhi 110054.

2 *The Addl. Director (Edu)*
North MCD Civic Centre
Minipal Road New Delhi


Chief Fire Officer
Delhi Fire Service

etc 8m

Note:-This fire safety certificate is subject to compliance of the condition printed over leaf.

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants In case of emergency.
3. All the fire fighting equipment shall be maintained In perfect working condition all the time and any lapse rendering non – functional of fire safety measures, management shall be responsible.
4. Any devlation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
5. Basement shall be used as per BBL.
6. This NOC may not be treated In any case for regularizations of unauthorized construction, if any.

N/1

INSPECTION REPORT

1. Name & address of the building : MCD Primary Girls School, Nahru Vihar, Delhi-54
2. Type of Occupancy : Educational
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. Nil Dated: _____
5. Fire Safety directives letter No : Circular, Dir. of Education. 1/3/2011 ✓
6. Date of inspection : 02/2/2013
7. Name of the Inspecting Officers : ADO - SHYAMLAL ✓
8. Name and designation of officers from the building side : Smt. Poonam Rani (Principal)
9. Year of Construction : 1985 (Ground only) ✓
10. Applicant's letter No. : Nil dated 22-10-2012

Sl. No.	Minimum Standards on fire prevention and fire safety U/R 33	Circular, Dir. of Edn. 1/3/2011 Requirement	Provided at site	Remarks MR/NMR		
<u>Access to building</u>						
	• Road width	<u>Accessible</u>	<u>6 m</u>	<u>M/R</u> ✓		
	• Gate width	<u>-h-</u>	<u>3 m</u>	<u>M/R</u> ✓		
	• Width of internal road	<u>-h-</u>	<u>5 m</u>	<u>M/R</u> ✓		
<u>Number, Width, Type & Arrangement of Exits</u>						
a.	Number of staircases	<u>N/A</u>				
	• Upper Floors					
	• Basements					
b.	Width of staircases					
	• Upper Floors					
	• Basements					
c.	Protection of exits					
	• Fire check door					
	• Pressurization					
e.	No. of continuous staircases to terrace					
d.	Width of Corridor					
f.	Door Size	<u>1 m</u>	<u>1.10 m</u>	<u>M/R</u> ✓		

(one door each class less than 45 students)

42 ✓

4. Compartmentation.					
• Fire check door				NIR 	
• Sealing of electrical shafts					
• Fire Rating of shaft door					
• Water Curtain					
• Fire Dampers					
5. Smoke Management System.					
• Basements	30 a/c per hour			NIR 	
• Upper floors	12 a/c per hour				
6. Fire Extinguishers					
• Total numbers	02	02			NIR ✓
• Types	ABC/CO2 (2.5kg)	ABC			NIR ✓
• ISI marking	ISI marked	YES			NIR ✓
7. First-Aid Hose Reels.					
• Total numbers on each floor				NIR 	
• Length of hose reel hose	30 m				
• Nozzle diameter	5 mm				
8. Automatic fire detection and alarming system.					
• Type of detectors				NIR 	
• Location of Main Panel					
• Location of Repeater Panel					
• Alternate source of power					
• Hooters' Location					
9. MOEFA					NIR
10. Public Address System.					NIR
11. Automatic Sprinkler System.					
• Basement					NIR

M/3

	• Upper Floor		N/R	
	• Sprinkler above false ceiling		N/R	
11	Internal Hydrants			
	• Size of riser/down-comer		N/R	
	• Number of hydrants per floor		/	
	• Hose Box		/	
12	Yard Hydrants.			
	• Total number of hydrants		N/R	
	• Hose Box		/	
13	Pumping Arrangements.			
	• Ground Level		N/R	
	➤ Discharge of main Pump			
	➤ Head of Main pump			
	➤ Number of main pumps			
	➤ Jockey Pump out put			
	➤ Jockey pump head			
	➤ Standby Pump out put			
	➤ Standby Pump Head			
	➤ Auto Starting/ Manual stopping			
	➤ Pump House Access			
	• Terrace level			
	➤ Discharge of pump			
	➤ Head of the pump			
	➤ Power Supply			
	➤ Auto Starting of pump			
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity		N/R	
	➤ Draw-off connection		/	

N/A

	➤ Fire service inlet		NIR	
	➤ Access to tank			
	• Overhead Tank capacity			
15	Exit Signage.		NIR	
16	Provision of Lifts.		N/A	
	• Pressurization of Lift Shaft			
	• Pressurization of Lift lobby			
	• Communication In lift Car			
	• Fireman's Grounding Switch			
	• Lift Signage			
17	Standby power supply		NIR	
18	Refuge Area.		N/A	
	➤ Total Area			
	➤ Location			
19	Fire Control Room		NIR	
	• Detector System Panel			
	• Flow Switch Panel			
	• PA System Panel			
	• Batter backup			
	• Building Floor Plans			
20	Special Fire Protection Systems for Protection of special Risks, if any:	Nil	Nil	Nil

- ✓ The fire protection systems provided in the building were test checked and found functional at the time of inspection.
- ✓ Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

~~DO NOT WRITE~~
Defto (10)

Swish
4/2/13

Shyam Lal
2/2/2013
ADO (RN)
(SHYAM LAL)

CSB
Kantat