

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/2013/ 701

Dated: 19/02/13

FIRE SAFETY CERTIFICATE

Certified that the **M/s Alka flame** located at **Site No.-1, Sector-7, R.K. Puram, New Delhi**, comprised of **Single Storey Building (LPG Godown)** was granted NOC by this department vide letter No. **F6/DFSMS/LPG/10/284** dated **29/01/10**. The premises was inspected by the officer concerned of this department on **07/02/13** in the presence of **Mr. Raj Kumar** and found that the said service station have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Group J Hazardous Building** with effect from 19/02/13 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010 subject to conditions as printed below.

Issued 19/02/13 at New Delhi by.


187
Chief Fire Officer
Delhi Fire Service

Copy to:- (1) The Administrative Officer,
Municipal Corporation of Delhi,
Office of The Asstt. Commissioner (South zone) Green Park, New Delhi.

(2) M/s Alka flame,
Site No.-1, Sector-7, R.K. Puram, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building:- M/s Alka Flame, Site No.1, Sector -7, R.K. Puram, New Delhi.
2. Type of occupancy:- Group J Hazardous Building
3. Type of case:- Renewal
4. Details of previous NOC:- No. F6/DFS/MS/LPG/10/284 dated 29/01/10.
5. Fire safety directives No.- N/A.
6. Date of inspection:- 07/02/13.
7. Name of the inspecting officer:- A.D.O. S.S. Kaushik
8. Name & designation of officer
From the building side:- Mr. Raj Kumar.
9. Year of construction:- N/A
10. Applicant's letter No:- Nil dated 21/01/13 Single Storey Building (LPG Godown).

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building	Required	Provided	MR
	1) Road width	12 mtr.	Provided	MR
	2) Gate width	Yes	Provided	MR
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	B. Width of staircase	N/A	N/A	N/A
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	C. Protection of exits	N/A	N/A	N/A
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	Yes	1 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	N/A	N/A
	2) Upper floors	12 a/c per hour	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	ISI Marked	10 Nos.	MR
	2) Types		ABC, Co2, DCP & M.Foam	MR

7/11

	3) ISI marking		Yes	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	N/A	N/A	N/A
	2) Length of hose reel hose	30 m	N/A	N/A
	3) Nozzle diameter	5 mm	N/A	N/A
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A

13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level	N/A	N/A	N/A
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	N/A	N/A	N/A
15.	Exit Signage.	N/A	N/A	N/A
16.	Provision of Lifts.	N/A	N/A	N/A
	a) Pressurization of lift shaft	N/A	N/A	N/A

	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A

	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			MR
	Fire Buckets filled with sand, No smoking boards in Hindi & English were found displayed. No lose electric wiring were seen in premises.			

The fire protection system provided in the building were checked and found functional at the time of inspection.


Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/-----

Accordingly DFA is put up please.


Signature of the inspecting officer

Signature of the inspecting officer

Name:- Dharampal Bharadwaj



Designation:- Divisional Officer



Name:- S.S. Kaushik.

Designation:- Assistant Divisional Officer.