

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO.

F6/DF3MS/EH/2013/725

Dated: 20/02/2013

FIRE SAFETY CERTIFICATE

Certified that the Amritsar to China Restaurant (A unit of Citgo Hospitality Ltd.) GA-04 & GA 05, Metro Walk Mall, Sector -10, Rohini, Delhi 110085 was granted NOC by this department vide letter no F-6/MS/DFS/EH/2009/3765 Dated 11/12/2009. The premises was re-inspected by the officers concerned of this department on 07/02/2013 in the presence of Sh. Varun Dahiya and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and premises is fit for Assembly occupancy with effect from 20/2/13 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of Delhi Fire Service Rules, 2010.

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able by guests in an event of emergency.
2. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
3. The fire suppression / protection arrangements provided in the restaurant are to minimize losses, if maintained in good working condition. These systems cannot give any guarantee that there will be no fire or losses in the event of one.
4. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
5. This report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 20/02/13 at New Delhi by

Chief Fire Officer
Delhi Fire Service

ok

20/2

ok

Copy to:

1. The Additional Commissioner of Police (Lic), 1st floor, Police Station, Defense Colony, New Delhi for information
2. The Authorized Signatory, Amritsar to China Restaurant (A unit of Citgo Hospitality Ltd.) GA-04 & GA 05, Metro Walk Mall, Sector -10, Rohini, Delhi 110085

Renewal

INSPECTION REPORT

1. Name & address of the building : Amritsar To Ching GA 425, metro walk, Sec-10, Rohit Delhi.
2. Type of Occupancy : Restaurant (Assembly) on G.F
3. Type of Case : New Case/Renewal
4. Details of previous NOC : Letter No. F6/DFI/MS/EH/2009/3205 Dated: 11/12/09
5. Fire Safety directives letter No : -
6. Date of inspection : 07/02/2013
7. Name of the Inspecting Officers : DO (NW) SSTuli
8. Name and designation of officers from the building side : Mr Varun Dahiya
9. Year of Construction : -
10. Applicant's letter No. : Nil dtd 31/01/13

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	<u>6 m</u>	<u>P</u>	<u>m/R</u>
	• Gate width	<u>-</u>	<u>-</u>	<u>-</u>
	• Width of internal road	<u>-</u>	<u>-</u>	<u>-</u>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			/
	• Upper Floors			
	• Basements			
	b. Width of staircases			
	• Upper Floors			
	• Basements			
	c. Protection of exits			
	• Fire check door			
	• Pressurization			
	e. No. of continuous staircases to terrace			
	g. Width of Corridor			
	h. Door Size	<u>old case</u>	<u>front 1.02 mtr Rear 1.13 mtr</u>	<u>m/R</u>
3	Compartmentation.	<u>Available with metro walk</u>		
	• Fire check door	<u>R</u>	<u>P</u>	<u>m/R</u>
	• Sealing of electrical shafts	<u>-</u>	<u>-</u>	<u>-</u>
	• Fire Rating of shaft door	<u>-</u>	<u>-</u>	<u>-</u>
	• Water Curtain	<u>-</u>	<u>-</u>	<u>-</u>
	• Fire Dampers	<u>-</u>	<u>-</u>	<u>-</u>
4	Smoke Management System.	<u>Provided with metro walk.</u>		
	• Basements	30 a/c per hour	<u>-</u>	<u>-</u>
	• Upper floors	12 a/c per hour	<u>exhaust fans</u>	<u>m/R</u>