

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No.


FC/DFS/MS/VGA/2013/723

Dated: 20 / 03 /2013

FIRE SAFETY CERTIFICATE

Certified that the Funky Kingdom Amusement Pvt. Ltd (name of the building or premises) located at 217 – A, second floor Moments Mall, Kirti Nagar, New Delhi have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of Fire Service on 10/02/2013 in the presence of Sh Diwan and that the building/premises is fit for occupancy Class – D Assembly with effect from 20 / 02 /2013 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 subject to conditions printed below.

Issued on 20/02/13 at New Delhi.


Chief Fire Officer
Delhi Fire Service

ofc
Mav

Copy to:

1. The Additional Commissioner of Police (Lic), 1st floor, Police Station, Defence Colony,
2. Funky Kingdom Amusement Pvt. Ltd, 217 – A, second floor Moments Mall, Kirti Nagar, New Delhi

Following fire safety directives must be adhered to

- a. Means of escape shall not be kept locked or bolted from outside and shall be easily open able by guests in an event of emergency.
- b. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
- c. The fire suppression / protection arrangements provided in the restaurant are to minimize losses, if maintained in good working condition. These systems cannot give any guarantee that there will be no fire or losses in the event of one.
- d. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
- e. This report may not in any way be treated as regularization of unauthorized construction, if any.
- f. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

May Kindly peruse letter no. 5584/Addl.C.P./Lic/Amst dated 05/02/2102 received from Addl.C.P./Lic (Amst.) regarding Issuance of NOC in r/o **Funky Kingdom Pvt. Ltd** located at shop no. 217 – A, second floor Moments Mall, near Kirti Nagar metro station, New Delhi. In this connection it is informed that the premises was inspected by ADO (WP) and observed that the shopping mall building comprised basement, ground plus two upper floors. Fire safety arrangements are put up on the prescribed Performa:

1. Name & address of the building : **Funky Kingdom Pvt. Ltd**, 217 – A, second floor Moments Mall, near Kirti Nagar metro station, New Delhi. *Amusement*
2. Type of Occupancy : Class-D (Assembly)
3. Type of Case : New
4. Details of previous NOC : N/A
5. Fire Safety directives letter No. : N/A
6. Date of inspection : 10/02/2013
7. Name of the Inspecting Officers : ADO (MN)
8. Name and designation of officers
From the building side : Sh. Diwan
9. Year of Construction : 2011
10. Applicant's letter No. : 5584/Addl.C.P./Lic/Amst dated 05/02/2102

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6.0mtrs	24.0mtr	M/R
	• Gate width	5.0mtr	Provided	M/R
	• Width of internal road	Required	Provided	M.R.
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	2	3	M.R.
	• Basement	2	3	M.R.

	b. Width of staircases			
	• Upper Floors	1.5 mtrs	1.6 mtrs	Provided
	• Basement	1.5 mtrs	1.6 mtrs	Provided
	c. Protection of exits			
	• Fire check door	Required	Provided	M.R.
	• Pressurization	Required	Provided	M.R.
	d. No. of continuous staircases to terrace	02	02	M.R
	e. Width of Corridor	1.5 mts	2.10 mtrs	M.R
f. Door size	2 X 2.0 mts	1 X 3.2 mtrs. 1 X 2.0 mts		
3.	Compartmentation.			
	• Fire check door	Not Required	N/A	N/A
	• Sealing of electrical shafts	Required	Provided	M.R.
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/R	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System.			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	8	10	M.R
	• Types	ABC & CO ₂	Provided	M.R

	<ul style="list-style-type: none"> IS marking 	ISI marks	Provided	M.R
6.	First-Aid Hose Rees. – Common With S/Mall			
	<ul style="list-style-type: none"> Total numbers on each floor 	2	Provided	M.R
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m required	Provided	M.R
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm required	Provided	M.R
7.	Automatic fire detection and alarming system. - Common With S/Mall			
	<ul style="list-style-type: none"> Type of detectors 	Smoke Heat	Provided	M.R
	<ul style="list-style-type: none"> Location of Main Panel 	G. Floor	Provided	M.R
	<ul style="list-style-type: none"> Location of Repeater Panel 	On each floor	Provided	M.R
	<ul style="list-style-type: none"> Alternate source of power 	Required	Provided	M.R
	<ul style="list-style-type: none"> Hooter's Location 	Required	Provided	M.R.
8.	MOEFA	Required	Provided Common With S/Mall	M.R
9.	Public Address System	Required	Provided Common With S/Mall	.M.R.
10.	Automatic Sprinkler system	Common With S/Ma		
	<ul style="list-style-type: none"> Basement 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Upper Floor 	Required	Provided	M.R
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N/A	N/A	N/A
11.	Internal Hydrants - Common With S/Mall			

Family Kingdom.

	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	150 mm	Provided	M.R
		2	Provided	M.R
		2	Provided	M.R
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
13.	Pumping Arrangements. - Common With S/Mall			
	Ground Level			
	➤ Discharge of main pump	2280 LPM Of the Mall	Provided	M/R
	➤ Head of Main pump	60 mtr	Provided	M/R
	➤ Number of main pumps	2	Provided	M/R
	➤ Jockey Pump out put	180 LPM	Provided	M.R.
	➤ Jockey pump head	60 mtr	Provided	M.R.
	➤ Standby pump out put	2280 LPM Of the Mall	Provided	M/R
	➤ Standby pump Head	60 mtr	Provided	M/R
	➤ Auto Starting/Manual stopping	Required	Provided	M/R
	➤ Pump Hose Access	Required	Provided	M.R.
	Terrace level			
	➤ Discharge of pump	900 LPM	Provided	M.R
	➤ Head of the pump	60 mtr	Provided	M.R

	➤ Power supply	Required	Provided	M.R
	➤ Auto Starting of pump	Required	Provided	M.R
14.	Captive Water Storage for firefighting. - Common With S/Mall			
	Underground tank capacity	50,000 ltrs	Provided	M.R.
	➤ Draw -off connection	Required	Provided	M.R
	➤ Fire service inlet	Required	Provided	M.R
	➤ Access to tank	Required	Provided	M.R
	➤ Overhead Tank Capacity	10, 000 ltrs	Provided	M.R
15	Exit Signage.	Required	Provided	M.R
16.	Provision of Lifts	Common With S/Mall		
	• Pressurization of Lift Shaft	Required	Provided	M.R
	• Pressurization of Lift lobby	Required	Provided	M.R
	• Communication In lift Car	Required	Provided	M.R
	• Fireman's Grounding Switch	Required	Provided	M.R
	• Lift Signage	Required	Provided	M.R.
17.	Standby power supply	Required	Provided	M.R
18.	Refuge Area	N.R.	N.R	N.R
	➤ Total Area	N.R.	N.R.	N.R

Funky Kingdom

	➤ Location	N.R.	N.R.	N.R.
19.	Fire Control Room	Common With S/Mall		
	➤ Detector System Panel	N.R.	N.R.	N.R.
	➤ Flow Switch Panel	N.R.	N.R.	N.R.
	➤ PA system Panel	N.R.	N.R.	N.R.
	➤ Batter backup	N.R.	N.R.	N.R.
	➤ Building Floor plans	N.R.	N.R.	N.R.
20.	Special Fire Protection Systems for Protection of special Risks, if any	N.R.	N.R.	N.R.

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 .



Signature of the Inspection Officer

Name S. K. Dua

Designation ADO (WP)