

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**


No. F6/DFS/MS/School/2013/ 743

Dated: 21/02/13

**FIRE SAFETY CERTIFICATE**

Certified that **M.C.D. Primary School, Vinoba Puri, New Delhi**, comprised of ground plus one upper floor **Owned/Occupied** by M.C.D. Primary School has complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 and verified by officer concerned of Delhi Fire Service on 07/02/2013 in the presence of Sh. Abdul Gaffer, Principal of the school and that the building/premises is fit for occupancy class-B "**Educational building**" with effect from 21/02/13 for a period of **THREE** years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010.

Issued on 21/02/13 ----- at New Delhi by



CHIEF FIRE OFFICER  
DELHI FIRE SERVICE

*o/c/m*

**Copy To: -**

1. The Directorate of Education, <sup>South mes civic centre</sup> Govt. of NCTD, Old Secretariat, New Delhi.
2. The Principal, M.C.D. Primary School, Vinoba Puri, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

- a) All the Fire Safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
- b) Building Sanctioning Authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c) The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d) The Basement shall be used strictly as per the provisions of Building Bye Laws.
- e) The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

## INSPECTION REPORT

1. Name and address of the building : M.C.D. Primary School  
 : Vinoba Puri, New Delhi-110024
2. Type of Occupancy : Class- B "Educational Building"
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives letter No : Directorate of Education Cir Dt:01/03/2011
6. Date of Inspection : 07/02/2013
7. Name of the Inspecting Officers : *D. P. Bhandari Div. offi*
8. Name and Designation of Officers From the building side : Sh. Abdul Gaffer, Principal
9. Year of Construction : 2010, (Ground plus one upper floor)
10. Applicants letter No : Nil

S.No.	Minimum Standards on Fire Prevention and Fire Safety U/R 33	DOE Circular 01.03.2011	Provided at site	Remarks MR/NMR
<b>1</b>	<b>Access to building</b>			
	• Road width	Accessible	9 Mtrs	MR
	• Gate width	NA	5 Mtrs	MR
	• Width of internal road	NA	NA	NA
<b>2</b>	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	• Number of staircase			
	➤ Upper Floors	2	2	MR
	➤ Basements	NA	NA	NA
	• Width of Staircases			
	➤ Upper Floors	1.50 Mtrs <i>Each</i>	1.50 Mtrs <i>Each</i>	MR
	➤ Basements	NA	NA	NA
	• Protection of exits			
	➤ Fire check door	NA	NA	NA
	➤ Pressurization	NA	NA	NA
	• No. of continuous staircases to terrace	NA	NA	NA
	• Width of Corridor	NA	NA	NA
	• Door width/Size	1.0 Mtrs	1.15 Mtrs	MR
<b>3</b>	<b>Compartmentation</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire rating of shaft door	NA	NA	NA
	• Water curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
<b>4</b>	<b>Smoke Management System</b>			
	• Basements	NA	NA	NA
	• Upper Floors	NA	NA	NA

N/2

<b>5</b>	<b>Fire Extinguishers</b>			
	• Total Number	01/300m2	04 Nos	MR
	• Types	ABC/CO2	ABC	MR
	• IS marking	ISI mark	YES	MR
<b>6</b>	<b>Firs-Aid Hose Reels</b>			
	• Total Number on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
<b>7</b>	<b>Automatic Fire detection and alarming system</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooter's Location	NA	NA	NA
<b>8</b>	<b>MOEFA /SIRON</b>	Required	Provided	MR
<b>9</b>	<b>Public Address System</b>	NA	NA	NA
<b>10</b>	<b>Automatic Sprinkler System</b>			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
<b>11</b>	<b>Internal Hydrants</b>			
	• Size of riser/down comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
<b>12</b>	<b>Yard Hydrants</b>			
	• Total Number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
<b>13</b>	<b>Pumping Arrangements</b>			
	• <b>Ground Level</b>			
	➤ Number of main pump	NA	NA	NA
	➤ Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump Head	NA	NA	NA
	➤ Standby pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual	NA	NA	NA
	➤ Pump House Access			
	• <b>Terrace level</b>			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto starting /manual	NA	NA	NA
<b>14</b>	<b>Captive Water Storage for Fire Fighting</b>			

M/S

	<ul style="list-style-type: none"> <li>Underground tank capacity               <ul style="list-style-type: none"> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> </ul> </li> <li>Overhead tank capacity</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
<b>15</b>	<b>Exit Signage</b>	NA	NA	NA
<b>16</b>	<b>Provision of Lifts</b>			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Pressurization of Lift lobby</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Communication in lift Car</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Fireman's Grounding Switch</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Lift Signage</li> </ul>	NA	NA	NA
<b>17</b>	<b>Standby Power Supply</b>	NA	NA	NA
<b>18</b>	<b>Refuge Area</b>			
	<ul style="list-style-type: none"> <li>Total Area</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Location</li> </ul>	NA	NA	NA
<b>19</b>	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>Detector System Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Flow Switch Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>PA System Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Battery back up</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Building Floor Plans</li> </ul>	NA	NA	NA
<b>20</b>	<b>Special Fire Protection System for Protection of special risk, if any.</b>	NA	NA	NA

The Fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, It is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / issue shortcomings as noted at serial number.....

Accordingly, DFA/FT letter is put up for perusal and signature, if approved please.

  
 Signature of Inspecting Officer

Name : DHARAM PAL

Designation: DIV. OFFICER