

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUATERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

NO.F6/DFS/MS/EH/2012/ 761

Dated: 21/2/13

FIRE SAFETY CERTIFICATE

Certified that **M/s Barbeque Nation (A unit of Barbeque Nations Hospitality Pvt. Ltd)**, located at 2nd floor of N-96, 97 & 98, Munshi Lal Building, Connaught Circus, New Delhi-110001 comprised of ground (shop + Ambar restaurant), first floor (Nirulas Potpourri restaurant) & second floor(Barbeque Nation) have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service rules, 2010 and verified by the officers concerned of Delhi fire service on 07.01.2013 in presence of Shri Anil Kr. Sharma, Liaison Manager of the restaurant and that the building/premises is fit for occupancy class D Assembly Building Sub Division D-3 with effect from 21/2/13 for a period of **3(three)** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 21/2/13 at New Delhi by.


**Chief Fire Officer
Delhi Fire Service**

Copy to: -

1. The Manager M/s Barbeque Nation (A unit of Barbeque Nations Hospitality Pvt. Ltd), 2nd floor of N-96, 97 & 98, Munshi Lal Building, Connaught Circus, New Delhi-110001.
2. The Medical Officer of Health, Health Department, NDMC, Palika Kendra, New Delhi

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
3. Any loss to life or property due to non functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.

INSPECTION REPORT

1. Name & address of the building : M/s Barbeque Nation (A unit of Barbeque Nations Hospitality Pvt. Ltd), 2nd floor of N-96, 97 & 98, Munshi Lal Building, Connaught Circus, New Delhi-110001
2. Type of Occupancy : Eating House
3. Type of Case : New case
4. Details of previous NOC : N/A
5. Fire Safety directives letter No : N/A
6. Date of inspection : 07.01.2013
7. Name of the Inspecting Officers : Dharamvir Singh Yadav, DO(CD) and M.K.Chattopadhyay, ADO(CC)
8. Name and designation of officers
from the building side : Anil Sharma, Liaison Manager
9. Year of Construction : Prior 1962
10. Applicant's letter No. : MOH/D/1376/DSO/(Lic)SI-I dated 06-11-2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC / <i>DBL</i> Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	More than 06 mts	MR
	• Gate width	-----	Directly accessible from the road	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	----	-----	-----
	• Upper Floors	02	03	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-----	-----	-----
	• Upper Floors	1.25 mts	1.3mts, 1.26 mts & 1.0 mts	MR being old bldg prior to 1983
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-----	-----	-----
	• Fire check door	N/A	N/A	-----

J

	<ul style="list-style-type: none"> Pressurization 	N/A	N/A	-----
	e. No. of continuous staircases to terrace	01	01	MR
	g. Width of Corridor	N/A	N/A	-----
	h. Door Size	1.5 mts	provided	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door 	N/A	N/A	-----
	<ul style="list-style-type: none"> Sealing of electrical shafts 	N/A	N/A	-----
	<ul style="list-style-type: none"> Fire Rating of shaft door 	N/A	N/A	-----
	<ul style="list-style-type: none"> Water Curtain 	N/A	N/A	-----
	<ul style="list-style-type: none"> Fire Dampers 	N/A	N/A	-----
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements 	30 a/c per hour	N/A	N/A
	<ul style="list-style-type: none"> Upper floors 	12 a/c per hour	Provided	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	06	Provided	MR
	<ul style="list-style-type: none"> Types 	ABC, W.CO ₂	Provided	MR
	<ul style="list-style-type: none"> IS marking 	ISI marked	Provided	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor 	01	Provided	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m	Provided	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	Heat/smoke	Provided	MR
	<ul style="list-style-type: none"> Location of Main Panel 	2 nd floor	Provided	MR
	<ul style="list-style-type: none"> Location of Repeater Panel 	N/A	N/A	-----
	<ul style="list-style-type: none"> Alternate source of power 	Required	Provided	MR
	<ul style="list-style-type: none"> Hooters' Location 	Restaurant	Provided	MR

8

8	MOEFA	Required	Provided	MR
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	N/A	N/A	N/A
		Required	Provided	MR
		Required	Provided	MR
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	100 mm	Provided	MR
		01	Provided	MR
		01	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	N/A	N/A	-----
		N/A	N/A	-----
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump 	N/A	N/A	-----
		N/A	N/A	-----
		N/A	N/A	-----
		N/A	N/A	-----
		N/A	N/A	-----
		N/A	N/A	-----
		N/A	N/A	-----
		N/A	N/A	-----
		N/A	N/A	-----
		N/A	N/A	-----
		N/A	N/A	-----
		450 LPM	450, 180 LPM	MR

	➤ Head of the pump	40 mts	Provided	MR
	➤ Power Supply	Required	provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	N/A	N/A	-----
	➤ Draw-off connection	N/A	N/A	-----
	➤ Fire service inlet	N/A	N/A	-----
	➤ Access to tank	N/A	N/A	-----
	• Overhead Tank capacity	10,000 lts	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	-----
	➤ Location	N/A	N/A	-----
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	-----
	• Flow Switch Panel	N/A	N/A	-----
	• PA System Panel	N/A	N/A	-----
	• Batter backup	N/A	N/A	-----
	• Building Floor Plans	N/A	N/A	-----

20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	One ABC type fire extinguisher found Provided near elect. panel	MR
----	--	----------	---	----


The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Note:- Previously, first & second floor of N-block, Munshi Lal Building, Connaught Circus, New Delhi-110001 was used for centre court hotel and the same was closed.



M.K.Chattopadhyay
Asstt. Div. Officer (CC)



Dharamvir Singh Yadav
DO(CD)