

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001


NO. F6/DFS/MS/2013 / 799

Dated: 22 / 2 / 2013

FIRE SAFETY CERTIFICATE

Certified that the Kendriya Vidyalaya Sect-3 Rohini Delhi.....comprised  
of Ground + Two upper floors.....  
.....owned/occupied  
by Kendriya Vidyalaya.....complied with the fire prevention and fire safety  
requirement in accordance with BBL-1983, National Building Code Part IV.....and  
verified by the officer concerned of fire service on 7-2-2013.....in the  
presence of Sh. A.K. Kalra.....and that the building /premises is fit for  
occupancy.....Educational.....building with effect  
from 22/2/13.....for period of Three years.....in accordance with rule 36 unless  
renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the  
conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 22/2/13.....at New Delhi.

  
Chief Fire officer  
Delhi Fire Service  
J.C. Sharma

Copy to:-

1. The Principal,  
Kendriya Vidyalaya Sect-3  
Rohini Delhi 110085.
2. The Dy-Commissioner  
Kendriya Vidyalaya Sangathan  
(D.R) J.N.U campus N. Delhi.

Note:-This fire safety certificate is subject to compliance of the condition printed over leaf.

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
5. Basement shall be used as per BBL.
6. This NÓC may not be treated in any case for regularizations of unauthorized construction, if any.

17/2

INSPECTION REPORT

1. Name & address of the building : Kenderya Vidyalaya, sect-3, Rohini, Delhi-
2. Type of Occupancy : Educational
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. Nil Dated: \_\_\_\_\_
5. Fire Safety directives letter No : NBC
6. Date of inspection : 07-2-2013
7. Name of the Inspecting Officers : ADO - SHYAM LAL
8. Name and designation of officers from the building side : Sh. A.K. Kalra
9. Year of Construction : 2006, (Gr. +2)
10. Applicant's letter No. : KVR (S-3) F87/2012-13/680 dt 23.1.2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	12 m	12 m	M/R ✓
	• Gate width	6 m	6.2 m	M/R ✓
	• Width of internal road	6 m	6 m	M/R ✓
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	04	04	M/R ✓
	• Upper Floors	04	04	M/R ✓
	• Basements	Nil	Nil	Nil
	b. Width of staircases			
	• Upper Floors	1.5 m	1.5 m each.	M/R ✓ <u>complied</u>
	• Basements	Nil	Nil	Nil
	c. Protection of exits			
	• Fire check door		NIR	
	• Pressurization			
	e. No. of continuous staircases to terrace	2	2	M/R ✓
	g. Width of Corridor	R		
	h. Door Size	1 m	1 m with door filling	M/R ✓ <u>complied</u>
3	<b>Compartmentation.</b>			
	• Fire check door		NIR	
	• Sealing of electrical shafts			
	• Fire Rating of shaft door			
	• Water Curtain			
	• Fire Dampers			
4	<b>Smoke Management System.</b>			
	• Basements	30 a/c per hour	NIR	
	• Upper floors	12 a/c per hour	1	

[15 class rooms = 2 doors  
 21 class room = 1 door 2 less than 15 student]

6/N

5	<b>Fire Extinguishers</b>				
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	<p>22 ABC/CO2 (25kg) ISI marked</p>	<p>22 ABC yes</p>	<p>MIR MIR MIR</p>	<p>Complied ✓ ✓</p>
6	<b>First-Aid Hose Reels.</b>				
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	<p>03 30 m 5 mm</p>	<p>Provided provided provided</p>	<p>MIR MIR MIR</p>	<p>Complied ✓ ✓</p>
7	<b>Automatic fire detection and alarming system.</b>				
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>		<p>NIR   NIR</p>		
8	<b>MOEFA</b>				
9	<b>Public Address System.</b>				
			<p>NIR</p>		
10	<b>Automatic Sprinkler System.</b>				
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>		<p>NIR   /</p>		
11	<b>Internal Hydrants</b>				
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>		<p>NIR  </p>		
12	<b>Yard Hydrants.</b>				
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>		<p>NIR  </p>		
13	<b>Pumping Arrangements.</b>				
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>		<p>NIR   NIR NIR P</p>	<p>450 Lts./minuit. 40 m NIR MIR MIR</p>	<p>Complied ✓ ✓ ✓ ✓</p>

7/N

Captive Water Storage for fire fighting.				
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>Overhead Tank capacity</li> </ul>		NIR	
		10000 lts.	Provided	m/r
15	Exit Signage.	R	P	m/r
16 Provision of Lifts.				
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of Lift lobby</li> <li>Communication In lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>		N/A	
17	Standby power supply		NIR	
18 Refuge Area.				
	➤ Total Area		N/A	
	➤ Location			
19 Fire Control Room				
	<ul style="list-style-type: none"> <li>Detector System Panel</li> <li>Flow Switch Panel</li> <li>PA System Panel</li> <li>Batter backup</li> <li>Building Floor Plans</li> </ul>		NIR	
20	Special Fire Protection Systems for Protection of special Risks, if any:	Nil	Nil	Nil

Complied

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

*Shyam Lal*

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Name (SHYAM LAL

Designation

Designation

D.P.  
(NCO)  
*Ruph*  
12/2/13

Assist. Divn. Officer