

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI


No F 6 / DFS / MS / 2013 / EH / 760

Dated 21-02-2013

**FIRE SAFETY CERTIFICATE**

Certified that the "RPM Max" Restaurant situated at mezzanine and First floor located at 40, Basant Lok, Vasant Vihar, New Delhi 110067 was granted NOC by this department vide letter No F6/ MS / DFS / EH / 2009 / 2920 dated 01.10.2009. The premises was re-inspected by the officer concerned of this department on 18.02.2013 in the presence of Mr. Uday Pandye and found that the Restaurant have deemed complied with fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Group D Assembly Building of with effect from ...21/2/13... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...21/2/13... at New Delhi by.

  
Chief Fire Officer  
Delhi Fire Service



Copy to: -

1. The Assistant Commissioner of Police, (Lic), 1<sup>st</sup> floor, PS Defence Colony, New Delhi
2. The Owner/Partner, RPM Max, Restaurant at 40, Basant Lok, Vasant Vihar, New Delhi.

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

## INSPECTION REPORT

1. Name & address of the building: RPM Max Restaurant, at 40, Basant Lok, Vasant Vihar,  
New Delhi- 110067
2. Type of Occupancy : Restaurant
3. Type of Case : Renewal
4. Details of previous NOC : Letter No F6/ MS /DFS/ EH/2009/2920 Dated 01.10.2009
5. Fire Safety directives Letter No. : N/A
6. Date of inspection : 18.02.2013
7. Name of the Inspecting Officer : Dy. CFO Atul Garg
8. Name and designation of Officer  
from the building side : Mr. Uday Pandye
9. Year of Construction : Before 2002
10. Addl. C.P. letter No. : 67900 Addl.C.P./Lic(Amst.) dated 30.11.2012 & Applicant  
Letter No. Nil dated 04.01.2013

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	4.5 mtr.	4.5 mtr.	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	02	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	N/A	1.25 mtr. 1.00 mtr.	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A

	d. No of continuous staircase to terrace	01	01	MR
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	02 doors	1.1 mtr. & 1 mtr.	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	YES	MR (old case)
5.	Fire Extinguishers			
	• Total numbers	04	04	MR
	• Types		WT, CO <sub>2</sub>	MR
	• IS marking	ISI marked	YES	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	01	01	MR
	• Length of hose reel hose	30 m	YES	MR
	• Nozzle diameter	5 mm	YES	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	YES	YES	MR
9.	Public Address System	YES	YES	MR
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	YES	YES	MR
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down- comer	100 m	Provided	MR



	<ul style="list-style-type: none"> <li>• Number of hydrants per floor</li> </ul>	01	01	MR
	<ul style="list-style-type: none"> <li>• Hose Box</li> </ul>	01	01	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Hose Box</li> </ul>	N/A	N/A	N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> <li>• Ground Level</li> </ul>			
	<ul style="list-style-type: none"> <li>• Discharge of main pump</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Head of main pump</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Number of main pumps</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Jockey pump out put</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Jockey pump head</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Standby Pump out put</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Standby Pump Head</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Auto Starting/Manual stopping</li> </ul>	YES	YES	MR
	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Terrace level</li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of pump</li> </ul>	450 Lpm	YES	MR
	<ul style="list-style-type: none"> <li>➤ Head of the pump</li> </ul>	30 M	30 M	MR
	<ul style="list-style-type: none"> <li>➤ Power supply</li> </ul>	YES	YES	MR
	<ul style="list-style-type: none"> <li>➤ Auto starting of pump</li> </ul>	YES	YES	MR
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> <li>• Under ground tank capacity</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Draw of connection</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> </ul>	YES	YES	MR
	<ul style="list-style-type: none"> <li>➤ Access to tank</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Overhead Tank capacity</li> </ul>	5000 L	5000 L	MR
15	Exit Signage	YES	YES	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> <li>➤ Pressurization of Lift Shaft</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Pressurization of lift lobby</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Communication in lift Car</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Fireman's Grounding Switch</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Lift Signage</li> </ul>	N/A	N/A	N/A
17.	Standby power supply	YES	YES	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> <li>➤ Total area</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Location</li> </ul>	N/A	N/A	N/A
19.	Fire control room			
	<ul style="list-style-type: none"> <li>➤ Detector system panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Flow Switch Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ PA System Panel</li> </ul>	N/A	N/A	N/A

RPM Max Restaurant, 40, Basant lok, Vasant Vihar, ND

	➤ Batter backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renew Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer


Name



Designation


Signature of the Inspecting Officer

Name



ATUL GARS

Designation



DEFO/KOVAR