

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

NO.F6/DFS/MS/Auditorium/2013/ 759

Dated: 21/02/2013

FIRE SAFETY CERTIFICATE

Certified that **Triveni Kala Sagam Auditorium located at 205, Tansen Marg, New Delhi** was granted NOC by this department vide letter No. F.6/DFS/MS/GH/2004/397 dated 19-02-2004. The premises was re-inspected by the officers concerned of this department on 15-02-2013 in the presence of Mr. Punit Sharma, Admin Officer of the Auditorium and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and that the premises / building is fit for occupancy class **Assembly (Auditorium)** with effect from 21/2/13 for a period of **3(three)** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi fire service Rules,2010.

Issued on 21/2/13 at New Delhi by.


21/2
**Chief Fire Officer
Delhi Fire Service**

Copy to: -

1. The Addl.C.P (Lic.), Police Station, Defence Colony, 1st floor, New Delhi w.r.t. your letter No. 4746-51/Addl.C.P./Lic(H) dated 31-01-13.
2. The Admin Officer, Triveni Kala Sagam Auditorium, 205, Tansen Marg, New Delhi

Conditions for the validity of fire safety certificate

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Triveni Kala Sagam, 205, Tansen Marg, New Delhi-110001
2. Type of Occupancy : Assembly (Auditorium)
3. Type of Case : Renewal
4. Details of previous NOC : Letter No. F6/MS/DFS/2004/397 Dated: 19.02.2004
5. Fire Safety directives letter No : N.A
6. Date of inspection : 01.01.2013
7. Name of the Inspecting Officers : Dharamvir Singh Yadav , DO(CD), M.K.Chattopadhyay, ADO(CC)
8. Name and designation of officers
from the building side : Punit Sharma, Admin Officer
9. Year of Construction : Starting year 1981 (1975)
10. Applicant's letter No. : 4746-51/Addl. C.P./Lic (Amst) dated 31.01.2013

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC ^{1/BBL} Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6 mts	60 Feet Approx.	MR
	• Gate width	4.5 mts	4.5 mts	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	—	—	—
	• Upper Floors	02	02	MR
	• Basements	02	02	MR
	b. Width of staircases	—	—	—
	• Upper Floors	0.77 & 1.40 mts	Provided	MR
	• Basements	1.70 & 1.22 mts	Provided	MR
	c. Protection of exits	—	—	—
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01	01	MR
	g. Width of Corridor	1.5 mts	1.5 mts	MR
	h. Door Size	1.80 mts, 1.90 mts	Provided	MR
		—	—	—
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A

	<ul style="list-style-type: none"> Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hour	Exhaust Fans	MR
		12 a/c per hour	Natural Ventilation	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	35 W.Co ₂ ,ABC, Co ₂ , ISI marked	Provided	MR
			Provided	MR
			Provided	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	03 nos. in Auditorium 30 m 5 mm	Provided	MR
			Provided	MR
			Provided	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke Ground Floor N/A Generator Near Gate	Provided Provided N/A Provided Provided	MR MR N/A MR MR
8	MOEFA	Yes	Provided	MR
9	Public Address System.	Yes	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	Yes N/A N/A	Provided N/A N/A	MR N/A N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	100 mm 01 01	Provided 01 01	MR 01 01


12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level	(1)1630 LPM (2) 1250 LPM	Provided	MR
	➤ Discharge of pump	40 mts	Provided	MR
	➤ Head of the pump	Required	150 KVA Provided	MR
	➤ Power Supply	Yes	Provided	MR
	➤ Auto Starting of pump			
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	25,000 lts	Provided	MR
15	Exit Signage.	Yes	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A

	<ul style="list-style-type: none"> • Fireman's Grounding Switch 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Lift Signage 	N/A	N/A	N/A
17	Standby power supply	D.G. Set	150 KVA Provided	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Flow Switch Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • PA System Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Batter backup 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Building Floor Plans 	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	02 ABC type fire extinguishers provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to /grant / renew Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Note:- Triveni Kala Sangam Auditorium is located at ground & mezzanine floor of a building comprised of basement, ground, mezzanine and two upper floors.



M.K.CHATTOPADHYAY
Asstt. Div. Officer (CC)



DHARAMVIR SINGH YADAV
Divisional Officer (CD)